

Issues

| # | Project | Tracker | ID | Source | Status | Priority | Standard(s) | Subject | Updated |
|------|---------|---------|----|--------|--------|----------|-------------|--|---------------------|
| 6657 | Server | Issues | | | Closed | Low | | Annex H certificate 9c missing (xx/xx) | 03/01/2024 10:09 AM |
| 6491 | Server | Issues | | | Closed | Low | | Incorrect reference | 03/01/2024 10:06 AM |
| 6320 | Server | Issues | | | Closed | Low | | Ct24 description uses not defined in the standard term: Internal Controllable Objects | 03/01/2024 10:04 AM |
| 6215 | Server | Issues | | | Closed | Low | | ED2 Amendment 1 TP1.2 Editorial - Change references to Table 54 -> Table 21 | 03/01/2024 10:00 AM |
| 657 | Server | Issues | | | Closed | Low | | Publish/subscribe enum with negative value | 03/01/2024 09:49 AM |
| 656 | Server | Issues | | | Closed | Low | | Publish/subscribe enum with value > 127 | 03/01/2024 09:48 AM |
| 6674 | Server | Issues | | | Closed | Normal | | Discuss changes to submission form and Certificates | 03/01/2024 10:10 AM |
| 6658 | Server | Issues | | | Closed | Normal | | Certificate template page 1 and page 2 seems to be disconnected | 03/01/2024 10:09 AM |
| 6633 | Server | Issues | | | Closed | Normal | | sRp15, sBr15 test description contains doName="MMXU...", while MMXU is InClass, not doName | 03/01/2024 10:08 AM |
| 6614 | Server | Issues | | | Closed | Normal | | New DO required for routable GOOSE and SMV service tracking - 1701 | 03/01/2024 10:08 AM |
| 6598 | Server | Issues | | | Closed | Normal | | Using the same dataset in URCB, BRCB and GoCB | 03/01/2024 10:08 AM |
| 6541 | Server | Issues | | | Closed | Normal | | sMdl15 allow SCL floating point value can have minor difference in DUT | 03/01/2024 10:07 AM |
| 6519 | Server | Issues | | | Closed | Normal | | Need to be able to test 61850-7-420 (Ed2.1) | 03/01/2024 10:07 AM |
| 6518 | Server | Issues | | | Closed | Normal | | Functional constraint object non-volatility ambiguous - TISSUE 1822 | 03/01/2024 10:06 AM |
| 6473 | Server | Issues | | | Closed | Normal | | Inconsistency in LPHD requirements - Tissue 1752 | 03/01/2024 10:06 AM |
| 6470 | Server | Issues | | | Closed | Normal | | SynchSrcID support mandatory for devices that support IEC 61850-9-3 (tissue 1692) | 03/01/2024 10:05 AM |
| 6453 | Server | Issues | | | Closed | Normal | | sSvs8 the minimum svID length 4chars is not right against test case sSvp14 | 03/01/2024 10:04 AM |
| 6291 | Server | Issues | | | Closed | Normal | | sGos13 - Remove/deprecate PIXIT Gs12 | 03/01/2024 10:04 AM |
| 6281 | Server | Issues | | | Closed | Normal | | Templates for Ed. 2.1 conformance statements | 03/01/2024 10:04 AM |
| 6280 | Server | Issues | | | Closed | Normal | | sSBOes8 check Cancel consistency with SelectWithValue | 03/01/2024 10:04 AM |
| 6279 | Server | Issues | | | Closed | Normal | | sSBOs8 - Test and Check in Cancel after Select request | 03/01/2024 10:03 AM |
| 6278 | Server | Issues | | | Closed | Normal | | Test case sSBOes1, sDOes1 miss referring to PIXIT entries | 03/01/2024 10:03 AM |
| 6277 | Server | Issues | | | Closed | Normal | | sCtl4 (stSeld) shall be mandatory in Ed2 Amend 1 | 03/01/2024 10:02 AM |
| 6276 | Server | Issues | | | Closed | Normal | | sGop13 does not consider that dataset with maximumAttributes number of FCD may be too big for GOOSE | 03/01/2024 10:02 AM |
| 6269 | Server | Issues | | | Closed | Normal | | sSrv9, sSrv10: change Table 3 to Table D.1 reference | 03/01/2024 10:01 AM |
| 6255 | Server | Issues | | | Closed | Normal | | ED2.0 TP2.0.6 has sGos23 but PIXIT template misses the entry Gs13 while in TP1.2 ED2.1 the Gs13 has Amd1 Ed only | 03/01/2024 10:01 AM |
| 6227 | Server | Issues | | | Closed | Normal | | sDoc5 GSESettings/SMVsettings apply for SendGOOSE/SMVmessage not SetGoCBValues/SetMsvCBValues | 03/01/2024 10:01 AM |

| # | Project | Tracker | ID | Source | Status | Priority | Standard(s) | Subject | Updated |
|------|-------------|---------|----|--------|--------|----------|-------------|--|---------------------|
| 6214 | Server | Issues | | | Closed | Normal | | ED2 sCtl14 refer to PIXIT entry Ct16 which is a ED1 only PIXIT entry | 03/01/2024 10:00 AM |
| 6213 | Server | Issues | | | Closed | Normal | | sSvsN1 - confRev-1 not possible for backwards config | 03/01/2024 10:00 AM |
| 6211 | Server | Issues | | | Closed | Normal | | TP1.2 Certificate template makes sSvP12 mandatory while it shall be optional | 03/01/2024 10:00 AM |
| 6210 | Server | Issues | | | Closed | Normal | | sSvs4 remove PIXIT entry Svs3 | 03/01/2024 09:59 AM |
| 6203 | Server | Issues | | | Closed | Normal | | sSvs6 - Test configuration does not consider available bandwidth | 03/01/2024 09:59 AM |
| 6198 | Server | Issues | | | Closed | Normal | | How to interpret SCL with Services element in the IED and in the AccessPoint? | 03/01/2024 09:59 AM |
| 6193 | Server | Issues | | | Closed | Normal | | sRpN5 does not test for the case where URCBs are association based (non-indexed). | 03/01/2024 09:58 AM |
| 6192 | Server | Issues | | | Closed | Normal | | Polarity of neutral in WYE | 03/01/2024 09:58 AM |
| 6188 | Server | Issues | | | Closed | Normal | | sSBOs8 does not consider PIXIT Ct13 | 03/01/2024 09:58 AM |
| 6169 | Server | Issues | | | Closed | Normal | | verify IED can subscribe to GOOSE/SV from ServerAt accesspoint | 03/01/2024 09:57 AM |
| 6157 | Server | Issues | | | Closed | Normal | | sCnf/sMdl not applicable for test equipment | 03/01/2024 09:57 AM |
| 5959 | Server | Issues | | | Closed | Normal | | sSvp3 remove random and allow synSourceID=TRUE for backwards compatible config | 03/01/2024 09:56 AM |
| 5958 | Server | Issues | | | Closed | Normal | | sTm2 allow a more accurate Time Accuracy as documented | 03/01/2024 09:56 AM |
| 5954 | Server | Issues | | | Closed | Normal | | sGop10 detail test missing | 03/01/2024 09:55 AM |
| 5948 | Server | Issues | | | Closed | Normal | | sSvp22 detail is missing in TP1.2 (editorial) | 03/01/2024 09:55 AM |
| 5914 | Server | Issues | | | Closed | Normal | | Verify that LPHD.Sim is not affected by LLN0.Beh | 03/01/2024 09:54 AM |
| 5913 | Server | Issues | | | Closed | Normal | | sSrvN1e and sSrvN3 change condition SCL FC=CF/DC/SP with valKind=Set | 03/01/2024 09:54 AM |
| 5912 | Server | Issues | | | Closed | Normal | | sSrv6 checking the read-only part is always applicable | 03/01/2024 09:54 AM |
| 5910 | Server | Issues | | | Closed | Normal | | Need to test that IEDs support 1 Step and 2 Step clocks: IOP 2022 | 03/01/2024 09:53 AM |
| 5907 | Server | Issues | | | Closed | Normal | | sCtl26 - Cancel a direct control object | 03/01/2024 09:53 AM |
| 5905 | Server | Issues | | | Closed | Normal | | sSrvN4 is mandatory, used SetDataValues service is optional in PICS and may not be not supported | 03/01/2024 09:53 AM |
| 5362 | Server | Issues | | | Closed | Normal | | sGop2 and sGop4 check minimum MinTime and minimum MaxTime | 03/01/2024 09:52 AM |
| 5326 | Server | Issues | | | Closed | Normal | | sSBOes8 incorrectly requires addCause=blocked-by-mode | 03/01/2024 09:49 AM |
| 652 | Server | Issues | | | Closed | Normal | | Publisher can use maximum number of dataset elements | 03/01/2024 09:48 AM |
| 6566 | Server | Issues | | | Closed | Normal | | Description discrepancy LTMS between Source and Channels - 1859 | 11/28/2023 08:18 AM |
| 6564 | Server | Issues | | | Closed | Normal | | Functional constraint object non-volatility ambiguous - 1822 | 11/14/2023 09:06 AM |
| 6567 | Server | Issues | | | Closed | Normal | | Semantic of PMRI.StrInhTmm -1856 | 11/14/2023 09:05 AM |
| 6570 | Server | Issues | | | Closed | Normal | | RSYN Rel mandatory? - 1766 | 11/14/2023 09:04 AM |
| 6527 | SCL Tooling | Issues | | | Closed | Normal | | ICT Ed2.1 Certificate template mismatches | 11/14/2023 08:36 AM |
| 6526 | SCL Tooling | Issues | | | Closed | Normal | | Revision 0.7 (final draft) should be 1.0 | 11/14/2023 08:35 AM |
| 6525 | SCL Tooling | Issues | | | Closed | Normal | | Ed2.1 tTf4 and tTf5 expected result mismatch | 11/14/2023 08:35 AM |

| # | Project | Tracker | ID | Source | Status | Priority | Standard(s) | Subject | Updated |
|------|---------|---------|----|--------|--------|----------|-------------|---|---------------------|
| 6209 | Server | Issues | | | Closed | Normal | | When does the one packet with SmpCnt=0 is missing in step 2 of sSvsN6 | 02/21/2023 08:14 AM |
| 5319 | Server | Issues | | | Closed | Normal | | T1782 sCtl7 addcause "inconsistent-parameters" when check=00 not-supported | 11/01/2022 08:28 AM |
| 5289 | Server | Issues | | | Closed | Normal | | Ed2.1 Server TP 1.1 Does not include 2.0 server PIXIT Gs12 | 07/27/2022 10:39 AM |
| 637 | Server | Issues | | | Closed | Normal | | sFt4 missing expected result for step 3 and 4 | 06/14/2022 08:29 AM |
| 635 | Server | Issues | | | Closed | Normal | | sTm7 mandatory? | 06/14/2022 08:29 AM |
| 634 | Server | Issues | | | Closed | Normal | | sCnf11 allow "none" as well | 06/14/2022 08:28 AM |
| 616 | Server | Issues | | | Closed | Normal | | sCnf10 in Ed2 remove voltagelevel and bay name TEMPLATE | 06/14/2022 08:28 AM |
| 638 | Server | Issues | | | Closed | Normal | | sCtl28 typo tOpOK and opOK (should be tOpOk and opOk) | 09/14/2021 06:50 AM |
| 639 | Server | Issues | | | Closed | Normal | | Boolean ASN.1 encoding 0x02 for MMS client/server | 09/14/2021 06:50 AM |
| 642 | Server | Issues | | | Closed | Normal | | Blocked/Test-blocked does not impact CSWI->XCBR interface - Tissue Ready to Be Tested | 09/14/2021 06:48 AM |
| 678 | Server | Issues | | | Closed | Normal | | MirrorBlockCommand state not used for LNs without direct process interface (sCtl28) | 09/14/2021 06:44 AM |
| 641 | Server | Issues | | | Closed | Normal | | Integrity will be buffered - Tissue Ready for Test Development | 03/02/2021 08:52 AM |
| 6595 | Server | Issues | | | Closed | High | | Configuration and datamodel test cases not applicable for test equipment | 03/01/2024 10:07 AM |
| 668 | Server | Issues | | | Closed | High | | MirrorBlockCommand state not used for LNs without direct process interface (sCtl28) | 06/14/2022 08:30 AM |
| 5917 | Server | Issues | | | Closed | Urgent | | 'Expected result' for some test cases of CB9b: GOOSE subscribe | 03/01/2024 09:55 AM |