

## Issues

#	Project	Tracker	ID	Source	Status	Priority	Standard(s)	Subject	Updated
6728	Client	Issues			In Progress	Normal		cSg13 refers to PIXIT entry Sg5/Sg6 but not clarified in the expected result	05/06/2024 09:34 AM
6776	Client	Issues			In Progress	Normal		cSBOs4 requires different control value	05/06/2024 08:44 AM
6769	Server	Issues			In Progress	Normal		sGop9 should allow NdsCom to be set in the GOOSE message	05/06/2024 08:08 AM
6753	Server	Issues			In Progress	Normal		sGos20, sGos21 force DUT as Subscriber to ignore future edition dataset elements, while 61850-7-1 expects achievable forward compatibility	05/06/2024 07:56 AM
6723	Server	Issues			In Progress	Normal		GOOSE destination MAC address according Amd1: PIXIT Gs1 mismatches enhancement of sGos5	05/02/2024 10:01 AM
6722	Server	Issues			In Progress	Normal		sGop10 PIXIT reference needed ?	05/02/2024 09:41 AM
6724	Client	Issues			In Progress	Normal		GOOSE Subscriber sGos12 test expects DUT to _send_ a GOOSE message	04/30/2024 08:17 AM
6777	Client	Issues			In Progress	Normal		SCD import and Tool Functionality test procedures	04/30/2024 08:13 AM
6749	Server	Issues			Resolved	High		Clarification of ExtRef attributes usage - TISSUE 1818	04/16/2024 08:31 AM
6750	Server	Issues			Resolved	High		sAddr length - TISSUE 1885	04/16/2024 08:17 AM
6710	Server	Issues			Resolved	Normal		sSrv13 does not specify that the lower hierarchy Mod.stVal shall not change	04/02/2024 02:42 PM
6688	Client	Issues			Resolved	Normal		cSrvN10 - Ed1 specific error codes do not exist for MMS GetNameList	04/02/2024 08:42 AM
6727	Client	Issues			Resolved	Normal		cDsN1bc, cFtN2 have no non-Ed2 specific error code	04/02/2024 08:42 AM
6697	Server	Issues			Resolved	Normal		sRpN9 does not specify the expected access error by negative response on SetURCBValues	04/02/2024 08:40 AM
6674	Server	Issues			Closed	Normal		Discuss changes to submission form and Certificates	03/01/2024 10:10 AM
6658	Server	Issues			Closed	Normal		Certificate template page 1 and page 2 seems to be disconnected	03/01/2024 10:09 AM
6657	Server	Issues			Closed	Low		Annex H certificate 9c missing (xx/xx)	03/01/2024 10:09 AM
6633	Server	Issues			Closed	Normal		sRp15, sBr15 test description contains doName="MMXU...", while MMXU is InClass, not doName	03/01/2024 10:08 AM
6614	Server	Issues			Closed	Normal		New DO required for routable GOOSE and SMV service tracking - 1701	03/01/2024 10:08 AM
6598	Server	Issues			Closed	Normal		Using the same dataset in URCB, BRCB and GoCB	03/01/2024 10:08 AM
6595	Server	Issues			Closed	High		Configuration and datamodel test cases not applicable for test equipment	03/01/2024 10:07 AM
6541	Server	Issues			Closed	Normal		sMdl15 allow SCL floating point value can have minor difference in DUT	03/01/2024 10:07 AM
6519	Server	Issues			Closed	Normal		Need to be able to test 61850-7-420 (Ed2.1)	03/01/2024 10:07 AM
6518	Server	Issues			Closed	Normal		Functional constraint object non-volatility ambiguous - TISSUE 1822	03/01/2024 10:06 AM
6491	Server	Issues			Closed	Low		Incorrect reference	03/01/2024 10:06 AM
6473	Server	Issues			Closed	Normal		Inconsistency in LPHD requirements - Tissue 1752	03/01/2024 10:06 AM
6470	Server	Issues			Closed	Normal		SynchSrcID support mandatory for devices that support IEC 61850-9-3 (tissue 1692)	03/01/2024 10:05 AM

#	Project	Tracker	ID	Source	Status	Priority	Standard(s)	Subject	Updated
6453	Server	Issues			Closed	Normal		sSvs8 the minimum svID length 4chars is not right against test case sSvp14	03/01/2024 10:04 AM
6320	Server	Issues			Closed	Low		Ct24 description uses not defined in the standard term: Internal Controllable Objects	03/01/2024 10:04 AM
6291	Server	Issues			Closed	Normal		sGos13 - Remove/deprecate PIXIT Gs12	03/01/2024 10:04 AM
6281	Server	Issues			Closed	Normal		Templates for Ed. 2.1 conformance statements	03/01/2024 10:04 AM
6280	Server	Issues			Closed	Normal		sSBOes8 check Cancel consistency with SelectWithValue	03/01/2024 10:04 AM
6279	Server	Issues			Closed	Normal		sSBOs8 - Test and Check in Cancel after Select request	03/01/2024 10:03 AM
6278	Server	Issues			Closed	Normal		Test case sSBOes1, sDOes1 miss referring to PIXIT entries	03/01/2024 10:03 AM
6277	Server	Issues			Closed	Normal		sCtl4 (stSeld) shall be mandatory in Ed2 Amend 1	03/01/2024 10:02 AM
6276	Server	Issues			Closed	Normal		sGop13 does not consider that dataset with maximumAttributes number of FCD may be too big for GOOSE	03/01/2024 10:02 AM
6269	Server	Issues			Closed	Normal		sSrv9, sSrv10: change Table 3 to Table D.1 reference	03/01/2024 10:01 AM
6255	Server	Issues			Closed	Normal		ED2.0 TP2.0.6 has sGos23 but PIXIT template misses the entry Gs13 while in TP1.2 ED2.1 the Gs13 has Amd1 Ed only	03/01/2024 10:01 AM
6227	Server	Issues			Closed	Normal		sDoc5 GSESettings/SMVsettings apply for SendGOOSE/SMVmessage not SetGoCBValues/SetMsvCBValues	03/01/2024 10:01 AM
6215	Server	Issues			Closed	Low		ED2 Amendment 1 TP1.2 Editorial - Change references to Table 54 -> Table 21	03/01/2024 10:00 AM
6214	Server	Issues			Closed	Normal		ED2 sCtl14 refer to PIXIT entry Ct16 which is a ED1 only PIXIT entry	03/01/2024 10:00 AM
6213	Server	Issues			Closed	Normal		sSvsN1 - confRev-1 not possible for backwards config	03/01/2024 10:00 AM
6211	Server	Issues			Closed	Normal		TP1.2 Certificate tempalte makes sSvP12 mandatory while it shall be optional	03/01/2024 10:00 AM
6210	Server	Issues			Closed	Normal		sSvs4 remove PIXIT entry Svs3	03/01/2024 09:59 AM
6203	Server	Issues			Closed	Normal		sSvs6 - Test configuration does not consider available bandwidth	03/01/2024 09:59 AM
6198	Server	Issues			Closed	Normal		How to interpret SCL with Services element in the IED and in the AccessPoint?	03/01/2024 09:59 AM
6193	Server	Issues			Closed	Normal		sRpN5 does not test for the case where URCS are association based (non-indexed).	03/01/2024 09:58 AM
6192	Server	Issues			Closed	Normal		Polarity of neutral in WYE	03/01/2024 09:58 AM
6188	Server	Issues			Closed	Normal		sSBOs8 does not consider PIXIT Ct13	03/01/2024 09:58 AM
6169	Server	Issues			Closed	Normal		verify IED can subscribe to GOOSE/SV from ServerAt accesspoint	03/01/2024 09:57 AM
6157	Server	Issues			Closed	Normal		sCnf/sMdl not applicable for test equipment	03/01/2024 09:57 AM
5959	Server	Issues			Closed	Normal		sSvp3 remove random and allow synSourceID=TRUE for backwards compatible config	03/01/2024 09:56 AM
5958	Server	Issues			Closed	Normal		sTm2 allow a more accurate Time Accuracy as documented	03/01/2024 09:56 AM

#	Project	Tracker	ID	Source	Status	Priority	Standard(s)	Subject	Updated
5954	Server	Issues			Closed	Normal		sGop10 detail test missing	03/01/2024 09:55 AM
5948	Server	Issues			Closed	Normal		sSvp22 detail is missing in TP1.2 (editorial)	03/01/2024 09:55 AM
5917	Server	Issues			Closed	Urgent		'Expected result' for some test cases of CB9b: GOOSE subscribe	03/01/2024 09:55 AM
5914	Server	Issues			Closed	Normal		Verify that LPHD.Sim is not affected by LLN0.Beh	03/01/2024 09:54 AM
5913	Server	Issues			Closed	Normal		sSrvN1e and sSrvN3 change condition SCL FC=CF/DC/SP with valKind=Set	03/01/2024 09:54 AM
5912	Server	Issues			Closed	Normal		sSrv6 checking the read-only part is always applicable	03/01/2024 09:54 AM
5910	Server	Issues			Closed	Normal		Need to test that IEDs support 1 Step and 2 Step clocks: IOP 2022	03/01/2024 09:53 AM
5907	Server	Issues			Closed	Normal		sCtl26 - Cancel a direct control object	03/01/2024 09:53 AM
5905	Server	Issues			Closed	Normal		sSrvN4 is mandatory, used SetDataValues service is optional in PICS and may not be not supported	03/01/2024 09:53 AM
5362	Server	Issues			Closed	Normal		sGop2 and sGop4 check minimum MinTime and minimum MaxTime	03/01/2024 09:52 AM
5326	Server	Issues			Closed	Normal		sSBOes8 incorrectly requires addCause=blocked-by-mode	03/01/2024 09:49 AM
657	Server	Issues			Closed	Low		Publish/subscribe enum with negative value	03/01/2024 09:49 AM
656	Server	Issues			Closed	Low		Publish/subscribe enum with value > 127	03/01/2024 09:48 AM
652	Server	Issues			Closed	Normal		Publisher can use maximum number of dataset elements	03/01/2024 09:48 AM
6489	GOOSE Performance	Issues			Resolved	Normal		Reducing the needed resources for time correlated subscribed GOOSE not used for ping-pong	01/23/2024 08:05 AM
6631	SCL Tooling	Issues			Resolved	Normal		tTf1 (mustUnderstand) for the ICT test needs clarification	01/09/2024 08:59 AM
6655	Client	Issues			Resolved	Normal		cLogN5 is missing in table A4.2 and certificate template	01/09/2024 08:28 AM
6654	Client	Issues			Resolved	Normal		Tracking numbering mismatch Ed2 <> Ed2.1	01/09/2024 08:27 AM
6566	Server	Issues			Closed	Normal		Description discrepancy LTMS between Source and Channels - 1859	11/28/2023 08:18 AM
6564	Server	Issues			Closed	Normal		Functional constraint object non-volatility ambiguous - 1822	11/14/2023 09:06 AM
6567	Server	Issues			Closed	Normal		Semantic of PMRI.StrInhTmm -1856	11/14/2023 09:05 AM
6570	Server	Issues			Closed	Normal		RSYN Rel mandatory? - 1766	11/14/2023 09:04 AM
6565	Server	Issues			Rejected	Normal		Added more precise qualifications to TmSrcTyp - 1883	11/14/2023 09:03 AM
6568	Server	Issues			Rejected	Normal		The definition of LTMS.TmSrc is different in the actual AMD1 and Consolidated Version - 1846	11/14/2023 08:37 AM
6527	SCL Tooling	Issues			Closed	Normal		ICT Ed2.1 Certificate template mismatches	11/14/2023 08:36 AM
6526	SCL Tooling	Issues			Closed	Normal		Revision 0.7 (final draft) should be 1.0	11/14/2023 08:35 AM
6525	SCL Tooling	Issues			Closed	Normal		Ed2.1 tTf4 and tTf5 expected result mismatch	11/14/2023 08:35 AM
6483	Server	Issues			Resolved	Normal		Need to be able to test 61850-7-420	09/05/2023 08:14 AM
6488	GOOSE Performance	Issues			Resolved	Low		Incorrect reference	09/05/2023 08:08 AM
6471	Client	Issues			Resolved	Normal		Select.response+ (Tissue 1753)	08/22/2023 08:10 AM

#	Project	Tracker	ID	Source	Status	Priority	Standard(s)	Subject	Updated
6465	GOOSE Performance	Issues			Resolved	Normal		The Ed2 GOOSE performance also apply for Ed2Amd1	08/08/2023 08:42 AM
6463	Client	Issues			Resolved	Normal		cSrv7, cSvrN3 some clients only read DA (not DO)	07/25/2023 08:07 AM
6324	SCL Tooling	Issues			Rejected	Normal		sCnf6 - not all extRef require intAddr not referring to external device	05/16/2023 08:44 AM
6327	SCL Tooling	Issues			Resolved	Normal		tTf2 - export CID file only for Ed2.1?	05/16/2023 08:20 AM
6326	SCL Tooling	Issues			Resolved	Normal		tlie1 - remove step 10-14 to undo previous changes	05/16/2023 08:09 AM
6325	SCL Tooling	Issues			Resolved	Normal		PIXIT missing entries on tlie1 "when supported"	05/16/2023 08:04 AM
6323	SCL Tooling	Issues			Resolved	Normal		tTf5 IED name=None is not allowed tissue #1365	05/02/2023 08:20 AM
6208	Server	Issues			Rejected	Normal		sSvsN2 in TP1.2 does not check the situation where the DUT checks ConfRev	03/21/2023 08:20 AM
6209	Server	Issues			Closed	Normal		When does the one packet with SmpCnt=0 is missing in step 2 of sSvsN6	02/21/2023 08:14 AM
6174	Server	Issues			Rejected	Normal		Amend sCtl7 to test both interlocking check and check synchronizing ?	02/07/2023 08:24 AM
6200	SCL Tooling	Issues			Resolved	Normal		tTf1 change Ed2/2007B to Ed2.1/2007B4	01/24/2023 08:33 AM
6206	Server	Issues			Rejected	Normal		Type and size of Length field value (TLV) encoding in SV	01/11/2023 06:19 AM
5319	Server	Issues			Closed	Normal		T1782 sCtl7 addcause "inconsistent-parameters" when check=00 not-supported	11/01/2022 08:28 AM
5347	Server	Issues			Resolved	Normal		How should time correlated GOOSE change status in GOOSE Performance test	10/04/2022 09:11 AM
5906	Server	Issues			Rejected	Normal		sCnf51 at least one LPHD	09/06/2022 08:20 AM
5120	SCL Tooling	Issues			Resolved	Normal		LGOS/LSVS reference with functional naming (SCL)	08/09/2022 08:40 AM
5289	Server	Issues			Closed	Normal		Ed2.1 Server TP 1.1 Does not include 2.0 server PIXIT Gs12	07/27/2022 10:39 AM
668	Server	Issues			Closed	High		MirrorBlockCommand state not used for LNs without direct process interface (sCtl28)	06/14/2022 08:30 AM
637	Server	Issues			Closed	Normal		sFt4 missing expected result for step 3 and 4	06/14/2022 08:29 AM
635	Server	Issues			Closed	Normal		sTm7 mandatory?	06/14/2022 08:29 AM
634	Server	Issues			Closed	Normal		sCnf11 allow "none" as well	06/14/2022 08:28 AM
616	Server	Issues			Closed	Normal		sCnf10 in Ed2 remove voltagelevel and bay name TEMPLATE	06/14/2022 08:28 AM
638	Server	Issues			Closed	Normal		sCtl28 typo tOpOK and opOK (should be tOpOk and opOk)	09/14/2021 06:50 AM
639	Server	Issues			Closed	Normal		Boolean ASN.1 encoding 0x02 for MMS client/server	09/14/2021 06:50 AM
642	Server	Issues			Closed	Normal		Blocked/Test-blocked does not impact CSWI->XCBR interface - Tissue Ready to Be Tested	09/14/2021 06:48 AM
678	Server	Issues			Closed	Normal		MirrorBlockCommand state not used for LNs without direct process interface (sCtl28)	09/14/2021 06:44 AM
748	Server	Issues			Resolved	Normal		sGos9 use SPS when INS subscribe is not supported	07/27/2021 10:07 AM
636	Client	Issues			Resolved	High		Mandate RCB reservation for Ed2.0 client and Amd1 server	04/20/2021 02:23 PM

#	Project	Tracker	ID	Source	Status	Priority	Standard(s)	Subject	Updated
641	Server	Issues			Closed	Normal		Integrity will be buffered - Tissue Ready for Test Development	03/02/2021 08:52 AM