

## Issues

#	Project	Tracker	ID	Source	Status	Priority	Standard(s)	Subject	Updated
660	IEC 61850 User Feedback Task Force	Support	1	WG10	Closed	Normal	IEC 61850-6, TR IEC 61850-90-30	IED model documentation	11/21/2023 09:00 AM
6184	IEC 61850 User Feedback Task Force	Bug			Closed	Normal	IEC 61850-7-3 Ed.2 Amd.1	Trigger option 'dchg' for settings of FC=SG	06/05/2023 01:59 AM
5077	IEC 61850 User Feedback Task Force	Feature	1	MH	Closed	Normal	IEC61850 7-1	Location of SGCB in LD structures	03/14/2023 09:10 AM
6186	IEC 61850 User Feedback Task Force	Feature			Closed	Normal	IEC 61850-7-2 Clause 16	Changing the ActSG while reservation by another client is ongoing	12/06/2022 09:39 AM
5143	IEC 61850 User Feedback Task Force	Support			Closed	Normal		how do we manage IEDs with flexible control block creation, but which do not allow creating them anywhere in the datamodel?	06/21/2022 08:57 AM
5090	IEC 61850 User Feedback Task Force	Feature	9	H30	Closed	Normal	IEC 61850-7-1 Ed2.1	Mod inheritance when multiple root LD's (GrRef's) exist	12/07/2021 08:19 AM
664	IEC 61850 User Feedback Task Force	Improvement	9	H30	Closed	Normal		Recommended improvements to TISSUE Process	07/13/2021 04:05 PM