

Issues

#	Project	Tracker	ID	Source	Status	Priority	Standard(s)	Subject	Updated
6714	IEC TC57 WG10 Future Work	WG10 Future Work		IEC PAS 61850-90-3	New	Normal		Improve the models used for power regulation	02/20/2024 11:04 AM
6358	IEC TC57 WG10 Future Work	WG10 Future Work			New	Normal	IEC 61850	IEC 61850-7-4 list of abbreviations	10/26/2023 04:56 AM
6316	IEC TC57 WG10 Future Work	WG10 Future Work		RTE	New	Normal	IEC 61850-6	Clarification of using of ValKind, Vallmport.	10/26/2023 04:58 AM
6186	IEC 61850 User Feedback Task Force	Feature			Closed	Normal	IEC 61850-7-2 Clause 16	Changing the ActSG while reservation by another client is ongoing	12/06/2022 09:39 AM
6184	IEC 61850 User Feedback Task Force	Bug			Closed	Normal	IEC 61850-7-3 Ed.2 Amd.1	Trigger option 'dchg' for settings of FC=SG	06/05/2023 01:59 AM
5944	IEC TC57 WG10 Future Work	WG10 Future Work		RTE	New	Normal	IEC 61850-7-4	Need to create a new LN of group P (Protection), as "PCDP" to represent the Pole Discrepancy Protection.	02/08/2024 04:27 AM
5943	IEC TC57 WG10 Future Work	WG10 Future Work		RTE	New	Normal	IEC 61850-7-4	New LN of group L (as "LTED") to represent the dynamic topology of the substation.	02/08/2024 04:35 AM
5942	IEC TC57 WG10 Future Work	WG10 Future Work		RTE	New	Normal	IEC 61850-7-4	Activation and deactivation of a function by configuration.	02/08/2024 04:37 AM
5938	IEC TC57 WG10 Future Work	WG10 Future Work		RTE	New	Normal	IEC 61850-7-4	LN RADR evolution	02/08/2024 04:44 AM
5904	IEC TC57 WG10 Future Work	WG10 Future Work		WG10	New	Normal	IEC 61850-7-4	Introduce alarm and counter DOs in 7-4	02/08/2024 05:22 AM
5143	IEC 61850 User Feedback Task Force	Support			Closed	Normal		how do we manage IEDs with flexible control block creation, but which do not allow creating them anywhere in the datamodel?	06/21/2022 08:57 AM
5091	IEC 61850 User Feedback Task Force	Feature	10	H30	Resolved	Normal	IEC 61850-2	Devices types/acronyms	06/05/2023 01:58 AM
5090	IEC 61850 User Feedback Task Force	Feature	9	H30	Closed	Normal	IEC 61850-7-1 Ed2.1	Mod inheritance when multiple root LD's (GrRef's) exist	12/07/2021 08:19 AM
5077	IEC 61850 User Feedback Task Force	Feature	1	MH	Closed	Normal	IEC61850 7-1	Location of SGCB in LD structures	03/14/2023 09:10 AM
664	IEC 61850 User Feedback Task Force	Improvement	9	H30	Closed	Normal		Recommended improvements to TISSUE Process	07/13/2021 04:05 PM
660	IEC 61850 User Feedback Task Force	Support	1	WG10	Closed	Normal	IEC 61850-6, TR IEC 61850-90-30	IED model documentation	11/21/2023 09:00 AM
647	IEC 61850 User Feedback Task Force	Support	57	ENTSO-E	Resolved	Normal	IEC 61850-7-500	Single phase and multi phase trip indication for the autorecloser	05/09/2023 09:32 AM
627	IEC 61850 User Feedback Task Force	Feature	29	RTE	Resolved	Normal	IEC 61850-7-4	Activation and deactivation of a function by configuration.	05/09/2023 09:32 AM

#	Project	Tracker	ID	Source	Status	Priority	Standard(s)	Subject	Updated
624	IEC 61850 User Feedback Task Force	Support	21	RTE	Resolved	Normal	IEC 61850-6	Clarification of using of ValKind, VallImport.	05/09/2023 09:32 AM
621	IEC 61850 User Feedback Task Force	Feature	17	RTE	In Progress	Normal	IEC 61850-7-4/7-500	New controllable DO in RREC to define the mode of the recloser of the circuit breaker	05/11/2021 10:08 AM
619	IEC 61850 User Feedback Task Force	Feature	15	RTE	Resolved	Normal		New LN of group L (as "LTED") to represent the dynamic topology of the substation.	05/09/2023 09:32 AM
612	IEC 61850 User Feedback Task Force	Feature	11	RTE	Resolved	Normal	IEC 61850-7-4	Need to create a new LN of group P (Protection), as "PCDP" to represent the Pole Discrepancy Protection.	05/09/2023 09:32 AM