

Issues

| # | Project | Tracker | ID | Source | Status | Priority | Standard(s) | Subject | Updated |
|------|---------------------------|------------------|----|--------------------|-------------|----------|------------------------------------|---|---------------------|
| 6726 | 61850-7-5 and 61850-7-500 | IEC61850-7-5 | | RTE | In Progress | Normal | | New LN of group L (as "LTED") to represent the dynamic topology of the substation. | 02/29/2024 09:07 AM |
| 6725 | 61850-7-5 and 61850-7-500 | IEC61850-7-5 | | RTE | In Progress | Normal | | Simultaneous change of InRef.setSrcRef and InRef.setSrcCB for dynamic commutation | 02/29/2024 09:07 AM |
| 6711 | 61850-7-5 and 61850-7-500 | IEC61850-7-5 | | WG10 Fall workshop | In Progress | Low | | SCL Modelling of Fault Measurements (RFMX) | 02/29/2024 08:33 AM |
| 6701 | IEC TC57 WG10 Future Work | WG10 Future Work | | | New | Normal | IEC 61850-7-3 | Integration of proposed and canceled amendment 2 of part 7-3 | 02/08/2024 05:25 AM |
| 6607 | 61850-7-5 and 61850-7-500 | IEC61850-7-5 | | RTE | New | Normal | | Create DO indicating the source of synchronisation | 11/21/2023 08:49 AM |
| 6606 | 61850-7-5 and 61850-7-500 | IEC61850-7-5 | | RTE | New | Normal | | CPU monitoring | 11/21/2023 08:40 AM |
| 6604 | IEC TC57 WG10 Future Work | WG10 Future Work | | TissueDB | New | Normal | IEC 61850-7-4 | IEC61850.Tissue #1754 Event driven schedules - Type of InSyn missing | 02/08/2024 01:42 AM |
| 6579 | IEC TC57 WG10 Future Work | WG10 Future Work | | Vattenfall | New | High | IEC 61850-6 | How to add utility process name to DOs | 02/19/2024 10:43 AM |
| 6578 | IEC TC57 WG10 Future Work | WG10 Future Work | | TF 61850-80-6 | New | Normal | IEC 61850-7-2; IEC 61850-8-1, 80-6 | Extension of the AddCause required to reflect communication issues in multi level control | 02/08/2024 01:50 AM |
| 6561 | IEC TC57 WG10 Future Work | WG10 Future Work | | | New | Normal | IEC 61850-7-4 | Modeling of primary equipment | 10/26/2023 04:20 AM |
| 6448 | IEC TC57 WG10 Future Work | WG10 Future Work | | WG10 Fall workshop | New | Urgent | TR IEC 61850-7-5 | GOOSE treatment as a command | 02/08/2024 01:53 AM |
| 6447 | IEC TC57 WG10 Future Work | WG10 Future Work | | WG10 Fall workshop | New | Low | | Enhanced Quality Information for Measurements (accuracy classes, update periods, filter applied, algorithm applied, etc.) | 02/08/2024 03:16 AM |
| 6446 | IEC TC57 WG10 Future Work | WG10 Future Work | | WG10 Fall workshop | New | Low | TR IEC 61850-7-500 | SCL Modelling of Fault Measurements (RFMX) | 02/08/2024 02:12 AM |
| 6441 | IEC TC57 WG10 Future Work | WG10 Future Work | | WG10 Fall workshop | New | Normal | TR IEC 61850-90-14 | Extensions to "Z" Logical Nodes (e.g. ZBAT) | 10/26/2023 04:10 AM |
| 6439 | IEC TC57 WG10 Future Work | WG10 Future Work | | WG10 Fall workshop | New | High | | Inter-substation GOOSE Naming convention (90-1) | 10/26/2023 03:42 AM |
| 6437 | IEC TC57 WG10 Future Work | WG10 Future Work | | WG10 Fall workshop | New | High | TR IEC 61850-7-5 | Logical Device Inheritance Rules for LocSta | 10/26/2023 03:43 AM |
| 6436 | IEC TC57 WG10 Future Work | WG10 Future Work | | WG10 Fall workshop | New | Low | TR IEC 61850-10-3 | SCL Modelling of the Test Equipment | 02/08/2024 02:36 AM |
| 6435 | IEC TC57 WG10 Future Work | WG10 Future Work | | WG10 Fall workshop | New | Low | IEC 61850-9-2 | Compression of Sample Value Messages | 02/08/2024 05:36 AM |
| 6433 | IEC TC57 WG10 Future Work | WG10 Future Work | | WG10 Fall workshop | New | Low | | SCL Extensions (partial configuration updates in a top-down approach, mixed editions with private CDCs, etc.) | 02/08/2024 03:03 AM |

| # | Project | Tracker | ID | Source | Status | Priority | Standard(s) | Subject | Updated |
|------|---------------------------|------------------|----|---------------------|-------------|----------|--|---|---------------------|
| 6432 | IEC TC57 WG10 Future Work | WG10 Future Work | | WG10 Fall workshop | New | Normal | TR IEC 61850-90-30 | SCL Engineering Lifecycle, Types and Security for SCL files and Elements | 10/26/2023 04:26 AM |
| 6430 | IEC TC57 WG10 Future Work | WG10 Future Work | | WG10 Fall workshop | New | Low | IEC 61850-6 | Management of SCL File Sizes (Compression Techniques, Handling of Privates) | 02/08/2024 03:17 AM |
| 6429 | IEC TC57 WG10 Future Work | WG10 Future Work | | WG10 Fall workshop | New | Normal | IEC 61850-7-4xx | Logical Node Groups with Dedicated Namespaces | 10/26/2023 04:28 AM |
| 6428 | IEC TC57 WG10 Future Work | WG10 Future Work | | WG10 Fall workshop | New | Urgent | IEC 61850-6 | Next Steps with IEC 61850-90-11 (Publish versus Corrigenda) | 10/26/2023 02:47 AM |
| 6427 | IEC TC57 WG10 Future Work | WG10 Future Work | | WG10 Fall workshop | New | Normal | TR IEC 61850-90-3 | New Logical Nodes - Battery Charger | 10/26/2023 04:31 AM |
| 6423 | IEC TC57 WG10 Future Work | WG10 Future Work | | WG10 Fall workshop | New | Normal | TS IEC 61850-80-7 | SCL Control Block | 10/26/2023 04:32 AM |
| 6422 | IEC TC57 WG10 Future Work | WG10 Future Work | | WG10 Fall workshop | New | Urgent | IEC 61850-7-4xx | Consistent Handling of Abbreviations for Data Object Names Within/Across All Domains and Namespaces | 10/26/2023 02:52 AM |
| 6420 | IEC TC57 WG10 Future Work | WG10 Future Work | | WG10 Fall workshop | In Progress | Urgent | IEC 61850-6, IEC 61850-7-x, IEC 61850-8-1, IEC 61850-9-2 | Validation of SCL Files Using Object Constraint Language (OCL) | 10/26/2023 02:57 AM |
| 6419 | IEC TC57 WG10 Future Work | WG10 Future Work | | WG10 Fall workshop | New | Normal | | Logical Nodes for SLD/Topology Aware Functions | 02/09/2024 04:55 AM |
| 6417 | IEC TC57 WG10 Future Work | WG10 Future Work | | WG10 Fall workshop | New | Normal | TR IEC 61850-90-4 | SCL Modelling of the Communication Network and All its Components | 10/26/2023 04:40 AM |
| 6414 | IEC TC57 WG10 Future Work | WG10 Future Work | | WG10 Fall workshop | In Progress | Urgent | | Golden Single Line Diagram For All SCL/GCL/HCL Examples | 10/26/2023 02:58 AM |
| 6413 | IEC TC57 WG10 Future Work | WG10 Future Work | | WG10 Fall workshop | New | Low | IEC 61850-80-7 | Asset Management of Setting & Configuration Data | 02/08/2024 05:32 AM |
| 6412 | IEC TC57 WG10 Future Work | WG10 Future Work | | WG10 Fall workshop | New | Normal | IEC 61850-7-3 | Improved SCL Modelling of Function Inputs (InRef/ExtRef) | 10/26/2023 04:41 AM |
| 6411 | IEC TC57 WG10 Future Work | WG10 Future Work | | WG10 Fall workshop | New | Urgent | TR IEC 61850-7-500, TR IEC 61850-90-3 | Update the Model of Circuit Breaker/Disconnecter Switch | 10/26/2023 03:08 AM |
| 6410 | IEC TC57 WG10 Future Work | WG10 Future Work | | UCA Test. Committee | New | Normal | IEC 61850-7-2 | SBOs to be deprecated in future. | 10/26/2023 04:42 AM |
| 6408 | 61850-7-5 and 61850-7-500 | IEC61850-7-5 | | | New | Normal | | Clarification of addCause | 06/20/2023 08:37 AM |
| 6407 | 61850-7-5 and 61850-7-500 | IEC61850-7-5 | | | New | Normal | | Schedules - allow 3 values per time point | 06/20/2023 08:36 AM |
| 6406 | 61850-7-5 and 61850-7-500 | IEC61850-7-5 | | | New | Normal | | Schedules - add optional data objects to support irregular interval schedules | 06/20/2023 08:36 AM |
| 6405 | 61850-7-5 and 61850-7-500 | IEC61850-7-5 | | | New | Normal | | Schedules - allow updates to single values while schedules are running | 06/20/2023 08:35 AM |
| 6394 | 61850-7-5 and 61850-7-500 | IEC61850-7-5 | | | In Progress | Normal | | Clarifications on the local/remote concept 8/8 | 09/14/2023 08:04 AM |

| # | Project | Tracker | ID | Source | Status | Priority | Standard(s) | Subject | Updated |
|------|------------------------------------|------------------|----|--------|-------------|----------|---------------|--|---------------------|
| 6393 | 61850-7-5 and 61850-7-500 | IEC61850-7-5 | | | In Progress | Normal | | Clarifications on the local/remote concept 7/8 | 10/05/2023 08:55 AM |
| 6392 | 61850-7-5 and 61850-7-500 | IEC61850-7-5 | | | In Progress | Normal | | Clarifications on the local/remote concept 6/8 | 10/05/2023 08:55 AM |
| 6391 | 61850-7-5 and 61850-7-500 | IEC61850-7-5 | | | In Progress | Normal | | Clarifications on the local/remote concept 5/8 | 10/05/2023 08:55 AM |
| 6390 | 61850-7-5 and 61850-7-500 | IEC61850-7-5 | | | In Progress | Normal | | Clarifications on the local/remote concept 4/8 | 10/05/2023 08:55 AM |
| 6389 | 61850-7-5 and 61850-7-500 | IEC61850-7-5 | | | In Progress | Normal | | Clarifications on the local/remote concept 3/8 | 10/05/2023 08:55 AM |
| 6388 | 61850-7-5 and 61850-7-500 | IEC61850-7-5 | | | In Progress | Normal | | Clarifications on the local/remote concept 2/8 | 10/05/2023 08:55 AM |
| 6387 | 61850-7-5 and 61850-7-500 | IEC61850-7-5 | | | New | Normal | | S/S related applications: Auxiliary circuit supervision | 06/14/2023 08:20 AM |
| 6386 | 61850-7-5 and 61850-7-500 | IEC61850-7-5 | | | New | Normal | | Voltage protection: Overvoltage protection - 3ph operate | 06/14/2023 08:20 AM |
| 6385 | 61850-7-5 and 61850-7-500 | IEC61850-7-5 | | | New | Normal | | Voltage protection: Undervoltage protection - 3ph operate | 06/14/2023 08:19 AM |
| 6384 | 61850-7-5 and 61850-7-500 | IEC61850-7-5 | | | New | Normal | | New controllable DO in RREC to define the mode of the recloser of the circuit breaker | 06/14/2023 08:19 AM |
| 6383 | 61850-7-5 and 61850-7-500 | IEC61850-7-5 | | | New | Normal | | Single phase and multi phase trip indication for the autorecloser | 06/14/2023 08:19 AM |
| 6382 | 61850-7-5 and 61850-7-500 | IEC61850-7-5 | | | New | Normal | | Clarification on the ctlModel 1/3 | 06/14/2023 08:18 AM |
| 6380 | 61850-7-5 and 61850-7-500 | IEC61850-7-5 | | | New | Normal | | Clarification on the ctlModel 2/3 | 06/14/2023 08:18 AM |
| 6379 | 61850-7-5 and 61850-7-500 | IEC61850-7-5 | | | New | Normal | | Clarification on the ctlModel 3/3 | 06/14/2023 08:17 AM |
| 6378 | 61850-7-5 and 61850-7-500 | IEC61850-7-5 | | | In Progress | Normal | | Clarifications on the local/remote concept 1/8 | 10/05/2023 08:56 AM |
| 6377 | 61850-7-5 and 61850-7-500 | IEC61850-7-5 | | | New | High | | Update the Switchgear / Breaker Model | 06/14/2023 08:17 AM |
| 6376 | 61850-7-5 and 61850-7-500 | IEC61850-7-5 | | | New | Normal | | LN PDIF – setting for nominal current | 02/13/2024 05:59 AM |
| 6375 | 61850-7-5 and 61850-7-500 | IEC61850-7-5 | | | In Progress | Normal | | XCBR LN new DO to describe withdrawable circuit breaker | 08/24/2023 07:57 AM |
| 6370 | IEC 61850 User Feedback Task Force | Improvement | | | Resolved | Normal | | SBOs to be deprecated in future. | 06/20/2023 09:39 AM |
| 6358 | IEC TC57 WG10 Future Work | WG10 Future Work | | | New | Normal | IEC 61850 | IEC 61850-7-4 list of abbreviations | 10/26/2023 04:56 AM |
| 6316 | IEC TC57 WG10 Future Work | WG10 Future Work | | RTE | New | Normal | IEC 61850-6 | Clarification of using of ValKind, VallImport. | 10/26/2023 04:58 AM |
| 6246 | IEC 61850 User Feedback Task Force | Feature | | | Resolved | Normal | IEC 61850-6 | ExtRef cannot specify a Poll intended to be implemented as a GetDataSetValues request | 06/05/2023 01:58 AM |
| 5966 | IEC TC57 WG10 Future Work | WG10 Future Work | | EDF | New | Normal | | Indicate typical SIUnit for every DO with CDC MV would help users + Add a dedicated attribute in NSD files instead of having it in the description ? | 02/09/2024 04:02 AM |
| 5965 | IEC TC57 WG10 Future Work | WG10 Future Work | | | New | Normal | IEC 61850-7-4 | Schedules - allow updates to single values while schedules are running | 02/08/2024 05:31 AM |

| # | Project | Tracker | ID | Source | Status | Priority | Standard(s) | Subject | Updated |
|------|---------------------------|------------------|----|-------------------|--------|----------|---------------------------------------|---|---------------------|
| 5944 | IEC TC57 WG10 Future Work | WG10 Future Work | | RTE | New | Normal | IEC 61850-7-4 | Need to create a new LN of group P (Protection), as "PCDP" to represent the Pole Discrepancy Protection. | 02/08/2024 04:27 AM |
| 5943 | IEC TC57 WG10 Future Work | WG10 Future Work | | RTE | New | Normal | IEC 61850-7-4 | New LN of group L (as "LTED") to represent the dynamic topology of the substation. | 02/08/2024 04:35 AM |
| 5942 | IEC TC57 WG10 Future Work | WG10 Future Work | | RTE | New | Normal | IEC 61850-7-4 | Activation and deactivation of a function by configuration. | 02/08/2024 04:37 AM |
| 5941 | IEC TC57 WG10 Future Work | WG10 Future Work | | TissueDB | New | Normal | IEC 61850-7-4 | IEC61850.Tissue #1755 Event driven schedules – Add DO to stop schedule by event | 02/08/2024 04:39 AM |
| 5939 | IEC TC57 WG10 Future Work | WG10 Future Work | | RTE | New | Normal | IEC 61850-6 | Mapping of another phases system description to the generic phases phsA, phsB, phsC | 02/08/2024 04:43 AM |
| 5938 | IEC TC57 WG10 Future Work | WG10 Future Work | | RTE | New | Normal | IEC 61850-7-4 | LN RADR evolution | 02/08/2024 04:44 AM |
| 5937 | IEC TC57 WG10 Future Work | WG10 Future Work | | WG10 | New | Normal | IEC 61850-7-4 | Report of current active setting group | 02/08/2024 04:46 AM |
| 5936 | IEC TC57 WG10 Future Work | WG10 Future Work | | TissueDB | New | Normal | IEC 61850-7-4 | IEC61850.Tissue #1756 Event driven schedules – Extend description | 02/08/2024 04:49 AM |
| 5935 | IEC TC57 WG10 Future Work | WG10 Future Work | | MH | New | Normal | IEC 61850-7-3 | Extension of CDC ASG | 02/08/2024 04:51 AM |
| 5934 | IEC TC57 WG10 Future Work | WG10 Future Work | | RTE | New | Normal | TR IEC 61850-10-3, TR IEC 61850-90-20 | Simultaneous change of InRef.setSrcRef and InRef.setSrcCB for dynamic commutation | 02/08/2024 05:02 AM |
| 5933 | IEC TC57 WG10 Future Work | WG10 Future Work | | FNN Germany | New | Normal | IEC 61850-7-4 | Proposal of a new LN class ASWI | 02/08/2024 05:06 AM |
| 5932 | IEC TC57 WG10 Future Work | WG10 Future Work | | IEC 62361-102 R2 | New | Normal | IEC 61850-6 | CIM-61850 Harmonization - Extend list of equipment type codes | 02/08/2024 05:07 AM |
| 5931 | IEC TC57 WG10 Future Work | WG10 Future Work | | IEC 62361-102 R3 | New | Normal | IEC 61850-6 | CIM-61850 Harmonization - Add string attribute psrType to tPowerSystemResource. | 02/08/2024 05:08 AM |
| 5930 | IEC TC57 WG10 Future Work | WG10 Future Work | | IEC 62361-102 R6 | New | Normal | IEC 61850-6 | CIM-61850 Harmonization - mRID attribute in SCL for Equipment, Terminals, ConnectivityNodes | 02/08/2024 05:08 AM |
| 5929 | IEC TC57 WG10 Future Work | WG10 Future Work | | IEC 62361-102 R8 | New | Normal | IEC 61850-6 | CIM-61850 Harmonization - allow Terminals with no connections - use explicit ConnectivityNode.name = None | 02/08/2024 05:08 AM |
| 5928 | IEC TC57 WG10 Future Work | WG10 Future Work | | IEC 62361-102 R9 | New | Normal | IEC 61850-6 | CIM-61850 Harmonization - extend tPhaseEnum to match CIM PhaseCode | 02/08/2024 05:23 AM |
| 5927 | IEC TC57 WG10 Future Work | WG10 Future Work | | IEC 62361-102 R15 | New | Normal | IEC 61850-7-4 | CIM-61850 Harmonization - Add PosFlwIn data object to measurement classes | 02/08/2024 05:22 AM |