

Issues

| # | Project | Tracker | ID | Source | Status | Priority | Standard(s) | Subject | Updated |
|------|------------------------------|---------------------|----|--------|-------------|----------|-------------|--|---------------------|
| 6471 | Client | Issues | | | Resolved | Normal | | Select.response+ (Tissue 1753) | 08/22/2023 08:10 AM |
| 6172 | Client | Issues | | | Resolved | Normal | | client check bits must be tested | 12/13/2022 08:34 AM |
| 6751 | IEC 61850 TPWG | Issues | | | Resolved | Normal | | Update IEC 61850 QAP Addendum for adding requirement quickly | 04/16/2024 08:16 AM |
| 6319 | IEC TC57 WG10 Future Work | WG10 Future Work | | | New | Normal | IEC 61850-6 | maxAttributes - conflicting requirements between GOOSE and reporting | 10/26/2023 04:58 AM |
| 5926 | SCL Tooling | Issues | | | Resolved | Normal | | Review ICT TP | 11/29/2022 07:23 AM |
| 6750 | Server | Issues | | | Resolved | High | | sAddr length - TISSUE 1885 | 04/16/2024 08:17 AM |
| 6749 | Server | Issues | | | Resolved | High | | Clarification of ExtRef attributes usage - TISSUE 1818 | 04/16/2024 08:31 AM |
| 6769 | Server | Issues | | | In Progress | Normal | | sGop9 should allow NdsCom to be set in the GOOSE message | 04/30/2024 08:09 AM |
| 6568 | Server | Issues | | | Rejected | Normal | | The definition of LTMS.TmSrc is different in the actual AMD1 and Consolidated Version - 1846 | 11/14/2023 08:37 AM |
| 6565 | Server | Issues | | | Rejected | Normal | | Added more precise qualifications to TmSrcTyp - 1883 | 11/14/2023 09:03 AM |
| 6472 | Server | Issues | | | Rejected | Normal | | Concept of smpRate for input analogue signal acquisition is misleading (Tissue 1857) | 08/22/2023 08:22 AM |
| 6206 | Server | Issues | | | Rejected | Normal | | Type and size of Length field value (TLV) encoding in SV | 01/11/2023 06:19 AM |