

Issues

| # | Project | Tracker | ID | Source | Status | Priority | Standard(s) | Subject | Updated |
|------|---------------------------------|---------------------|----|--------|-------------|----------|-------------|--|---------------------|
| 6769 | Server | Issues | | | In Progress | Normal | | sGop9 should allow NdsCom to be set in the GOOSE message | 04/30/2024 08:09 AM |
| 6751 | IEC 61850 TPWG | Issues | | | Resolved | Normal | | Update IEC 61850 QAP Addendum for adding requirement quickly | 04/16/2024 08:16 AM |
| 6750 | Server | Issues | | | Resolved | High | | sAddr length - TISSUE 1885 | 04/16/2024 08:17 AM |
| 6749 | Server | Issues | | | Resolved | High | | Clarification of ExtRef attributes usage - TISSUE 1818 | 04/16/2024 08:31 AM |
| 6614 | Server | Issues | | | Closed | Normal | | New DO required for routable GOOSE and SMV service tracking - 1701 | 03/01/2024 10:08 AM |
| 6570 | Server | Issues | | | Closed | Normal | | RSYN Rel mandatory? - 1766 | 11/14/2023 09:04 AM |
| 6569 | Server | Issues | | | Closed | Normal | | Update of NxtStrTm for time-driven schedules - 1836 | 10/31/2023 08:47 AM |
| 6568 | Server | Issues | | | Rejected | Normal | | The definition of LTMS.TmSrc is different in the actual AMD1 and Consolidated Version - 1846 | 11/14/2023 08:37 AM |
| 6567 | Server | Issues | | | Closed | Normal | | Semantic of PMRI.StrInhTmm -1856 | 11/14/2023 09:05 AM |
| 6566 | Server | Issues | | | Closed | Normal | | Description discrepancy LTMS between Source and Channels - 1859 | 11/28/2023 08:18 AM |
| 6565 | Server | Issues | | | Rejected | Normal | | Added more precise qualifications to TmSrcTyp - 1883 | 11/14/2023 09:03 AM |
| 6564 | Server | Issues | | | Closed | Normal | | Functional constraint object non-volatility ambiguous - 1822 | 11/14/2023 09:06 AM |
| 6518 | Server | Issues | | | Closed | Normal | | Functional constraint object non-volatility ambiguous - TISSUE 1822 | 03/01/2024 10:06 AM |
| 6517 | IEC 61850 TPWG | Bug | | | Closed | Normal | | Create TF to start SCT Ed2.1 test procedures. | 10/31/2023 08:32 AM |
| 6473 | Server | Issues | | | Closed | Normal | | Inconsistency in LPHD requirements - Tissue 1752 | 03/01/2024 10:06 AM |
| 6472 | Server | Issues | | | Rejected | Normal | | Concept of smpRate for input analogue signal acquisition is misleading (Tissue 1857) | 08/22/2023 08:22 AM |
| 6471 | Client | Issues | | | Resolved | Normal | | Select.response+ (Tissue 1753) | 08/22/2023 08:10 AM |
| 6470 | Server | Issues | | | Closed | Normal | | SynchSrcID support mandatory for devices that support IEC 61850-9-3 (tissue 1692) | 03/01/2024 10:05 AM |
| 6469 | Server | Issues | | | Closed | Normal | | Type and size of Length field value (TLV) encoding in SV | 03/01/2024 10:05 AM |
| 6319 | IEC TC57 WG10 Future Work | WG10 Future Work | | | New | Normal | IEC 61850-6 | maxAttributes - conflicting requirements between GOOSE and reporting | 10/26/2023 04:58 AM |
| 6206 | Server | Issues | | | Rejected | Normal | | Type and size of Length field value (TLV) encoding in SV | 01/11/2023 06:19 AM |
| 6193 | Server | Issues | | | Closed | Normal | | sRpN5 does not test for the case where URCBs are association based (non-indexed). | 03/01/2024 09:58 AM |
| 6192 | Server | Issues | | | Closed | Normal | | Polarity of neutral in WYE | 03/01/2024 09:58 AM |
| 6172 | Client | Issues | | | Resolved | Normal | | client check bits must be tested | 12/13/2022 08:34 AM |
| 5960 | General Testing Issues | Improvement | | | Closed | Normal | | Herb to review access control of test documents | 02/21/2023 08:05 AM |

| # | Project | Tracker | ID | Source | Status | Priority | Standard(s) | Subject | Updated |
|------|-------------|---------|----|--------|----------|----------|-------------|--|---------------------|
| 5926 | SCL Tooling | Issues | | | Resolved | Normal | | Review ICT TP | 11/29/2022 07:23 AM |
| 5914 | Server | Issues | | | Closed | Normal | | Verify that LPHD.Sim is not affected by LLN0.Beh | 03/01/2024 09:54 AM |