

Issues

#	Project	Tracker	ID	Source	Status	Priority	Standard(s)	Subject	Updated
6471	Client	Issues			Resolved	Normal		Select.response+ (Tissue 1753)	08/22/2023 08:10 AM
6172	Client	Issues			Resolved	Normal		client check bits must be tested	12/13/2022 08:34 AM
5960	General Testing Issues	Improvement			Closed	Normal		Herb to review access control of test documents	02/21/2023 08:05 AM
6751	IEC 61850 TPWG	Issues			Resolved	Normal		Update IEC 61850 QAP Addendum for adding requirement quickly	04/16/2024 08:16 AM
6517	IEC 61850 TPWG	Bug			Closed	Normal		Create TF to start SCT Ed2.1 test procedures.	10/31/2023 08:32 AM
6319	IEC TC57 WG10 Future Work	WG10 Future Work			New	Normal	IEC 61850-6	maxAttributes - conflicting requirements between GOOSE and reporting	10/26/2023 04:58 AM
5926	SCL Tooling	Issues			Resolved	Normal		Review ICT TP	11/29/2022 07:23 AM
6750	Server	Issues			Resolved	High		sAddr length - TISSUE 1885	04/16/2024 08:17 AM
6749	Server	Issues			Resolved	High		Clarification of ExtRef attributes usage - TISSUE 1818	04/16/2024 08:31 AM
6769	Server	Issues			In Progress	Normal		sGop9 should allow NdsCom to be set in the GOOSE message	04/30/2024 08:09 AM
6614	Server	Issues			Closed	Normal		New DO required for routable GOOSE and SMV service tracking - 1701	03/01/2024 10:08 AM
6570	Server	Issues			Closed	Normal		RSYN Rel mandatory? - 1766	11/14/2023 09:04 AM
6569	Server	Issues			Closed	Normal		Update of NxtStrTm for time-driven schedules - 1836	10/31/2023 08:47 AM
6568	Server	Issues			Rejected	Normal		The definition of LTMS.TmSrc is different in the actual AMD1 and Consolidated Version - 1846	11/14/2023 08:37 AM
6567	Server	Issues			Closed	Normal		Semantic of PMRI.StrInhTmm - 1856	11/14/2023 09:05 AM
6566	Server	Issues			Closed	Normal		Description discrepancy LTMS between Source and Channels - 1859	11/28/2023 08:18 AM
6565	Server	Issues			Rejected	Normal		Added more precise qualifications to TmSrcTyp - 1883	11/14/2023 09:03 AM
6564	Server	Issues			Closed	Normal		Functional constraint object non-volatility ambiguous - 1822	11/14/2023 09:06 AM
6518	Server	Issues			Closed	Normal		Functional constraint object non-volatility ambiguous - TISSUE 1822	03/01/2024 10:06 AM
6473	Server	Issues			Closed	Normal		Inconsistency in LPHD requirements - Tissue 1752	03/01/2024 10:06 AM
6472	Server	Issues			Rejected	Normal		Concept of smpRate for input analogue signal acquisition is misleading (Tissue 1857)	08/22/2023 08:22 AM
6470	Server	Issues			Closed	Normal		SynchSrcID support mandatory for devices that support IEC 61850-9-3 (tissue 1692)	03/01/2024 10:05 AM
6469	Server	Issues			Closed	Normal		Type and size of Length field value (TLV) encoding in SV	03/01/2024 10:05 AM
6206	Server	Issues			Rejected	Normal		Type and size of Length field value (TLV) encoding in SV	01/11/2023 06:19 AM
6193	Server	Issues			Closed	Normal		sRpN5 does not test for the case where URCBs are association based (non-indexed).	03/01/2024 09:58 AM

#	Project	Tracker	ID	Source	Status	Priority	Standard(s)	Subject	Updated
6192	Server	Issues			Closed	Normal		Polarity of neutral in WYE	03/01/2024 09:58 AM
5914	Server	Issues			Closed	Normal		Verify that LPHD.Sim is not affected by LLN0.Beh	03/01/2024 09:54 AM