

## Issues

| #    | Project                   | Tracker     | ID | Source | Status | Priority | Standard(s) | Subject   | Updated             |
|------|---------------------------|-------------|----|--------|--------|----------|-------------|---|---------------------|
| 6517 | IEC 61850<br>TPWG         | Bug         |    |        | Closed | Normal   |             | Create TF to start SCT Ed2.1 test procedures.                                     | 10/31/2023 08:32 AM |
| 5960 | General Testing<br>Issues | Improvement |    |        | Closed | Normal   |             | Herb to review access control of test documents                                   | 02/21/2023 08:05 AM |
| 6614 | Server                    | Issues      |    |        | Closed | Normal   |             | New DO required for routable GOOSE and SMV service tracking - 1701                | 03/01/2024 10:08 AM |
| 6570 | Server                    | Issues      |    |        | Closed | Normal   |             | RSYN Rel mandatory? - 1766  | 11/14/2023 09:04 AM |
| 6569 | Server                    | Issues      |    |        | Closed | Normal   |             | Update of NxtStrTm for time-driven schedules - 1836                               | 10/31/2023 08:47 AM |
| 6567 | Server                    | Issues      |    |        | Closed | Normal   |             | Semantic of PMRI.StrInhTmm -1856  | 11/14/2023 09:05 AM |
| 6566 | Server                    | Issues      |    |        | Closed | Normal   |             | Description discrepancy LTMS between Source and Channels - 1859                   | 11/28/2023 08:18 AM |
| 6564 | Server                    | Issues      |    |        | Closed | Normal   |             | Functional constraint object non-volatility ambiguous - 1822                      | 11/14/2023 09:06 AM |
| 6518 | Server                    | Issues      |    |        | Closed | Normal   |             | Functional constraint object non-volatility ambiguous - TISSUE 1822               | 03/01/2024 10:06 AM |
| 6473 | Server                    | Issues      |    |        | Closed | Normal   |             | Inconsistency in LPHD requirements - Tissue 1752                                  | 03/01/2024 10:06 AM |
| 6470 | Server                    | Issues      |    |        | Closed | Normal   |             | SynchSrcID support mandatory for devices that support IEC 61850-9-3 (tissue 1692) | 03/01/2024 10:05 AM |
| 6469 | Server                    | Issues      |    |        | Closed | Normal   |             | Type and size of Length field value (TLV) encoding in SV                          | 03/01/2024 10:05 AM |
| 6193 | Server                    | Issues      |    |        | Closed | Normal   |             | sRpN5 does not test for the case where URCS are association based (non-indexed).  | 03/01/2024 09:58 AM |
| 6192 | Server                    | Issues      |    |        | Closed | Normal   |             | Polarity of neutral in WYE  | 03/01/2024 09:58 AM |
| 5914 | Server                    | Issues      |    |        | Closed | Normal   |             | Verify that LPHD.Sim is not affected by LLN0.Beh                                  | 03/01/2024 09:54 AM |