

Issues

#	Project	Tracker	ID	Source	Status	Priority	Standard(s)	Subject	Updated
6786	WG13 Issues	CIM Issues			Closed	Normal		Add clarification that BaseVoltage.nominalVoltage is line-to-line	06/05/2024 02:22 PM