

## Issues

#	Project	Tracker	ID	Source	Status	Priority	Standard(s)	Subject	Updated
6780	Server	Issues			New	Normal		sGos23 q=test shall be processes as invalid	05/01/2024 08:56 AM
6777	Client	Issues			In Progress	Normal		SCD import and Tool Functionality test procedures	04/30/2024 08:13 AM
6776	Client	Issues			In Progress	Normal		cSBOs4 requires different control value	04/30/2024 08:11 AM
6728	Client	Issues			In Progress	Normal		cSg13 refers to PIXIT entry Sg5/Sg6 but not clarified in the expected result	04/30/2024 08:20 AM
6685	GOOSE Performance	Issues			In Progress	Normal		Device need to be certified for Ed2.1 server first	04/30/2024 08:14 AM
6727	Client	Issues			Resolved	Normal		cDsN1bc, cFtN2 have no non-Ed2 specific error code	04/02/2024 08:42 AM
6710	Server	Issues			Resolved	Normal		sSrv13 does not specify that the lower hierarchy Mod.stVal shall not change	04/02/2024 02:42 PM
6688	Client	Issues			Resolved	Normal		cSrvN10 - Ed1 specific error codes do not exist for MMS GetNameList	04/02/2024 08:42 AM
6655	Client	Issues			Resolved	Normal		cLogN5 is missing in table A4.2 and certificate template	01/09/2024 08:28 AM
6654	Client	Issues			Resolved	Normal		Tracking numbering mismatch Ed2 <> Ed2.1	01/09/2024 08:27 AM
6631	SCL Tooling	Issues			Resolved	Normal		tTf1 (mustUnderstand) for the ICT test needs clarification	01/09/2024 08:59 AM
6617	SCL Tooling	Issues			Resolved	Normal		tlieN1 - can a popup warning be considered as 'not allowed'	12/12/2023 08:58 AM
6490	Client	Issues			Resolved	Normal		UCAiug requires Ed2Amd1 Jan 2024 - expect testlabs/toolvendors need more time	08/22/2023 08:16 AM
6465	GOOSE Performance	Issues			Resolved	Normal		The Ed2 GOOSE performance also apply for Ed2Amd1	08/08/2023 08:42 AM
6464	Client	Issues			Resolved	Normal		cSrv5 change the condition to GetDataValues or Reporting	07/11/2023 08:38 AM
6463	Client	Issues			Resolved	Normal		cSrv7, cSrvN3 some clients only read DA (not DO)	07/25/2023 08:07 AM
6327	SCL Tooling	Issues			Resolved	Normal		tTf2 - export CID file only for Ed2.1?	05/16/2023 08:20 AM
6326	SCL Tooling	Issues			Resolved	Normal		tlie1 - remove step 10-14 to undo previous changes	05/16/2023 08:09 AM
6325	SCL Tooling	Issues			Resolved	Normal		PIXIT missing entries on tlie1 "when supported"	05/16/2023 08:04 AM
6323	SCL Tooling	Issues			Resolved	Normal		tTf5 IED name=None is not allowed tissue #1365	05/02/2023 08:20 AM
6200	SCL Tooling	Issues			Resolved	Normal		tTf1 change Ed2/2007B to Ed2.1/2007B4	01/24/2023 08:33 AM
5327	Client	Issues			Resolved	Normal		PIXIT - add processing/mapping of quality bits	06/28/2022 09:44 AM
5120	SCL Tooling	Issues			Resolved	Normal		LGOS/LSVS reference with functional naming (SCL)	08/09/2022 08:40 AM
3115	Client	Issues			Resolved	Normal		Forward compatibility to Amd1 server with pre-assigned URCB/BRCB	06/14/2022 08:35 AM
748	Server	Issues			Resolved	Normal		sGos9 use SPS when INS subscribe is not supported	07/27/2021 10:07 AM
658	Client	Issues			Resolved	Normal		Verify Client does process a report before RptEna write respond+	06/01/2021 08:23 AM
636	Client	Issues			Resolved	High		Mandate RCB reservation for Ed2.0 client and Amd1 server	04/20/2021 02:23 PM
6520	SCL Tooling	Issues			Rejected	Normal		ICT Ed2.1 refers to TICS but there no part 6 tissues	10/31/2023 08:35 AM

#	Project	Tracker	ID	Source	Status	Priority	Standard(s)	Subject	Updated
6324	SCL Tooling	Issues			Rejected	Normal		sCnf6 - not all extRef require intAddr not referring to external device	05/16/2023 08:44 AM
5906	Server	Issues			Rejected	Normal		sCnf51 at least one LPHD	09/06/2022 08:20 AM
5344	Server	Issues			Rejected	Normal		sBr29 power-up the IED is missing	06/02/2022 04:12 PM
5138	Server	Issues			Rejected	Normal		sBr13 without pre-assignment	12/13/2021 04:43 AM
654	Server	Issues			Rejected	Low		Publish/subscribe minimum length data GOOSE	01/24/2023 09:02 AM
653	Server	Issues			Rejected	Low		Subscriber can use maximum number of dataset elements	01/24/2023 09:03 AM
651	Server	Issues			Rejected	Low		Verify subscriber can accept maximum size GOOSE	01/24/2023 08:40 AM