

Issues

#	Project	Tracker	ID	Source	Status	Priority	Standard(s)	Subject	Updated
639	Server	Issues			Closed	Normal		Boolean ASN.1 encoding 0x02 for MMS client/server	09/14/2021 06:50 AM
6727	Client	Issues			Resolved	Normal		cDsN1bc, cFtN2 have no non-Ed2 specific error code	04/02/2024 08:42 AM
5155	Server	Issues			Closed	Normal		Certificate update for ITCA; add ucauiug address and S/N or hardware version	06/02/2022 02:54 PM
6655	Client	Issues			Resolved	Normal		cLogN5 is missing in table A4.2 and certificate template	01/09/2024 08:28 AM
6595	Server	Issues			Closed	High		Configuration and datamodel test cases not applicable for test equipment	03/01/2024 10:07 AM
6776	Client	Issues			In Progress	Normal		cSBOs4 requires different control value	04/30/2024 08:11 AM
6728	Client	Issues			In Progress	Normal		cSg13 refers to PIXIT entry Sg5/Sg6 but not clarified in the expected result	04/30/2024 08:20 AM
6464	Client	Issues			Resolved	Normal		cSrv5 change the condition to GetDataValues or Reporting	07/11/2023 08:38 AM
6463	Client	Issues			Resolved	Normal		cSrv7, cSvrN3 some clients only read DA (not DO)	07/25/2023 08:07 AM
6688	Client	Issues			Resolved	Normal		cSrvN10 - Ed1 specific error codes do not exist for MMS GetNameList	04/02/2024 08:42 AM
6685	GOOSE Performance	Issues			In Progress	Normal		Device need to be certified for Ed2.1 server first	04/30/2024 08:14 AM
6525	SCL Tooling	Issues			Closed	Normal		Ed2.1 tTf4 and tTf5 expected result mismatch	11/14/2023 08:35 AM
3115	Client	Issues			Resolved	Normal		Forward compatibility to Amd1 server with pre-assigned URcb/BRCB	06/14/2022 08:35 AM
6527	SCL Tooling	Issues			Closed	Normal		ICT Ed2.1 Certificate template mismatches	11/14/2023 08:36 AM
6520	SCL Tooling	Issues			Rejected	Normal		ICT Ed2.1 refers to TICS but there no part 6 tissues	10/31/2023 08:35 AM
5120	SCL Tooling	Issues			Resolved	Normal		LGOS/LSVS reference with functional naming (SCL)	08/09/2022 08:40 AM
5119	Server	Issues			Closed	Normal		LGOS/LSVS subscribe with functional naming	06/02/2022 02:50 PM
636	Client	Issues			Resolved	High		Mandate RCB reservation for Ed2.0 client and Amd1 server	04/20/2021 02:23 PM
6201	Server	Issues			Closed	Normal		Merge sCnf and sMdl changes from ICT to Server	03/01/2024 09:59 AM
6519	Server	Issues			Closed	Normal		Need to be able to test 61850-7-420 (Ed2.1)	03/01/2024 10:07 AM
5327	Client	Issues			Resolved	Normal		PIXIT - add processing/mapping of quality bits	06/28/2022 09:44 AM
6325	SCL Tooling	Issues			Resolved	Normal		PIXIT missing entries on tie1 "when supported"	05/16/2023 08:04 AM
657	Server	Issues			Closed	Low		Publish/subscribe enum with negative value	03/01/2024 09:49 AM
656	Server	Issues			Closed	Low		Publish/subscribe enum with value > 127	03/01/2024 09:48 AM
655	Server	Issues			Closed	Normal		Publish/subscribe maximum length data	07/26/2022 08:32 AM
654	Server	Issues			Rejected	Low		Publish/subscribe minimum length data GOOSE	01/24/2023 09:02 AM
652	Server	Issues			Closed	Normal		Publisher can use maximum number of dataset elements	03/01/2024 09:48 AM
6526	SCL Tooling	Issues			Closed	Normal		Revision 0.7 (final draft) should be 1.0	11/14/2023 08:35 AM
5092	Server	Issues			Closed	Normal		sAss4 add note that the "i" entries in the table 127 shall be ignored	06/02/2022 02:48 PM

#	Project	Tracker	ID	Source	Status	Priority	Standard(s)	Subject	Updated
5142	Server	Issues			Closed	Normal		sAss4 verify callingSerive only conclude	06/02/2022 02:53 PM
5138	Server	Issues			Rejected	Normal		sBr13 without pre-assignment	12/13/2021 04:43 AM
5344	Server	Issues			Rejected	Normal		sBr29 power-up the IED is missing	06/02/2022 04:12 PM
6777	Client	Issues			In Progress	Normal		SCD import and Tool Functionality test procedures	04/30/2024 08:13 AM
6157	Server	Issues			Closed	Normal		sCnf/sMdl not applicable for test equipment	03/01/2024 09:57 AM
634	Server	Issues			Closed	Normal		sCnf11 allow "none" as well	06/14/2022 08:28 AM
3103	Server	Issues			Closed	Normal		sCnf121 serNum and hwRev values	06/14/2022 08:34 AM
5292	Server	Issues			Closed	Normal		sCnf125 smvOpts sampleSynchronized=true or absent, dataSet=false or absent	06/02/2022 02:57 PM
5906	Server	Issues			Rejected	Normal		sCnf51 at least one LPHD	09/06/2022 08:20 AM
6324	SCL Tooling	Issues			Rejected	Normal		sCnf6 - not all extRef require intAddr not referring to external device	05/16/2023 08:44 AM
5961	Server	Issues			Closed	Normal		sCtl16 shall specify LocSta/MitLev to match with table B.1	03/01/2024 09:57 AM
5907	Server	Issues			Closed	Normal		sCtl26 - Cancel a direct control object	03/01/2024 09:53 AM
638	Server	Issues			Closed	Normal		sCtl28 typo tOpOK and opOK (should be tOpOk and opOk)	09/14/2021 06:50 AM
659	Server	Issues			Closed	Normal		sCtl7 allow that bypassing interlocking is "not-supported"	06/08/2021 10:01 AM
6227	Server	Issues			Closed	Normal		sDoc5 GSESettings/SMVsettings apply for SendGOOSE/SMVmessage not SetGoCBValues/SetMsvCBValues	03/01/2024 10:01 AM
5131	Server	Issues			Closed	Normal		sFt1 file format according to part 8-1 K3.3	06/02/2022 02:53 PM
637	Server	Issues			Closed	Normal		sFt4 missing expected result for step 3 and 4	06/14/2022 08:29 AM
5362	Server	Issues			Closed	Normal		sGop2 and sGop4 check minimum MinTime and minimum MaxTime	03/01/2024 09:52 AM
5875	Server	Issues			Closed	Normal		sGopN2 mandatory?	08/09/2022 08:13 AM
6291	Server	Issues			Closed	Normal		sGos13 - Remove/deprecate PIXIT Gs12	03/01/2024 10:04 AM
1793	Server	Issues			Closed	Normal		sGos22 - comment does not match expected result	06/14/2022 08:30 AM
6780	Server	Issues			New	Normal		sGos23 q=test shall be processes as invalid	05/01/2024 08:56 AM
5288	Server	Issues			Closed	Normal		sGos4 LGOS.RxConfRevNum is not verified	06/02/2022 02:56 PM
748	Server	Issues			Resolved	Normal		sGos9 use SPS when INS subscribe is not supported	07/27/2021 10:07 AM
5343	Server	Issues			Closed	Normal		sGosN2 remove PIXIT Gs5	03/01/2024 09:51 AM
6541	Server	Issues			Closed	Normal		sMdl15 allow SCL floating point value can have minor difference in DUT	03/01/2024 10:07 AM
5112	Server	Issues			Closed	Normal		sRpN5 step 8 missing reservation	06/02/2022 02:49 PM
6710	Server	Issues			Resolved	Normal		sSrv13 does not specify that the lower hierarchy Mod.stVal shall not change	04/02/2024 02:42 PM
5912	Server	Issues			Closed	Normal		sSrv6 checking the read-only part is always applicable	03/01/2024 09:54 AM
5913	Server	Issues			Closed	Normal		sSrvN1e and sSrvN3 change condition SCL FC=CF/DC/SP with valKind=Set	03/01/2024 09:54 AM

#	Project	Tracker	ID	Source	Status	Priority	Standard(s)	Subject	Updated
3079	Server	Issues			Closed	Normal		sSvp13 Quality bit invalid - change to Conditional	06/14/2022 08:31 AM
5948	Server	Issues			Closed	Normal		sSvp22 detail is missing in TP1.2 (editorial)	03/01/2024 09:55 AM
5959	Server	Issues			Closed	Normal		sSvp3 remove random and allow synSourceID=TRUE for backwards compatible config	03/01/2024 09:56 AM
5130	Server	Issues			Closed	Normal		sSvs4 header and harmonize with sGos6b	06/02/2022 02:52 PM
6213	Server	Issues			Closed	Normal		sSvsN1 - confRev-1 not possible for backwards config	03/01/2024 10:00 AM
5958	Server	Issues			Closed	Normal		sTm2 allow a more accurate Time Accuracy as documented	03/01/2024 09:56 AM
635	Server	Issues			Closed	Normal		sTm7 mandatory?	06/14/2022 08:29 AM
3090	Server	Issues			Closed	Normal		sTm7: improve leap second processing	06/14/2022 08:32 AM
5915	Server	Issues			Closed	Normal		sTmP1 verify both step 1 and step 2 PTP are supported	08/09/2022 07:53 AM
653	Server	Issues			Rejected	Low		Subscriber can use maximum number of dataset elements	01/24/2023 09:03 AM
5319	Server	Issues			Closed	Normal		T1782 sCtl7 addcause "inconsistent-parameters" when check=00 not-supported	11/01/2022 08:28 AM
6465	GOOSE Performance	Issues			Resolved	Normal		The Ed2 GOOSE performance also apply for Ed2Amd1	08/08/2023 08:42 AM
644	Server	Issues			Closed	Normal		The test procedures does not specify which test cases are applicable for variants	06/14/2022 08:29 AM
6326	SCL Tooling	Issues			Resolved	Normal		tIie1 - remove step 10-14 to undo previous changes	05/16/2023 08:09 AM
6617	SCL Tooling	Issues			Resolved	Normal		tIieN1 - can a popup warning be considered as 'not allowed'	12/12/2023 08:58 AM
6654	Client	Issues			Resolved	Normal		Tracking numbering mismatch Ed2 <> Ed2.1	01/09/2024 08:27 AM
6631	SCL Tooling	Issues			Resolved	Normal		tTf1 (mustUnderstand) for the ICT test needs clarification	01/09/2024 08:59 AM
6200	SCL Tooling	Issues			Resolved	Normal		tTf1 change Ed2/2007B to Ed2.1/2007B4	01/24/2023 08:33 AM
6327	SCL Tooling	Issues			Resolved	Normal		tTf2 - export CID file only for Ed2.1?	05/16/2023 08:20 AM
6323	SCL Tooling	Issues			Resolved	Normal		tTf5 IED name=None is not allowed tissue #1365	05/02/2023 08:20 AM
6490	Client	Issues			Resolved	Normal		UCAiug requires Ed2Amd1 Jan 2024 - expect testlabs/toolvendors need more time	08/22/2023 08:16 AM
6598	Server	Issues			Closed	Normal		Using the same dataset in URcb, BRcb and GoCB	03/01/2024 10:08 AM
658	Client	Issues			Resolved	Normal		Verify Client does process a report before RptEna write respond+	06/01/2021 08:23 AM
6169	Server	Issues			Closed	Normal		verify IED can subscribe to GOOSE/SV from ServerAt accesspoint	03/01/2024 09:57 AM
651	Server	Issues			Rejected	Low		Verify subscriber can accept maximum size GOOSE	01/24/2023 08:40 AM