

## Issues

| #    | Project           | Tracker | ID | Source | Status      | Priority | Standard(s) | Subject   | Updated             |
|------|-------------------|---------|----|--------|-------------|----------|-------------|---|---------------------|
| 636  | Client            | Issues  |    |        | Resolved    | High     |             | Mandate RCB reservation for Ed2.0 client and Amd1 server                      | 04/20/2021 02:23 PM |
| 6728 | Client            | Issues  |    |        | In Progress | Normal   |             | cSg13 refers to PIXIT entry Sg5/Sg6 but not clarified in the expected result  | 05/06/2024 09:34 AM |
| 6776 | Client            | Issues  |    |        | In Progress | Normal   |             | cSBOs4 requires different control value                                       | 05/06/2024 08:44 AM |
| 6780 | Server            | Issues  |    |        | New         | Normal   |             | sGos23 q=test shall be processes as invalid                                   | 05/06/2024 08:37 AM |
| 6685 | GOOSE Performance | Issues  |    |        | In Progress | Normal   |             | Device need to be certified for Ed2.1 server first                            | 04/30/2024 08:14 AM |
| 6777 | Client            | Issues  |    |        | In Progress | Normal   |             | SCD import and Tool Functionality test procedures                             | 04/30/2024 08:13 AM |
| 6710 | Server            | Issues  |    |        | Resolved    | Normal   |             | sSrv13 does not specify that the lower hierarchy Mod.stVal shall not change   | 04/02/2024 02:42 PM |
| 6688 | Client            | Issues  |    |        | Resolved    | Normal   |             | cSrvN10 - Ed1 specific error codes do not exist for MMS GetNameList           | 04/02/2024 08:42 AM |
| 6727 | Client            | Issues  |    |        | Resolved    | Normal   |             | cDsN1bc, cFtN2 have no non-Ed2 specific error code                            | 04/02/2024 08:42 AM |
| 6631 | SCL Tooling       | Issues  |    |        | Resolved    | Normal   |             | tTf1 (mustUnderstand) for the ICT test needs clarification                    | 01/09/2024 08:59 AM |
| 6655 | Client            | Issues  |    |        | Resolved    | Normal   |             | cLogN5 is missing in table A4.2 and certificate template                      | 01/09/2024 08:28 AM |
| 6654 | Client            | Issues  |    |        | Resolved    | Normal   |             | Tracking numbering mismatch Ed2 <> Ed2.1                                      | 01/09/2024 08:27 AM |
| 6617 | SCL Tooling       | Issues  |    |        | Resolved    | Normal   |             | tlieN1 - can a popup warning be considered as 'not allowed'                   | 12/12/2023 08:58 AM |
| 6520 | SCL Tooling       | Issues  |    |        | Rejected    | Normal   |             | ICT Ed2.1 refers to TICS but there no part 6 tissues                          | 10/31/2023 08:35 AM |
| 6490 | Client            | Issues  |    |        | Resolved    | Normal   |             | UCAiug requires Ed2Amd1 Jan 2024 - expect testlabs/toolvendors need more time | 08/22/2023 08:16 AM |
| 6465 | GOOSE Performance | Issues  |    |        | Resolved    | Normal   |             | The Ed2 GOOSE performance also apply for Ed2Amd1                              | 08/08/2023 08:42 AM |
| 6463 | Client            | Issues  |    |        | Resolved    | Normal   |             | cSrv7, cSvrN3 some clients only read DA (not DO)                              | 07/25/2023 08:07 AM |
| 6464 | Client            | Issues  |    |        | Resolved    | Normal   |             | cSrv5 change the condition to GetDataValues or Reporting                      | 07/11/2023 08:38 AM |
| 6324 | SCL Tooling       | Issues  |    |        | Rejected    | Normal   |             | sCnf6 - not all extRef require intAddr not referring to external device       | 05/16/2023 08:44 AM |
| 6327 | SCL Tooling       | Issues  |    |        | Resolved    | Normal   |             | tTf2 - export CID file only for Ed2.1?  | 05/16/2023 08:20 AM |
| 6326 | SCL Tooling       | Issues  |    |        | Resolved    | Normal   |             | tlie1 - remove step 10-14 to undo previous changes                            | 05/16/2023 08:09 AM |
| 6325 | SCL Tooling       | Issues  |    |        | Resolved    | Normal   |             | PIXIT missing entries on tlie1 "when supported"                               | 05/16/2023 08:04 AM |
| 6323 | SCL Tooling       | Issues  |    |        | Resolved    | Normal   |             | tTf5 IED name=None is not allowed tissue #1365                                | 05/02/2023 08:20 AM |
| 6200 | SCL Tooling       | Issues  |    |        | Resolved    | Normal   |             | tTf1 change Ed2/2007B to Ed2.1/2007B4   | 01/24/2023 08:33 AM |
| 5906 | Server            | Issues  |    |        | Rejected    | Normal   |             | sCnf51 at least one LPHD  | 09/06/2022 08:20 AM |
| 5120 | SCL Tooling       | Issues  |    |        | Resolved    | Normal   |             | LGOS/LSVS reference with functional naming (SCL)                              | 08/09/2022 08:40 AM |
| 5327 | Client            | Issues  |    |        | Resolved    | Normal   |             | PIXIT - add processing/mapping of quality bits                                | 06/28/2022 09:44 AM |
| 3115 | Client            | Issues  |    |        | Resolved    | Normal   |             | Forward compatibility to Amd1 server with pre-assigned URCB/BRCB              | 06/14/2022 08:35 AM |

| #    | Project | Tracker | ID | Source | Status   | Priority | Standard(s) | Subject  | Updated             |
|------|---------|---------|----|--------|----------|----------|-------------|--|---------------------|
| 5344 | Server  | Issues  |    |        | Rejected | Normal   |             | sBr29 power-up the IED is missing                                | 06/02/2022 04:12 PM |
| 5138 | Server  | Issues  |    |        | Rejected | Normal   |             | sBr13 without pre-assignment                                     | 12/13/2021 04:43 AM |
| 748  | Server  | Issues  |    |        | Resolved | Normal   |             | sGos9 use SPS when INS subscribe is not supported                | 07/27/2021 10:07 AM |
| 658  | Client  | Issues  |    |        | Resolved | Normal   |             | Verify Client does process a report before RptEna write respond+ | 06/01/2021 08:23 AM |
| 653  | Server  | Issues  |    |        | Rejected | Low      |             | Subscriber can use maximum number of dataset elements            | 01/24/2023 09:03 AM |
| 654  | Server  | Issues  |    |        | Rejected | Low      |             | Publish/subscribe minimum length data GOOSE                      | 01/24/2023 09:02 AM |
| 651  | Server  | Issues  |    |        | Rejected | Low      |             | Verify subscriber can accept maximum size GOOSE                  | 01/24/2023 08:40 AM |