

Issues

#	Project	Tracker	ID	Source	Status	Priority	Standard(s)	Subject	Updated
7091	Server	Issues			Rejected	Normal		sSrv17 - New value should be different from the previous one and not from the SCL value. Test case will not work twice with SPG setpoints.	01/21/2025 08:06 AM
6904	Server	Issues			Resolved	Normal		sCtl14 in TP1.3 does not reflect the Issue #6214 resolution	10/29/2024 08:53 AM
6903	Server	Issues			Resolved	Normal		sGos20 requires the ICT to accept invalid SCD files due to FC out of tFCEnum	10/29/2024 08:52 AM
6823	Server	Issues			Resolved	Normal		sAss4 - Step 2 indicates two different situations with localDetailCalling	08/06/2024 08:15 AM