

## Issues

#	Project	Tracker	ID	Source	Status	Priority	Standard(s)	Subject	Updated
6203	Server	Issues			Closed	Normal		sSvs6 - Test configuration does not consider available bandwidth	03/01/2024 09:59 AM
6188	Server	Issues			Closed	Normal		sSBOs8 does not consider PIXIT Ct13	03/01/2024 09:58 AM
5371	Server	Issues			Closed	Normal		Scope of the test is limited to a given NSD release.	03/01/2024 09:52 AM
6151	IEC TC57 WG10 Future Work	WG10 Future Work		Tissue DB	New	Normal	IEC 61850-7-3	Use and configuration of ORG within the scope of InRef 7 BlkRef	10/26/2023 05:20 AM
645	Server	Issues			Closed	Normal		A4.11 a - Test procedures indicates that all sample rates & number of ASDUs variant shall be tested	09/14/2021 06:48 AM
666	Server	Issues			Closed	Normal		Missing GOOSE and SV subscriber test procedures: verify that the subscription of test signals follows IEC 61850-7-4 - Annex A.	09/14/2021 06:47 AM