

Issues

#	Project	Tracker	ID	Source	Status	Priority	Standard(s)	Subject	Updated
6622	IEC 61850 TPWG	Bug			Rejected	Normal		Test case Ttf1 (mustUnderstand) for the ICT conformance test needs clarification	12/12/2023 08:19 AM
640	Server	Issues			Closed	Normal		sMdl6 indicates that indexed = FALSE and RptEnabled max > 1 is prohibited, but for association specific URCBs max can be >1	09/14/2021 06:49 AM
650	Server	Issues			Closed	Normal		In Ed 2 test sCtl5 step 2, expected result when LN.Beh=on and control command sent to Mod where test flag set says commands are accepted and executed	06/08/2021 03:56 PM