

Issues

#	Project	Tracker	ID	Source	Status	Priority	Standard(s)	Subject	Updated
6768	61850-7-5 and 61850-7-500	IEC61850-7-5			New	Normal		Control of substituted or blocked objects	04/19/2024 05:08 AM
6739	IEC 61850 User Feedback Task Force	Feature			In Progress	Normal		How to deal with 'Beh' and 'Health' of isolated functions	04/09/2024 08:43 AM
6738	IEC 61850 User Feedback Task Force	Improvement			Resolved	Normal		Amending TGSN LN class with settings for adapting the signal	04/09/2024 08:19 AM
6737	IEC 61850 User Feedback Task Force	Improvement			Resolved	Normal	IEC 61850-90-29	Amending TGSN LN class with signal characteristics	04/09/2024 08:10 AM
6498	61850-7-5 and 61850-7-500	IEC61850-7-5			Waiting for Release	Normal		Explanation text on the usage of SwModKey	02/29/2024 07:52 AM
6545	61850-7-5 and 61850-7-500	IEC61850-7-5		TC92 WG2	Waiting for Release	Normal		Propagation of detailQual	02/29/2024 07:17 AM
6714	IEC TC57 WG10 Future Work	WG10 Future Work		IEC PAS 61850-90-3	New	Normal		Improve the models used for power regulation	02/20/2024 11:04 AM
5103	IEC TC57 WG10 Future Work	WG10 Future Work		IEEE H27	New	Normal	IEC 61850-7-3	Modified/new CDC for IEEE H27	02/09/2024 03:21 AM
5310	IEC TC57 WG10 Future Work	WG10 Future Work		WG 18	New	Normal	IEC 61850-7-3	New CDC for IEC/TC 57/WG 18	02/08/2024 05:19 AM
5104	IEC TC57 WG10 Future Work	WG10 Future Work		WG 17	New	Normal	IEC 61850-6	Add a type code 'INV'	02/08/2024 05:14 AM
6489	GOOSE Performance	Issues			Resolved	Normal		Reducing the needed resources for time correlated subscribed GOOSE not used for ping-pong	01/23/2024 08:05 AM
6684	61850-7-5 and 61850-7-500	IEC61850-7-5		discussion	New	Normal		Proposal to deprecate 'LocSta' in X and Y group LN classes	01/22/2024 02:50 AM
6537	61850-7-5 and 61850-7-500	IEC61850-7-5			New	Normal		Harmonizing expressions in 7-500 Ed.1	10/06/2023 08:13 AM
6499	61850-7-5 and 61850-7-500	IEC61850-7-5			In Progress	Normal		Explanation text on the application of check conditions	10/05/2023 08:57 AM
6500	61850-7-5 and 61850-7-500	IEC61850-7-5			In Progress	Normal		Parameters to enforce the checking of interlocking and synchronism	10/05/2023 08:57 AM
6488	GOOSE Performance	Issues			Resolved	Low		Incorrect reference	09/05/2023 08:08 AM
6497	61850-7-5 and 61850-7-500	IEC61850-7-5			New	Normal		Explanation text of IEC/TR 61850-7-500 clause 10.1.1.2	08/02/2023 10:43 AM
6256	IEC 61850 User Feedback Task Force	Bug			Resolved	Normal	IEC 61850-7-4	IEC 61850-7-4 list of abbreviations	06/06/2023 08:32 AM
5876	IEC 61850 User Feedback Task Force	Improvement		FNN Germany	Resolved	Normal	IEC 61850-7-4 Ed.3	Proposal of a new LN class ASWI	06/05/2023 01:58 AM
6174	Server	Issues			Rejected	Normal		Amend sCtl7 to test both interlocking check and check synchronizing ?	02/07/2023 08:24 AM