

## Issues

#	Project	Tracker	ID	Source	Status	Priority	Standard(s)	Subject	Updated
3089	Test Procedure Issues	Issues			Closed	Normal		Ed2.1 server certificate template standards reference	09/10/2021 12:16 PM
5356	Server	Issues			Closed	Normal		PIXIT entries mandated by 61850-8-1 but missing in PIXIT	03/01/2024 09:52 AM
5337	Server	Issues			Closed	Normal		Independence of GOOSE subscriber timeouts is not tested	03/01/2024 09:51 AM
5328	Server	Issues			Closed	Normal		sFt2ab issues with "directory" files	03/01/2024 09:51 AM
5326	Server	Issues			Closed	Normal		sSBOes8 incorrectly requires addCause=blocked-by-mode	03/01/2024 09:49 AM
5289	Server	Issues			Closed	Normal		Ed2.1 Server TP 1.1 Does not include 2.0 server PIXIT Gs12	07/27/2022 10:39 AM
5286	Server	Issues			Closed	Normal		Not every Sample rate/nofASDU combination is tested for SV publishers/subscribers	06/14/2022 08:33 AM
669	Server	Issues			Closed	Normal		T1681 - LActTm representation is not actual (sSg13, sSg14)	06/02/2022 04:14 PM
5308	Server	Issues			Closed	Normal		SV Publisher/subscriber maximum dataset size is untested	06/02/2022 03:08 PM
5284	Server	Issues			Closed	Normal		Local (not MMS) server update of active setting group not checked	06/02/2022 02:55 PM
5127	Server	Issues			Closed	Normal		Server ignores Cancel parameter to SBO	06/02/2022 02:52 PM
3087	Server	Issues			Closed	Normal		sGop9 allows DUT to reject a configuration with a GSEControl missing the datSet attribute	06/02/2022 02:48 PM
3081	Server	Issues			Closed	Normal		sGos6b does not verify non-Sim GOOSE are processed by the subscriber after a Sim GOOSE arrives	06/02/2022 02:47 PM
670	Server	Issues			Closed	Normal		T1702 - Limit LTRK to one instance on a server	06/02/2022 02:46 PM
665	Server	Issues			Closed	Normal		T1679 GoEna behavior at startup	06/02/2022 02:38 PM
5154	SCL Tooling	Issues			Closed	Normal		Add 61869-9 sample rates to UCA conformance certificates?	06/02/2022 03:12 PM