

## Issues

| #    | Project                            | Tracker     | ID | Source | Status      | Priority | Standard(s)         | Subject   | Updated             |
|------|------------------------------------|-------------|----|--------|-------------|----------|---------------------|---|---------------------|
| 6304 | IEC 61850 User Feedback Task Force | Support     |    | RTE    | Closed      | Normal   |                     | part 6 - clarification on product naming / functional naming                      | 11/23/2023 05:30 AM |
| 672  | IEC 61850 User Feedback Task Force | Improvement | 46 | RTE    | Resolved    | Normal   | TR IEC 61850-7-500  | Create DO indicating the source of synchronisation                                | 11/21/2023 08:49 AM |
| 673  | IEC 61850 User Feedback Task Force | Improvement | 47 | RTE    | Resolved    | Normal   | TR IEC 61850-7-500  | CPU monitoring  | 11/21/2023 08:40 AM |
| 675  | IEC 61850 User Feedback Task Force | Support     | 48 | RTE    | Resolved    | Normal   | IEC 61850-7-4 Ed2.1 | Clarification of blocked mode   | 11/21/2023 08:38 AM |
| 6605 | IEC 61850 User Feedback Task Force | Support     |    | RTE    | Resolved    | Normal   | TR IEC 61850-7-500  | Identification of three phase trip with ACT DO                                    | 11/21/2023 08:13 AM |
| 6303 | IEC 61850 User Feedback Task Force | Support     |    | RTE    | Resolved    | Normal   | IEC 61850-7-500     | LN PDIF – setting for nominal current   | 06/05/2023 01:58 AM |
| 5372 | IEC 61850 User Feedback Task Force | Improvement |    | RTE    | Resolved    | Normal   | IEC 61850-7-1       | Simultaneous change of InRef.setSrcRef and InRef.setSrcCB for dynamic commutation | 06/05/2023 01:58 AM |
| 676  | IEC 61850 User Feedback Task Force | Support     | 49 | RTE    | Resolved    | Normal   | IEC 61850-7-5       | Clarification of addCause   | 06/05/2023 01:58 AM |
| 677  | IEC 61850 User Feedback Task Force | Feature     | 50 | RTE    | In Progress | Normal   | IEC 61850-7-4       | Impact of IEC 61869-13 (SAMU)   | 02/28/2023 09:42 AM |
| 671  | IEC 61850 User Feedback Task Force | Bug         | 45 | RTE    | Closed      | Normal   | IEC 61850-90-4      | Complete XSD file adding CDC CGS  | 09/29/2021 03:15 AM |