

Issues

| # | Project | Tracker | ID | Source | Status | Priority | Standard(s) | Subject | Updated |
|------|------------------------------------|-------------|----|--------|-------------|----------|---------------------|---|---------------------|
| 6304 | IEC 61850 User Feedback Task Force | Support | | RTE | Closed | Normal | | part 6 - clarification on product naming / functional naming | 11/23/2023 05:30 AM |
| 671 | IEC 61850 User Feedback Task Force | Bug | 45 | RTE | Closed | Normal | IEC 61850-90-4 | Complete XSD file adding CDC CGS | 09/29/2021 03:15 AM |
| 672 | IEC 61850 User Feedback Task Force | Improvement | 46 | RTE | Resolved | Normal | TR IEC 61850-7-500 | Create DO indicating the source of synchronisation | 11/21/2023 08:49 AM |
| 673 | IEC 61850 User Feedback Task Force | Improvement | 47 | RTE | Resolved | Normal | TR IEC 61850-7-500 | CPU monitoring | 11/21/2023 08:40 AM |
| 675 | IEC 61850 User Feedback Task Force | Support | 48 | RTE | Resolved | Normal | IEC 61850-7-4 Ed2.1 | Clarification of blocked mode | 11/21/2023 08:38 AM |
| 6605 | IEC 61850 User Feedback Task Force | Support | | RTE | Resolved | Normal | TR IEC 61850-7-500 | Identification of three phase trip with ACT DO | 11/21/2023 08:13 AM |
| 6303 | IEC 61850 User Feedback Task Force | Support | | RTE | Resolved | Normal | IEC 61850-7-500 | LN PDIF – setting for nominal current | 06/05/2023 01:58 AM |
| 5372 | IEC 61850 User Feedback Task Force | Improvement | | RTE | Resolved | Normal | IEC 61850-7-1 | Simultaneous change of InRef.setSrcRef and InRef.setSrcCB for dynamic commutation | 06/05/2023 01:58 AM |
| 676 | IEC 61850 User Feedback Task Force | Support | 49 | RTE | Resolved | Normal | IEC 61850-7-5 | Clarification of addCause | 06/05/2023 01:58 AM |
| 677 | IEC 61850 User Feedback Task Force | Feature | 50 | RTE | In Progress | Normal | IEC 61850-7-4 | Impact of IEC 61869-13 (SAMU) | 02/28/2023 09:42 AM |