

Issues

#	Project	Tracker	ID	Source	Status	Priority	Standard(s)	Subject	Updated
5885	CIM Issues	CIM Issues			New	Normal	IEC 61970-301	Consider CIM measurement classes that can hold multiple measured values with the same timestamp and quality.	07/13/2022 10:50 AM
5884	CIM Issues	CIM Issues			New	Normal		Modify control model - create DiscreteCommand for enumerations such as raise/lower	07/13/2022 10:45 AM
5883	CIM Issues	CIM Issues			New	Normal	IEC 61970-301	Define a standard way to define IEC 61850 data object names for MeasurementTypes and ControlTypes	07/13/2022 10:31 AM
5882	CIM Issues	CIM Issues			New	Normal	IEC 61970-301	Model fans, motors, battery systems and similar auxiliary equipment with terminals	07/13/2022 10:24 AM
6167	IEC 61850 User Feedback Task Force	Support		email	Resolved	Normal	IEC 61850-90-6	IEC 61850-90-6 Voltage presence CDC for SVPI.Prs	06/05/2023 01:58 AM
6703	IEC TC57 WG10 Future Work	WG10 Future Work		Ed 3 review	New	Normal	IEC 61850-7-4, IEC TS 61850-80-4	Part 80-4 Mapping to COSEM : add reactive and apparent energy data objects to MMTR and MMTN	02/09/2024 02:43 PM
6736	WG13 Issues	CIM Issues			New	Normal	IEC 61970-301	Quality61850 Class does not match the definition of Quality in IEC 61850-7-2	03/12/2024 04:05 PM
5976	WG13 Issues	CIM Issues			New	Normal		CIM-61850 Harmonization - revise control model for DiscreteCommand (e.g. raise/lower)	09/21/2022 04:13 AM
5975	WG13 Issues	CIM Issues			New	Normal		CIM-61850 Harmonization - define a standard list of control types	09/21/2022 03:59 AM
5974	WG13 Issues	CIM Issues			New	Normal		CIM-61850 Harmonization - allow direct association IED to MeasurementValue	09/21/2022 04:07 AM
5972	WG13 Issues	CIM Issues			New	Normal		CIM-61850 Harmonization - define a method of using IEC 61850 data object names as measurement types	09/21/2022 03:27 AM
5973	WG13 Issues	CIM Issues			New	Low		CIM-61850 Harmonization - consider Measurement classes with multiple values (vector, Wye ...)	09/21/2022 03:36 AM
5971	WG13 Issues	CIM Issues			New	Low		CIM-61850 Harmonization - Consider modelling fans, pump motors and battery systems as types of auxiliary equipment	09/21/2022 04:01 AM
5312	WG14 Issues	CIM Issues			Review	Normal	IEC 61968	Change associations for meter UsagePoint to make it more like Measurements	12/28/2023 11:57 AM
5321	IEC 61850 User Feedback Task Force	Improvement	1	WG17	Resolved	Normal	IEC 61850-7-4,7-5	Schedules - allow 3 values per time point	06/05/2023 01:58 AM
5322	IEC 61850 User Feedback Task Force	Improvement	2	WG17	Resolved	Normal	IEC 61850-7-4,7-5	Schedules - add optional data objects to support irregular interval schedules	06/05/2023 01:58 AM
5323	IEC 61850 User Feedback Task Force	Improvement	3	WG17	Resolved	Normal	IEC 61850-7-4,7-5	Schedules - allow updates to single values while schedules are running	06/05/2023 01:58 AM