

Issues

| # | Project | Tracker | ID | Source | Status | Priority | Standard(s) | Subject | Updated |
|------|------------------------------------|------------------|----|-------------|----------|----------|----------------------------------|--|---------------------|
| 6736 | WG13 Issues | CIM Issues | | | New | Normal | IEC 61970-301 | Quality61850 Class does not match the definition of Quality in IEC 61850-7-2 | 03/12/2024 04:05 PM |
| 6703 | IEC TC57 WG10 Future Work | WG10 Future Work | | Ed 3 review | New | Normal | IEC 61850-7-4, IEC TS 61850-80-4 | Part 80-4 Mapping to COSEM : add reactive and apparent energy data objects to MMTR and MMTN | 02/09/2024 02:43 PM |
| 6167 | IEC 61850 User Feedback Task Force | Support | | email | Resolved | Normal | IEC 61850-90-6 | IEC 61850-90-6 Voltage presence CDC for SVPI.Prs | 06/05/2023 01:58 AM |
| 5976 | WG13 Issues | CIM Issues | | | New | Normal | | CIM-61850 Harmonization - revise control model for DiscreteCommand (e.g. raise/lower) | 09/21/2022 04:13 AM |
| 5975 | WG13 Issues | CIM Issues | | | New | Normal | | CIM-61850 Harmonization - define a standard list of control types | 09/21/2022 03:59 AM |
| 5974 | WG13 Issues | CIM Issues | | | New | Normal | | CIM-61850 Harmonization - allow direct association IED to MeasurementValue | 09/21/2022 04:07 AM |
| 5973 | WG13 Issues | CIM Issues | | | New | Low | | CIM-61850 Harmonization - consider Measurement classes with multiple values (vector, Wye ...) | 09/21/2022 03:36 AM |
| 5972 | WG13 Issues | CIM Issues | | | New | Normal | | CIM-61850 Harmonization - define a method of using IEC 61850 data object names as measurement types | 09/21/2022 03:27 AM |
| 5971 | WG13 Issues | CIM Issues | | | New | Low | | CIM-61850 Harmonization - Consider modelling fans, pump motors and battery systems as types of auxiliary equipment | 09/21/2022 04:01 AM |
| 5885 | CIM Issues | CIM Issues | | | New | Normal | IEC 61970-301 | Consider CIM measurement classes that can hold multiple measured values with the same timestamp and quality. | 07/13/2022 10:50 AM |
| 5884 | CIM Issues | CIM Issues | | | New | Normal | | Modify control model - create DiscreteCommand for enumerations such as raise/lower | 07/13/2022 10:45 AM |
| 5883 | CIM Issues | CIM Issues | | | New | Normal | IEC 61970-301 | Define a standard way to define IEC 61850 data object names for MeasurementTypes and ControlTypes | 07/13/2022 10:31 AM |
| 5882 | CIM Issues | CIM Issues | | | New | Normal | IEC 61970-301 | Model fans, motors, battery systems and similar auxiliary equipment with terminals | 07/13/2022 10:24 AM |
| 5323 | IEC 61850 User Feedback Task Force | Improvement | 3 | WG17 | Resolved | Normal | IEC 61850-7-4,7-5 | Schedules - allow updates to single values while schedules are running | 06/05/2023 01:58 AM |
| 5322 | IEC 61850 User Feedback Task Force | Improvement | 2 | WG17 | Resolved | Normal | IEC 61850-7-4,7-5 | Schedules - add optional data objects to support irregular interval schedules | 06/05/2023 01:58 AM |
| 5321 | IEC 61850 User Feedback Task Force | Improvement | 1 | WG17 | Resolved | Normal | IEC 61850-7-4,7-5 | Schedules - allow 3 values per time point | 06/05/2023 01:58 AM |
| 5312 | WG14 Issues | CIM Issues | | | Review | Normal | IEC 61968 | Change associations for meter UsagePoint to make it more like Measurements | 12/28/2023 11:57 AM |