

Issues

| # | Project | Tracker | ID | Source | Status | Priority | Standard(s) | Subject | Updated |
|------|------------------------------------|------------------|----|--------|-------------|----------|-------------------------------|---|---------------------|
| 6225 | IEC 61850 User Feedback Task Force | Feature | 60 | RTE | In Progress | Normal | IEC 61850-7-4 | Parameters not available in standardized LN - SetPhsOrig | 02/28/2023 09:42 AM |
| 6224 | IEC 61850 User Feedback Task Force | Feature | 59 | RTE | In Progress | Normal | IEC 61850-7-4 | Parameters not available in standardized GAPC LN - SetRef | 02/28/2023 09:42 AM |
| 6223 | IEC 61850 User Feedback Task Force | Feature | 58 | RTE | In Progress | Normal | IEC 61850-7-4 | Parameters not available in standardized GAPC LN - StrVal | 02/28/2023 09:42 AM |
| 6222 | IEC 61850 User Feedback Task Force | Feature | 57 | RTE | In Progress | Normal | IEC 61850-7-4 | Parameters not available in standardized GAPC LN - SetNb | 02/28/2023 09:42 AM |
| 6221 | IEC 61850 User Feedback Task Force | Feature | 56 | RTE | In Progress | Normal | IEC 61850-7-4 | Parameters not available in standardized GAPC LN - OnOff | 02/28/2023 09:42 AM |
| 6220 | IEC TC57 WG10 Future Work | WG10 Future Work | | | New | Normal | IEC 61850-7-4 | Parameters not available in standardized GAPC LN - opDITmms, DITmms | 10/26/2023 05:00 AM |
| 6219 | IEC 61850 User Feedback Task Force | Feature | 54 | RTE | In Progress | Normal | IEC 61850-7-4 | Parameters not available in standardized LN - VRtg, ARtg and HzRtg | 02/28/2023 09:42 AM |
| 6218 | IEC 61850 User Feedback Task Force | Feature | 53 | RTE | In Progress | Normal | IEC 61850-7-4 | Parameters not available in standardized LN - PhyConnITF | 02/28/2023 09:42 AM |
| 6217 | IEC 61850 User Feedback Task Force | Feature | 52 | RTE | In Progress | Normal | IEC 61850-7-4 | Parameters not available in standardized LN - NamAccRtg | 02/28/2023 09:42 AM |
| 6216 | IEC 61850 User Feedback Task Force | Feature | 51 | RTE | In Progress | Normal | IEC 61850-7-4 | Parameters not available in standardized LN - SetPhNum | 02/28/2023 09:42 AM |
| 5091 | IEC 61850 User Feedback Task Force | Feature | 10 | H30 | Resolved | Normal | IEC 61850-2 | Devices types/acronyms | 06/05/2023 01:58 AM |
| 5090 | IEC 61850 User Feedback Task Force | Feature | 9 | H30 | Closed | Normal | IEC 61850-7-1 Ed2.1 | Mod inheritance when multiple root LD's (GrRef's) exist | 12/07/2021 08:19 AM |
| 5089 | IEC 61850 User Feedback Task Force | Improvement | 13 | MH | Resolved | Normal | IEC 61850 7-3 Ed2.1 | Extension of CDC ASG | 06/05/2023 01:58 AM |
| 5088 | IEC 61850 User Feedback Task Force | Feature | 12 | MH | Resolved | Normal | IEC 61850-7-4 Ed2.1 ,7-5 | Clarifications on the local/remote concept 8/8 | 06/05/2023 01:58 AM |
| 5087 | IEC 61850 User Feedback Task Force | Feature | 11 | MH | Resolved | Normal | IEC 61850-7-4 Ed2.1 ,7-5 | Clarifications on the local/remote concept 7/8 | 06/05/2023 01:58 AM |
| 5086 | IEC 61850 User Feedback Task Force | Feature | 10 | MH | Resolved | Normal | IEC 61850-7-4 Ed2.1 ,7-5 | Clarifications on the local/remote concept 6/8 | 06/05/2023 01:58 AM |
| 5085 | IEC 61850 User Feedback Task Force | Feature | 9 | MH | Resolved | Normal | IEC 61850 7-1 / 7-4 Ed2.1,7-5 | Clarifications on the local/remote concept 5/8 | 06/05/2023 01:58 AM |
| 5084 | IEC 61850 User Feedback Task Force | Feature | 8 | MH | Resolved | Normal | IEC 61850-7-1 Ed2.1,7-5 | Clarifications on the local/remote concept 4/8 | 06/05/2023 01:58 AM |
| 5083 | IEC 61850 User Feedback Task Force | Feature | 7 | MH | Resolved | Normal | IEC 61850-7-1 Ed2.1,7-5 | Clarifications on the local/remote concept 3/8 | 06/05/2023 01:58 AM |

| # | Project | Tracker | ID | Source | Status | Priority | Standard(s) | Subject | Updated |
|------|------------------------------------|-------------|----|---------|----------|----------|---|--|---------------------|
| 5082 | IEC 61850 User Feedback Task Force | Feature | 6 | MH | Resolved | Normal | IEC 61850-7-4,7-5 | Clarifications on the local/remote concept 2/8 | 06/05/2023 01:58 AM |
| 5081 | IEC 61850 User Feedback Task Force | Feature | 5 | MH | Resolved | Normal | IEC 61850-7-1 Ed2.1/7-4 Ed2.1 Annex B/7-500 | Clarifications on the local/remote concept 1/8 | 06/05/2023 01:58 AM |
| 5080 | IEC 61850 User Feedback Task Force | Feature | 4 | MH | Resolved | Normal | IEC 61850-7-1 Ed2.1 ,7-500 | Clarification on the ctlModel 3/3 | 06/05/2023 01:58 AM |
| 5079 | IEC 61850 User Feedback Task Force | Feature | 3 | MH | Resolved | Normal | IEC 61850-7-1 Ed2.1, 7-500 | Clarification on the ctlModel 2/3 | 06/05/2023 01:58 AM |
| 5078 | IEC 61850 User Feedback Task Force | Feature | 2 | MH | Resolved | Normal | IEC 61850-7-1 / 7-2 Ed2.1 / 7-5/7-500 | Clarification on the ctlModel 1/3 | 06/05/2023 01:58 AM |
| 5077 | IEC 61850 User Feedback Task Force | Feature | 1 | MH | Closed | Normal | IEC61850 7-1 | Location of SGCB in LD structures | 03/14/2023 09:10 AM |
| 667 | IEC 61850 User Feedback Task Force | Improvement | 4 | WG10 | Resolved | Normal | IEC 61850-7-4 | Report of current active setting group | 06/05/2023 01:58 AM |
| 664 | IEC 61850 User Feedback Task Force | Improvement | 9 | H30 | Closed | Normal | | Recommended improvements to TISSUE Process | 07/13/2021 04:05 PM |
| 660 | IEC 61850 User Feedback Task Force | Support | 1 | WG10 | Closed | Normal | IEC 61850-6, TR IEC 61850-90-30 | IED model documentation | 11/21/2023 09:00 AM |
| 647 | IEC 61850 User Feedback Task Force | Support | 57 | ENTSO-E | Resolved | Normal | IEC 61850-7-500 | Single phase and multi phase trip indication for the autorecloser | 05/09/2023 09:32 AM |
| 633 | IEC 61850 User Feedback Task Force | Improvement | 1 | ZIV | Resolved | Normal | IEC 61850-4 | Initial values of paramRev and valRev | 11/21/2023 09:09 AM |
| 632 | IEC 61850 User Feedback Task Force | Support | 8 | H30 | Resolved | High | IEC 61850-9-2, IEC 61869-9 | APPID 0x4000 - Sampled Values | 12/05/2023 09:16 AM |
| 631 | IEC 61850 User Feedback Task Force | Feature | 44 | RTE | Triage | Normal | | Evolution of LN PSCH to build switching on information | 08/17/2021 08:03 AM |
| 630 | IEC 61850 User Feedback Task Force | Improvement | 43 | RTE | Resolved | Normal | IEC 61850-7-500 | XCBR LN new DO to describe withdrawable circuit breaker | 05/09/2023 09:32 AM |
| 629 | IEC 61850 User Feedback Task Force | Improvement | 35 | RTE | Resolved | Normal | IEC TR 61850-90-29 | TCTR and TVTR new DO to identify physical terminal allocation in the IED | 01/16/2024 08:11 AM |
| 628 | IEC 61850 User Feedback Task Force | Bug | 30 | RTE | Closed | Normal | | Enum type reduction in ICD/SSD file | 03/02/2021 09:54 AM |
| 627 | IEC 61850 User Feedback Task Force | Feature | 29 | RTE | Resolved | Normal | IEC 61850-7-4 | Activation and deactivation of a function by configuration. | 05/09/2023 09:32 AM |
| 626 | IEC 61850 User Feedback Task Force | Improvement | 23 | RTE | Resolved | Normal | TR IEC 61850-90-4, IEC 61850-6 | Extension of P-type to describe connexion type (PhysCon) | 12/05/2023 08:52 AM |
| 625 | IEC 61850 User Feedback Task Force | Improvement | 22 | RTE | Resolved | Normal | IEC 61850-7-4 | LN RADR evolution | 12/05/2023 08:31 AM |

| # | Project | Tracker | ID | Source | Status | Priority | Standard(s) | Subject | Updated |
|-----|------------------------------------|-------------|----|--------|-------------|----------|--------------------------------|---|---------------------|
| 624 | IEC 61850 User Feedback Task Force | Support | 21 | RTE | Resolved | Normal | IEC 61850-6 | Clarification of using of ValKind, Vallmport. | 05/09/2023 09:32 AM |
| 623 | IEC 61850 User Feedback Task Force | Feature | 19 | RTE | In Progress | Normal | | New LN of group L (as "LPLE") representing a group of LED | 03/02/2021 09:42 AM |
| 622 | IEC 61850 User Feedback Task Force | Feature | 18 | RTE | Closed | Normal | IEC 61850-7-4 | Parameters not available in standardized LN | 01/17/2023 09:04 AM |
| 621 | IEC 61850 User Feedback Task Force | Feature | 17 | RTE | In Progress | Normal | IEC 61850-7-4/7-500 | New controllable DO in RREC to define the mode of the recloser of the circuit breaker | 05/11/2021 10:08 AM |
| 620 | IEC 61850 User Feedback Task Force | Feature | 16 | RTE | Closed | Normal | TR 61850-90-29 | New LN LPDO / LPDI in IEC 61850-7-5 | 10/25/2022 08:45 AM |
| 619 | IEC 61850 User Feedback Task Force | Feature | 15 | RTE | Resolved | Normal | | New LN of group L (as "LTED") to represent the dynamic topology of the substation. | 05/09/2023 09:32 AM |
| 618 | IEC 61850 User Feedback Task Force | Improvement | 14 | RTE | Resolved | Normal | IEC 61850-90-3 | Evolution of DO SumSqA of LN SPTRExt | 05/09/2023 09:32 AM |
| 613 | IEC 61850 User Feedback Task Force | Support | 13 | RTE | Closed | Normal | IEC 61850-7-4 | Clarification of representation of tap changer (LN ATTC, YLTC). | 11/09/2021 02:13 PM |
| 612 | IEC 61850 User Feedback Task Force | Feature | 11 | RTE | Resolved | Normal | IEC 61850-7-4 | Need to create a new LN of group P (Protection), as "PCDP" to represent the Pole Discrepancy Protection. | 05/09/2023 09:32 AM |
| 611 | IEC 61850 User Feedback Task Force | Bug | 5 | RTE | In Progress | Normal | IEC 61850-7-4 / IEC 61850-80-6 | Need a new DO (ENUM) to identify the protocol used for the SCADA exchange, in LN ITCI | 11/07/2023 08:29 AM |
| 610 | IEC 61850 User Feedback Task Force | Improvement | 2 | RTE | Resolved | Normal | IEC 61850-6 | Mapping of another phases system description to the generic phases phsA, phsB, phsC | 05/09/2023 09:32 AM |
| 609 | IEC 61850 User Feedback Task Force | Bug | 1 | RTE | Closed | Normal | | The value of the DO LLN0.Health of a LD should inherit from the alarm status of LPHD0.PhyHealth of the IED nesting the LD | 03/02/2021 08:37 AM |
| 608 | IEC 61850 User Feedback Task Force | Feature | 7 | H30 | In Progress | Normal | IEC 61850-90-xx | Comprehensive set of requirements covering validation and supervision of all IEC 61850 communications | 06/21/2022 02:09 AM |
| 607 | IEC 61850 User Feedback Task Force | Support | 6 | H30 | In Progress | Normal | IEC 61850-80-6 (90-2) | LPHD.Sim management | 06/21/2022 02:09 AM |
| 606 | IEC 61850 User Feedback Task Force | Bug | 5 | H30 | Closed | Normal | | LGOS/LSVS mandatory | 02/09/2022 07:48 AM |
| 605 | IEC 61850 User Feedback Task Force | Improvement | 4 | H30 | In Progress | Normal | IEC 61850-10-3 | Test and Simulation mode questions | 06/21/2022 02:09 AM |