

Issues

#	Project	Tracker	ID	Source	Status	Priority	Standard(s)	Subject	Updated
6559	61850-7-5 and 61850-7-500	IEC61850-7-5		Redmine: 6443	New	Normal		Modelling of a Lockout/trip seal-in relay	04/19/2024 09:19 AM
6768	61850-7-5 and 61850-7-500	IEC61850-7-5			New	Normal		Control of substituted or blocked objects	04/19/2024 05:08 AM
6757	WG13 Issues	CIM Issues			New	High		BasicIntervalSchedule and RegularIntervalSchedule	04/17/2024 11:31 AM
6767	IEC 61850 User Feedback Task Force	Bug			New	Normal		Specifying virtualized physical devices and LN's	04/17/2024 10:45 AM
6722	Server	Issues			New	Normal		sGop10 PIXIT reference needed ?	04/17/2024 05:02 AM
6758	WG13 Issues	CIM Issues			New	High		Measurement issues	04/13/2024 12:42 AM
6752	WG14 Part 5 Issues	CIM Issues			New	High		Deprecate Part 5 Modelling	04/02/2024 10:49 AM
6744	WG14 Part 3 Issues	CIM Issues			New	Normal	61968-3	CrewStatusKind enumeration is missing values for deassignment	03/26/2024 11:59 AM
6736	WG13 Issues	CIM Issues			New	Normal	IEC 61970-301	Quality61850 Class does not match the definition of Quality in IEC 61850-7-2	03/12/2024 04:05 PM
6632	WG13 Issues	CIM Issues			New	Normal	61970-301	update definition of deprecated	03/11/2024 03:56 PM
6735	WG16 Issues	CIM Issues			New	Normal		new disclaimer note on every Inf* UML diagram indicating to "use at your own risk"	03/11/2024 02:54 PM
6734	WG16 Issues	CIM Issues			New	Normal		Review use/inheritance of Document by UCA TF 16 classes, profile, standards	03/11/2024 09:58 AM
6616	WG13 Issues	CIM Issues			New	Normal	61970-301; 61970-452	Add SubstationKind	03/11/2024 06:57 AM
6729	CIM Joint Issues	CIM Issues			New	Normal		Multi-commodity Support	03/07/2024 11:10 AM
6730	CIM Joint Issues	CIM Issues			New	Normal		Evaluation of the Pipeline Open Data Standard (PODS)	03/07/2024 11:09 AM
6549	WG14 Part 9 Issues	CIM Issues			New	High	61968-3, 61968-5, 61968-9	Switch Contention Issue	03/07/2024 10:38 AM
5977	WG13 Issues	CIM Issues			New	Normal	61968-13, 61968-11, 61970-600-2	Cardinality of PowerSystemResource to Location	02/28/2024 10:49 AM
6714	IEC TC57 WG10 Future Work	WG10 Future Work		IEC PAS 61850-90-3	New	Normal		Improve the models used for power regulation	02/20/2024 11:04 AM
6265	IEC TC57 WG10 Future Work	WG10 Future Work			New	Normal	IEC 61850-6	track changes in SCL to know when a device needs to be updated based on new SCD version	02/19/2024 10:56 AM
6579	IEC TC57 WG10 Future Work	WG10 Future Work		Vattenfall	New	High	IEC 61850-6	How to add utility process name to DOs	02/19/2024 10:43 AM
6713	WG13 Issues	CIM Issues			New	Normal		Update namespace and profile from http to https	02/18/2024 08:35 AM

#	Project	Tracker	ID	Source	Status	Priority	Standard(s)	Subject	Updated
6376	61850-7-5 and 61850-7-500	IEC61850-7-5			New	Normal		LN PDIF – setting for nominal current	02/13/2024 05:59 AM
6703	IEC TC57 WG10 Future Work	WG10 Future Work		Ed 3 review	New	Normal	IEC 61850-7-4, IEC TS 61850-80-4	Part 80-4 Mapping to COSEM : add reactive and apparent energy data objects to MMTR and MMTN	02/09/2024 02:43 PM
6419	IEC TC57 WG10 Future Work	WG10 Future Work		WG10 Fall workshop	New	Normal		Logical Nodes for SLD/Topology Aware Functions	02/09/2024 04:55 AM
5966	IEC TC57 WG10 Future Work	WG10 Future Work		EDF	New	Normal		Indicate typical SIUnit for every DO with CDC MV would help users + Add a dedicated attribute in NSD files instead of having it in the description ?	02/09/2024 04:02 AM
5103	IEC TC57 WG10 Future Work	WG10 Future Work		IEEE H27	New	Normal	IEC 61850-7-3	Modified/new CDC for IEEE H27	02/09/2024 03:21 AM
6677	CIM Joint Issues	CIM Issues			New	Normal	IEC61968-11 Edition 4, IEC62325-301 Edition 4	Document Class Generalization Refinement	02/08/2024 10:33 AM
6435	IEC TC57 WG10 Future Work	WG10 Future Work		WG10 Fall workshop	New	Low	IEC 61850-9-2	Compression of Sample Value Messages	02/08/2024 05:36 AM
6413	IEC TC57 WG10 Future Work	WG10 Future Work		WG10 Fall workshop	New	Low	IEC 61850-80-7	Asset Management of Setting & Configuration Data	02/08/2024 05:32 AM
5965	IEC TC57 WG10 Future Work	WG10 Future Work			New	Normal	IEC 61850-7-4	Schedules - allow updates to single values while schedules are running	02/08/2024 05:31 AM
6700	IEC TC57 WG10 Future Work	WG10 Future Work			New	Normal	IEC 61850-6	Investigate to align to the new CIM model of transformers	02/08/2024 05:26 AM
6701	IEC TC57 WG10 Future Work	WG10 Future Work			New	Normal	IEC 61850-7-3	Integration of proposed and canceled amendment 2 of part 7-3	02/08/2024 05:25 AM
5928	IEC TC57 WG10 Future Work	WG10 Future Work		IEC 62361-102 R9	New	Normal	IEC 61850-6	CIM-61850 Harmonization - extend tPhaseEnum to match CIM PhaseCode	02/08/2024 05:23 AM
5927	IEC TC57 WG10 Future Work	WG10 Future Work		IEC 62361-102 R15	New	Normal	IEC 61850-7-4	CIM-61850 Harmonization - Add PosFlwIn data object to measurement classes	02/08/2024 05:22 AM
5904	IEC TC57 WG10 Future Work	WG10 Future Work		WG10	New	Normal	IEC 61850-7-4	Introduce alarm and counter DOs in 7-4	02/08/2024 05:22 AM
5878	IEC TC57 WG10 Future Work	WG10 Future Work			New	Normal	IEC 61850-7-4	Technical reports to be considered in edition 3 of IEC 61850-7-4	02/08/2024 05:20 AM
5310	IEC TC57 WG10 Future Work	WG10 Future Work		WG 18	New	Normal	IEC 61850-7-3	New CDC for IEC/TC 57/WG 18	02/08/2024 05:19 AM
5121	IEC TC57 WG10 Future Work	WG10 Future Work			New	Normal	IEC 61850-7-2	sFt2ab does not verify that the LastModified value is consistent or changes when file is modified	02/08/2024 05:18 AM
5104	IEC TC57 WG10 Future Work	WG10 Future Work		WG 17	New	Normal	IEC 61850-6	Add a type code 'INV'	02/08/2024 05:14 AM
3102	IEC TC57 WG10 Future Work	WG10 Future Work		TissueDB	New	Normal	IEC 61850-7-4	https://iec61850.tissue-db.com/tissue/1744 Clarification of Start Times in StrTm.setCal	02/08/2024 05:09 AM

#	Project	Tracker	ID	Source	Status	Priority	Standard(s)	Subject	Updated
5929	IEC TC57 WG10 Future Work	WG10 Future Work		IEC 62361-102 R8	New	Normal	IEC 61850-6	CIM-61850 Harmonization - allow Terminals with no connections - use explicit ConnectivityNode.name = None	02/08/2024 05:08 AM
5930	IEC TC57 WG10 Future Work	WG10 Future Work		IEC 62361-102 R6	New	Normal	IEC 61850-6	CIM-61850 Harmonization - mRID attribute in SCL for Equipment, Terminals, ConnectivitNodes	02/08/2024 05:08 AM
5931	IEC TC57 WG10 Future Work	WG10 Future Work		IEC 62361-102 R3	New	Normal	IEC 61850-6	CIM-61850 Harmonization - Add string attribute psrType to tPowerSystemResource.	02/08/2024 05:08 AM
5932	IEC TC57 WG10 Future Work	WG10 Future Work		IEC 62361-102 R2	New	Normal	IEC 61850-6	CIM-61850 Harmonization - Extend list of equipment type codes	02/08/2024 05:07 AM
5933	IEC TC57 WG10 Future Work	WG10 Future Work		FNN Germany	New	Normal	IEC 61850-7-4	Proposal of a new LN class ASWI	02/08/2024 05:06 AM
5934	IEC TC57 WG10 Future Work	WG10 Future Work		RTE	New	Normal	TR IEC 61850-10-3, TR IEC 61850-90-20	Simultaneous change of InRef.setSrcRef and InRef.setSrcCB for dynamic commutation	02/08/2024 05:02 AM
5935	IEC TC57 WG10 Future Work	WG10 Future Work		MH	New	Normal	IEC 61850-7-3	Extension of CDC ASG	02/08/2024 04:51 AM
5936	IEC TC57 WG10 Future Work	WG10 Future Work		TissueDB	New	Normal	IEC 61850-7-4	IEC61850.Tissue #1756 Event driven schedules – Extend description	02/08/2024 04:49 AM
5937	IEC TC57 WG10 Future Work	WG10 Future Work		WG10	New	Normal	IEC 61850-7-4	Report of current active setting group	02/08/2024 04:46 AM
5938	IEC TC57 WG10 Future Work	WG10 Future Work		RTE	New	Normal	IEC 61850-7-4	LN RADR evolution	02/08/2024 04:44 AM
5939	IEC TC57 WG10 Future Work	WG10 Future Work		RTE	New	Normal	IEC 61850-6	Mapping of another phases system description to the generic phases phsA, phsB, phsC	02/08/2024 04:43 AM
5941	IEC TC57 WG10 Future Work	WG10 Future Work		TissueDB	New	Normal	IEC 61850-7-4	IEC61850.Tissue #1755 Event driven schedules – Add DO to stop schedule by event	02/08/2024 04:39 AM
5942	IEC TC57 WG10 Future Work	WG10 Future Work		RTE	New	Normal	IEC 61850-7-4	Activation and deactivation of a function by configuration.	02/08/2024 04:37 AM
5943	IEC TC57 WG10 Future Work	WG10 Future Work		RTE	New	Normal	IEC 61850-7-4	New LN of group L (as "LTED") to represent the dynamic topology of the substation.	02/08/2024 04:35 AM
5944	IEC TC57 WG10 Future Work	WG10 Future Work		RTE	New	Normal	IEC 61850-7-4	Need to create a new LN of group P (Protection), as "PCDP" to represent the Pole Discrepancy Protection.	02/08/2024 04:27 AM
5964	IEC TC57 WG10 Future Work	WG10 Future Work		Tissue DB	New	Normal	IEC 61850-7-2	Incorrect Attribute type of TrgOp	02/08/2024 04:24 AM
6430	IEC TC57 WG10 Future Work	WG10 Future Work		WG10 Fall workshop	New	Low	IEC 61850-6	Management of SCL File Sizes (Compression Techniques, Handling of Privates)	02/08/2024 03:17 AM
6447	IEC TC57 WG10 Future Work	WG10 Future Work		WG10 Fall workshop	New	Low		Enhanced Quality Information for Measurements (accuracy classes, update periods, filter applied, algorithm applied, etc.)	02/08/2024 03:16 AM

#	Project	Tracker	ID	Source	Status	Priority	Standard(s)	Subject	Updated
6433	IEC TC57 WG10 Future Work	WG10 Future Work		WG10 Fall workshop	New	Low		SCL Extensions (partial configuration updates in a top-down approach, mixed editions with private CDCs, etc.)	02/08/2024 03:03 AM
6436	IEC TC57 WG10 Future Work	WG10 Future Work		WG10 Fall workshop	New	Low	TR IEC 61850-10-3	SCL Modelling of the Test Equipment	02/08/2024 02:36 AM
6446	IEC TC57 WG10 Future Work	WG10 Future Work		WG10 Fall workshop	New	Low	TR IEC 61850-7-500	SCL Modelling of Fault Measurements (RFMX)	02/08/2024 02:12 AM
6448	IEC TC57 WG10 Future Work	WG10 Future Work		WG10 Fall workshop	New	Urgent	TR IEC 61850-7-5	GOOSE treatment as a command	02/08/2024 01:53 AM
6578	IEC TC57 WG10 Future Work	WG10 Future Work		TF 61850-80-6	New	Normal	IEC 61850-7-2; IEC 61850-8-1, 80-6	Extension of the AddCause required to reflect communication issues in multi level control	02/08/2024 01:50 AM
6604	IEC TC57 WG10 Future Work	WG10 Future Work		TissueDB	New	Normal	IEC 61850-7-4	IEC61850.Tissue #1754 Event driven schedules - Type of InSyn missing	02/08/2024 01:42 AM
6613	IEC TC57 WG10 Future Work	WG10 Future Work		TissueDB	New	Normal	IEC 61850-6	IEC61850 Tissue 1833: Service SettingGroups.ConfSG clarification	02/08/2024 01:38 AM
6299	WG13 Issues	CIM Issues			New	Normal		OperationalLimitType; add an attribute to hold the "type" of limit, such as Emergency, Normal, ...	02/07/2024 02:30 PM
6328	WG13 Issues	CIM Issues			New	High	IEC 61970-301, IEC 61970-452, IEC 61070-600	Required usage of BusbarSection	02/07/2024 10:41 AM
6699	61850-7-5 and 61850-7-500	IEC61850-7-5			New	Normal		Behavior of a function while being dynamically blocked	02/07/2024 04:55 AM
6555	61850-7-5 and 61850-7-500	IEC61850-7-5			New	Normal		Behaviour of output contacts when LN is in blocked mode	02/07/2024 03:14 AM
6698	61850-7-5 and 61850-7-500	IEC61850-7-5			New	Normal		Integrate work from AHTF Control Between Functions	02/07/2024 02:29 AM
6686	61850-7-5 and 61850-7-500	IEC61850-7-5		Tissue #1892	New	Normal		Description of the different control methods to change position of OLTC (in automatic, manual modes)	01/23/2024 11:02 AM
6684	61850-7-5 and 61850-7-500	IEC61850-7-5		discussion	New	Normal		Proposal to deprecate 'LocSta' in X and Y group LN classes	01/22/2024 02:50 AM
6680	WG13 Issues	CIM Issues			New	High	61970-456	Support time series/schedule for SSH	01/17/2024 10:19 AM
6679	WG14 Part 11 Issues	CIM Issues			New	Normal		Document class description	01/16/2024 11:54 AM
6678	WG14 Part 11 Issues	CIM Issues			New	Normal		Refactoring Outage Class Modeling	01/16/2024 11:45 AM
6669	Market Management	CIM Issues			New	Normal		Add VATLevel attribute to ChargeType	01/05/2024 09:17 AM
6668	Market Management	CIM Issues			New	Normal		Add VATObliged attribute to ChargeType	01/05/2024 09:03 AM

#	Project	Tracker	ID	Source	Status	Priority	Standard(s)	Subject	Updated
6667	Market Management	CIM Issues			New	Normal		Add an association from ChargeType to Period	01/05/2024 07:58 AM
6666	Market Management	CIM Issues			New	Normal		Add PhaseCount to ESMP	01/05/2024 07:27 AM
6665	Market Management	CIM Issues			New	Normal		Add ChargeGroup to ESMP and move ChargeGroup to MarketCommon	01/05/2024 07:08 AM
6664	Market Management	CIM Issues			New	Normal		Add an association from MktActivityRecord to ChargeGroup	01/05/2024 06:44 AM
6656	CIM Joint Issues	CIM Issues			New	Normal		Add altitudeCompensation to EndDeviceInfo	12/21/2023 10:20 AM
6534	Market Management	CIM Issues			New	Normal		Add an association from Series to ChargeType	12/19/2023 10:32 AM
6634	WG13 Issues	CIM Issues			New	Normal	61970-301; 61970-452	Simplify Name model using enum	12/13/2023 07:58 AM
6636	WG14 Issues	CIM Issues			New	Normal	61968-3;61968-4;61968-5;61968-6	Update Name model for all XSD based profiles	12/13/2023 07:27 AM
6630	WG13 Issues	CIM Issues			New	Normal	61970-301	Update Identity and naming description	12/11/2023 04:43 AM
5978	WG13 Issues	CIM Issues			New	Normal	61968-301	Remove serialization instructions from the UML description of mRID	12/11/2023 04:32 AM
6620	WG14 Issues	CIM Issues			New	High		Enterprise Package Name Related Model Updates	12/05/2023 01:07 PM
6619	CIM Joint Issues	CIM Issues			New	High	IEC61968-3 thru IEC61968-11, IEC61970-301, IEC62325-301	Renaming the CIM UML Model Packages	12/05/2023 12:37 PM
6611	WG14 Part 9 Issues	CIM Issues			New	Normal	61968-9	Formulaic UOMs	11/27/2023 07:09 PM
6610	WG13 Issues	CIM Issues			New	High	61970-301; 61970-452	Multiple issue Measurement and Control	11/27/2023 10:27 AM
6607	61850-7-5 and 61850-7-500	IEC61850-7-5		RTE	New	Normal		Create DO indicating the source of synchronisation	11/21/2023 08:49 AM
6606	61850-7-5 and 61850-7-500	IEC61850-7-5		RTE	New	Normal		CPU monitoring	11/21/2023 08:40 AM
6601	WG14 Part 11 Issues	CIM Issues			New	Normal	61968-Common	Revise TimeSchedule class	11/16/2023 11:46 AM
6600	WG14 Part 9 Issues	CIM Issues			New	Normal	61968-9	Multipliers	11/16/2023 11:33 AM
6544	WG14 Part 9 Issues	CIM Issues			New	Normal	61968-9, 61968-4	Meter Asset Accuracy Class	11/16/2023 11:17 AM
6553	WG13 Issues	CIM Issues			New	High		Removal of InfGrid package InfSIPS	11/15/2023 10:48 AM
6597	CIM Joint Issues	CIM Issues			New	Normal		MarketManagement::Quantity has attribute and relation with the same name "quantity"	11/14/2023 08:00 AM
6584	CIM Joint Issues	CIM Issues			New	High		Handling unit multiplier needs joint WG consensus on approach	11/08/2023 07:03 AM

#	Project	Tracker	ID	Source	Status	Priority	Standard(s)	Subject	Updated
6583	WG14 Part 4 Issues	CIM Issues			New	Normal		Inheritance of Tower and Pole	11/07/2023 02:05 PM
6582	WG14 Part 4 Issues	CIM Issues			New	Normal		May need to add "kind" attribute to OverheadStructure to be consistent with UndergroundStructure.kind	11/07/2023 02:04 PM
6346	WG13 Issues	CIM Issues			New	Normal	61970-301,, 61968-13	[GMDM #14] Indicating starting point for feeder tracing	11/06/2023 10:55 AM
5379	WG14 Part 1 Issues	CIM Issues			New	Normal	61968-1	Construction Planning revision	11/04/2023 01:04 PM
6573	CIM Joint Issues	CIM Issues			New	Normal		Profile class duplicates	11/03/2023 03:34 AM
6572	WG14 Part 11 Issues	CIM Issues			New	Normal		IEC61968CIMVersion class is in triplicate	11/02/2023 04:07 PM
6144	IEC TC57 WG10 Future Work	WG10 Future Work		IOP 2022	New	Normal	IEC 61850-6	Need to add SCL mechanism to define a minimum MinTime	10/26/2023 05:21 AM
6151	IEC TC57 WG10 Future Work	WG10 Future Work		Tissue DB	New	Normal	IEC 61850-7-3	Use and configuration of ORG within the scope of InRef 7 BlkRef	10/26/2023 05:20 AM
6153	IEC TC57 WG10 Future Work	WG10 Future Work		Tissue DB	New	Normal	IEC 61850-7-4	https://iec61850.tissue-db.com/tissue/1691 Contradictory statement for Mod.stVal	10/26/2023 05:19 AM
6154	IEC TC57 WG10 Future Work	WG10 Future Work		Tissue DB	New	Normal	IEC 61850-7-4	https://iec61850.tissue-db.com/tissue/1698 AnOut in GAPC	10/26/2023 05:19 AM
6155	IEC TC57 WG10 Future Work	WG10 Future Work		Tissue DB	New	Normal	TR IEC 61850-7-500	https://iec61850.tissue-db.com/tissue/1706 Missing LN for Miniature Circuit Breaker (MCB)	10/26/2023 05:19 AM
6562	61850-7-5 and 61850-7-500	IEC61850-7-5		Redmine: 6155	New	Normal		Missing LN for Miniature Circuit Breaker (MCB)	10/26/2023 05:17 AM
6156	IEC TC57 WG10 Future Work	WG10 Future Work		Tissue DB	New	Normal	IEC 61850-7-3	https://iec61850.tissue-db.com/tissue/1748 Arrays of CDC	10/26/2023 05:15 AM
6158	IEC TC57 WG10 Future Work	WG10 Future Work		Tissue DB	New	Normal	IEC 61850-7-4	https://iec61850.tissue-db.com/tissue/1760 - OMulti for MMET data objects	10/26/2023 05:14 AM
6159	IEC TC57 WG10 Future Work	WG10 Future Work		Tissue DB	New	Normal	TR IEC 61850-90-3	https://iec61850.tissue-db.com/tissue/1789 SCBR - Coilxxx-Data-Objects shall be OMulti	10/26/2023 05:14 AM
6160	IEC TC57 WG10 Future Work	WG10 Future Work		Tissue DB	New	Normal	TR IEC 61850-90-29	https://iec61850.tissue-db.com/tissue/1796 LPHD.PwrSupAlm as OMulti	10/26/2023 05:13 AM
6161	IEC TC57 WG10 Future Work	WG10 Future Work		Tissue DB	New	Normal	TR IEC 61850-7-5	https://iec61850.tissue-db.com/tissue/1797 - SwModKey dependency of CSWI from LLN0	10/26/2023 05:08 AM
6162	IEC TC57 WG10 Future Work	WG10 Future Work		Tissue DB	New	Normal	TR IEC 61850-7-500	https://iec61850.tissue-db.com/tissue/1803 - Mechanical Blocking of 3 way switches	10/26/2023 05:07 AM
6163	IEC TC57 WG10 Future Work	WG10 Future Work		Tissue DB	New	Normal	TR IEC 61850-7-5	https://iec61850.tissue-db.com/tissue/1804 - When e.g. LocSta = false, result of command to switch DO Mod with "station-control" not clear.	10/26/2023 05:06 AM

#	Project	Tracker	ID	Source	Status	Priority	Standard(s)	Subject	Updated
6164	IEC TC57 WG10 Future Work	WG10 Future Work		Tissue DB	New	Normal	IEC 61850-7-4	https://iec61850.tissue-db.com/tissue/1825 - Permission mode for control/setting of a scheduled entity from a client	10/26/2023 05:03 AM
6165	IEC TC57 WG10 Future Work	WG10 Future Work		Tissue DB	New	Normal	TR IEC 61850-7-500	https://iec61850.tissue-db.com/tissue/1844 - Implementation of SumSwARs in 3-phase circuit breaker inaccurate	10/26/2023 05:01 AM
6185	IEC TC57 WG10 Future Work	WG10 Future Work		2022 IOP	New	Normal	IEC 61850-6	SCL Need to differentiate the difference in the number of GOOSE vs R-GOOSE	10/26/2023 05:01 AM
6220	IEC TC57 WG10 Future Work	WG10 Future Work			New	Normal	IEC 61850-7-4	Parameters not available in standardized GAPC LN - opDITmms, DITmms	10/26/2023 05:00 AM
6316	IEC TC57 WG10 Future Work	WG10 Future Work		RTE	New	Normal	IEC 61850-6	Clarification of using of ValKind, VallImport.	10/26/2023 04:58 AM
6319	IEC TC57 WG10 Future Work	WG10 Future Work			New	Normal	IEC 61850-6	maxAttributes - conflicting requirements between GOOSE and reporting	10/26/2023 04:58 AM
6358	IEC TC57 WG10 Future Work	WG10 Future Work			New	Normal	IEC 61850	IEC 61850-7-4 list of abbreviations	10/26/2023 04:56 AM
6410	IEC TC57 WG10 Future Work	WG10 Future Work		UCA Test. Committee	New	Normal	IEC 61850-7-2	SBOs to be deprecated in future.	10/26/2023 04:42 AM
6412	IEC TC57 WG10 Future Work	WG10 Future Work		WG10 Fall workshop	New	Normal	IEC 61850-7-3	Improved SCL Modelling of Function Inputs (InRef/ExtRef)	10/26/2023 04:41 AM
6417	IEC TC57 WG10 Future Work	WG10 Future Work		WG10 Fall workshop	New	Normal	TR IEC 61850-90-4	SCL Modelling of the Communication Network and All its Components	10/26/2023 04:40 AM
6423	IEC TC57 WG10 Future Work	WG10 Future Work		WG10 Fall workshop	New	Normal	TS IEC 61850-80-7	SCL Control Block	10/26/2023 04:32 AM
6427	IEC TC57 WG10 Future Work	WG10 Future Work		WG10 Fall workshop	New	Normal	TR IEC 61850-90-3	New Logical Nodes - Battery Charger	10/26/2023 04:31 AM
6429	IEC TC57 WG10 Future Work	WG10 Future Work		WG10 Fall workshop	New	Normal	IEC 61850-7-4xx	Logical Node Groups with Dedicated Namespaces	10/26/2023 04:28 AM
6432	IEC TC57 WG10 Future Work	WG10 Future Work		WG10 Fall workshop	New	Normal	TR IEC 61850-90-30	SCL Engineering Lifecycle, Types and Security for SCL files and Elements	10/26/2023 04:26 AM
6561	IEC TC57 WG10 Future Work	WG10 Future Work			New	Normal	IEC 61850-7-4	Modeling of primary equipment	10/26/2023 04:20 AM
6441	IEC TC57 WG10 Future Work	WG10 Future Work		WG10 Fall workshop	New	Normal	TR IEC 61850-90-14	Extensions to "Z" Logical Nodes (e.g. ZBAT)	10/26/2023 04:10 AM
6560	61850-7-5 and 61850-7-500	IEC61850-7-5		Redmine: 6443	New	Normal		Multiple information sources	10/26/2023 04:02 AM
6558	61850-7-5 and 61850-7-500	IEC61850-7-5		Redmine: 6443	New	Normal		How to model composed functions	10/26/2023 04:01 AM
6557	61850-7-5 and 61850-7-500	IEC61850-7-5		Redmine: 6443	New	Normal		Modelling of various MCB trips	10/26/2023 04:00 AM

#	Project	Tracker	ID	Source	Status	Priority	Standard(s)	Subject	Updated
6556	61850-7-5 and 61850-7-500	IEC61850-7-5		Redmine: 6443	New	Normal		How to impact the data quality of a data with respect to the communication links, the intermediate processing, the device hosting it.	10/26/2023 04:00 AM
6524	IEC TC57 WG10 Future Work	WG10 Future Work			New	Normal	IEC 61850-7-4	https://iec61850.tissue-db.com/tissue/670-enable/disable/LN/via/setting/new/DO/SetMod	10/26/2023 03:54 AM
6143	IEC TC57 WG10 Future Work	WG10 Future Work			New	High	TR IEC 61850-7-500, TR IEC 61850-90-3	Update the Switchgear / Breaker Model	10/26/2023 03:50 AM
6437	IEC TC57 WG10 Future Work	WG10 Future Work		WG10 Fall workshop	New	High	TR IEC 61850-7-5	Logical Device Inheritance Rules for LocSta	10/26/2023 03:43 AM
6439	IEC TC57 WG10 Future Work	WG10 Future Work		WG10 Fall workshop	New	High		Inter-substation GOOSE Naming convention (90-1)	10/26/2023 03:42 AM
6411	IEC TC57 WG10 Future Work	WG10 Future Work		WG10 Fall workshop	New	Urgent	TR IEC 61850-7-500, TR IEC 61850-90-3	Update the Model of Circuit Breaker/Disconnecter Switch	10/26/2023 03:08 AM
6422	IEC TC57 WG10 Future Work	WG10 Future Work		WG10 Fall workshop	New	Urgent	IEC 61850-7-4xx	Consistent Handling of Abbreviations for Data Object Names Within/Across All Domains and Namespaces	10/26/2023 02:52 AM
6428	IEC TC57 WG10 Future Work	WG10 Future Work		WG10 Fall workshop	New	Urgent	IEC 61850-6	Next Steps with IEC 61850-90-11 (Publish versus Corrigenda)	10/26/2023 02:47 AM
6369	WG14 Part 9 Issues	CIM Issues			New	Normal	61968-9	Support EVSE by adding new ReadingTypeID and EndDeviceEvent codes	10/24/2023 05:09 PM
6508	WG14 Part 9 Issues	CIM Issues			New	Normal	61968-9	Support the means to identify the accuracy of the measurement in <MeterReadings>	10/19/2023 11:28 AM
6543	WG14 Part 9 Issues	CIM Issues			New	Normal	IEC 61968-9 and others	AccuracyClass for sensors	10/19/2023 09:43 AM
6542	WG14 Part 9 Issues	CIM Issues			New	Normal	61968-9 and 61968-5	Group Management	10/19/2023 08:48 AM
6529	WG14 Part 9 Issues	CIM Issues			New	Normal	61968-9	Load Control Capabilities	10/19/2023 08:32 AM
5380	WG14 Part 7 Issues	CIM Issues			New	Normal		Customer Installation Management	10/16/2023 01:17 PM
5868	WG13 Issues	CIM Issues			New	Normal		New BusSegment for busbar modeling	10/08/2023 12:30 AM
6537	61850-7-5 and 61850-7-500	IEC61850-7-5			New	Normal		Harmonizing expressions in 7-500 Ed.1	10/06/2023 08:13 AM
6535	Market Management	CIM Issues			New	Normal		Add ChargeComponent to IEC 62325-351	09/28/2023 10:58 AM
6533	Market Management	CIM Issues			New	Normal		Add ChargeType to IEC 62325-351	09/28/2023 10:56 AM
6536	Market Management	CIM Issues			New	Normal		Add an association from ChargeType to MarketParticipant	09/28/2023 10:17 AM

#	Project	Tracker	ID	Source	Status	Priority	Standard(s)	Subject	Updated
6512	WG14 Part 9 Issues	CIM Issues			New	Normal	61968-9	Support measurements of configuration status	09/21/2023 03:05 PM
6507	WG14 Part 9 Issues	CIM Issues			New	Normal	61968-9	Support IoT sensors by adding durations of time in the seconds range.	09/21/2023 02:11 PM
6528	WG13 Issues	CIM Issues			New	Normal	61968-13	Evaluate information provided by IntrapPhaseSpacing class	09/20/2023 01:04 PM
6511	WG14 Part 9 Issues	CIM Issues			New	Normal	61968-9	Support gas metering with additional event codes and measurements	08/29/2023 03:29 PM
6510	Market Management	CIM Issues			New	Normal		Add an association between MarketEvaluationPoint and MktPSRType	08/21/2023 10:11 AM
6366	WG14 Part 9 Issues	CIM Issues			New	Normal	61968-9	Ground as a phase	08/17/2023 10:29 AM
6497	61850-7-5 and 61850-7-500	IEC61850-7-5			New	Normal		Explanation text of IEC/TR 61850-7-500 clause 10.1.1.2	08/02/2023 10:43 AM
6496	61850-7-5 and 61850-7-500	IEC61850-7-5			New	Normal		Typo in section 13.3	08/02/2023 08:54 AM
6454	CIM Issues	CIM Issues			New	Normal	61970-301	RemoteUnit minor typo in 301 description	06/28/2023 04:27 PM
6345	WG13 Issues	CIM Issues			New	Normal	61970-301, 61970-452, 61968-13	[GMDM #13] Overhead / underground indicator on equipment	06/28/2023 11:07 AM
6408	61850-7-5 and 61850-7-500	IEC61850-7-5			New	Normal		Clarification of addCause	06/20/2023 08:37 AM
6407	61850-7-5 and 61850-7-500	IEC61850-7-5			New	Normal		Schedules - allow 3 values per time point	06/20/2023 08:36 AM
6406	61850-7-5 and 61850-7-500	IEC61850-7-5			New	Normal		Schedules - add optional data objects to support irregular interval schedules	06/20/2023 08:36 AM
6405	61850-7-5 and 61850-7-500	IEC61850-7-5			New	Normal		Schedules - allow updates to single values while schedules are running	06/20/2023 08:35 AM
5979	WG14 Part 9 Issues	CIM Issues			New	Normal	IEC 61968-9 and others	Meter to UsagePoint relationship should be many-to-many	06/15/2023 09:32 AM
6387	61850-7-5 and 61850-7-500	IEC61850-7-5			New	Normal		S/S related applications: Auxiliary circuit supervision	06/14/2023 08:20 AM
6386	61850-7-5 and 61850-7-500	IEC61850-7-5			New	Normal		Voltage protection: Overvoltage protection - 3ph operate	06/14/2023 08:20 AM
6385	61850-7-5 and 61850-7-500	IEC61850-7-5			New	Normal		Voltage protection: Undervoltage protection - 3ph operate	06/14/2023 08:19 AM
6384	61850-7-5 and 61850-7-500	IEC61850-7-5			New	Normal		New controllable DO in RREC to define the mode of the recloser of the circuit breaker	06/14/2023 08:19 AM
6383	61850-7-5 and 61850-7-500	IEC61850-7-5			New	Normal		Single phase and multi phase trip indication for the autorecloser	06/14/2023 08:19 AM

#	Project	Tracker	ID	Source	Status	Priority	Standard(s)	Subject	Updated
6382	61850-7-5 and 61850-7-500	IEC61850-7-5			New	Normal		Clarification on the ctlModel 1/3	06/14/2023 08:18 AM
6380	61850-7-5 and 61850-7-500	IEC61850-7-5			New	Normal		Clarification on the ctlModel 2/3	06/14/2023 08:18 AM
6379	61850-7-5 and 61850-7-500	IEC61850-7-5			New	Normal		Clarification on the ctlModel 3/3	06/14/2023 08:17 AM
6377	61850-7-5 and 61850-7-500	IEC61850-7-5			New	High		Update the Switchgear / Breaker Model	06/14/2023 08:17 AM
6247	WG13 Issues	CIM Issues			New	Normal	61970-301	Missing support for fault indicators	06/14/2023 04:32 AM
6357	WG13 Issues	CIM Issues			New	Normal	61970-301, 61970-452, 61968-13	[GMDM #9] Modeling behind the inverter	06/14/2023 04:13 AM
6147	WG13 Issues	CIM Issues			New	Normal		[GMDM #1] Streamlining of tank-based transformer modelling	06/13/2023 10:01 AM
5295	CIM Joint Issues	CIM Issues			New	Normal	61968-11, 61968-4, 61970-301, 61968-13	Joint issue on ACLineSegment physical modeling clarification	06/13/2023 09:06 AM
6372	CIM Joint Issues	CIM Issues			New	High		Inconsistencies in Nameplate data for DERs	06/12/2023 08:18 AM
6368	WG14 Part 9 Issues	CIM Issues			New	High	61968-9	The interplay between events and status measurements should be supported more cleanly	06/01/2023 11:03 AM
6367	WG14 Part 9 Issues	CIM Issues			New	Normal	61968-9	Prepay Metering	06/01/2023 08:51 AM
6322	WG14 Part 9 Issues	CIM Issues			New	Normal	61968-9	New "Low Loss Potential" Quality Code needed in Part 9	06/01/2023 08:37 AM
6296	WG14 Part 9 Issues	CIM Issues			New	Normal	61968-9	New "Transformer Compensated" Quality Code needed in Part 9	06/01/2023 08:10 AM
5950	WG14 Part 9 Issues	CIM Issues			New	Normal	61968-9, 61968-11	How is readCycle used, should the definition be updated?	05/31/2023 07:13 PM
6344	WG13 Issues	CIM Issues			New	Normal	61970-301, 61970-452, 61968-13	[GMDM #10] Add .orderedPhases attribute on LinearShuntCompensatorPhase	05/24/2023 09:36 AM
6343	WG13 Issues	CIM Issues			New	Normal	61970-301, 61970-452, 61968-13	[GMDM #7] Convention for use of xxxPhase classes	05/24/2023 09:36 AM
6342	WG13 Issues	CIM Issues			New	Normal	61970-301, 61970-452, 61968-13	[GMDM #8] Phase modeling on the low side of residential and commercial service transformers	05/24/2023 09:35 AM
6341	WG13 Issues	CIM Issues			New	Normal	61970-301, 61970-452	[GMDM #4] Support for transformer type designation / determination	05/24/2023 09:34 AM
6329	WG13 Issues	CIM Issues			New	High	IEC61970-301, IEC61970-456	VsConverter required and optional attributes in SSH and SV Profiles	05/10/2023 11:18 AM
6297	WG14 Part 9 Issues	CIM Issues			New	Normal	61968-9	New Event code needed in Part 9 for DC Voltage	04/20/2023 09:54 AM
6321	CIM Issues	CIM Issues			New	Normal		Update the description of MktActivityRecord	04/20/2023 03:46 AM

#	Project	Tracker	ID	Source	Status	Priority	Standard(s)	Subject	Updated
6298	WG14 Part 9 Issues	CIM Issues			New	Normal	61968-9	New Event codes needed in Part 9 for overvoltage and undervoltage	03/22/2023 08:48 AM
6295	WG14 Issues	CIM Issues			New	Normal	61968-9	Publication of meter firmware versions from Part 9 to Part 4.	03/21/2023 03:54 PM
6294	WG14 Issues	CIM Issues			New	Normal	61968-9	IRM	03/21/2023 03:46 PM
5313	WG13 Issues	CIM Issues			New	Low		Better description for governorSCD	02/16/2023 06:10 AM
6267	CIM Joint Issues	CIM Issues			New	High	IEC61968-11	Person and Organization Relationships	02/15/2023 09:31 AM
6266	CIM Issues	CIM Issues			New	Normal	IEC61968-11	Person and Person Role Modeling	02/15/2023 09:21 AM
5093	WG13 Issues	CIM Issues			New	Normal		[GMDM #6] Clarify ambiguity on using Terminal phases for unbalanced loads.	02/15/2023 04:49 AM
6249	CIM Issues	CIM Issues			New	Normal		Update CIM namespace	02/06/2023 01:17 PM
6245	WG14 Part 3 Issues	CIM Issues			New	Normal		It is not possible to convey that an UnplannedOutage is frozen (prediction is suspended).	02/01/2023 02:29 PM
6244	WG14 Part 3 Issues	CIM Issues			New	Normal		Part 3 should specify that you can use 'updated' verb	01/31/2023 03:32 PM
6243	WG14 Part 3 Issues	CIM Issues			New	Normal		UnplannedOutages is missing OutageArea and AreaKind	01/31/2023 03:29 PM
6242	WG14 Part 3 Issues	CIM Issues			New	Normal		OutageArea has nowhere to put the name of the outage area	01/31/2023 03:26 PM
6241	WG14 Part 3 Issues	CIM Issues			New	Normal		UnplannedOutages does not provide a way to capture affected kVA for IEEE load-based indices	01/31/2023 03:23 PM
6240	WG14 Part 3 Issues	CIM Issues			New	Normal		UnplannedOutages has no way to indicate that the outage should be excluded from reliability reporting.	01/31/2023 02:59 PM
6239	WG14 Part 3 Issues	CIM Issues			New	Normal		UnplannedOutages profile needs ability to capture de-energized and energized times per UsagePoint	01/31/2023 02:26 PM
6231	Market Management	CIM Issues			New	Normal		Add the new datatype ESMPDataTypes / SettlementMethodType_String and enumeration	01/30/2023 10:21 AM
6194	WG14 Part 3 Issues	CIM Issues			New	Normal		PlannedOutageNotifications needs to support energize/de-energize time/date per UsagePoint.	11/29/2022 12:50 PM
6178	WG13 Issues	CIM Issues			New	Low		Relation between ResourcePerformanceEvaluation and ResourcePerformanceGlobalFactor contains a typo at the source side (role) of the association.	11/11/2022 08:12 AM
5341	WG13 Issues	CIM Issues			New	Normal	61970-452	CPSM (61970-452) artifacts not published	09/22/2022 03:43 PM
5976	WG13 Issues	CIM Issues			New	Normal		CIM-61850 Harmonization - revise control model for DiscreteCommand (e.g. raise/lower)	09/21/2022 04:13 AM
5974	WG13 Issues	CIM Issues			New	Normal		CIM-61850 Harmonization - allow direct association IED to MeasurementValue	09/21/2022 04:07 AM

#	Project	Tracker	ID	Source	Status	Priority	Standard(s)	Subject	Updated
5971	WG13 Issues	CIM Issues			New	Low		CIM-61850 Harmonization - Consider modelling fans, pump motors and battery systems as types of auxiliary equipment	09/21/2022 04:01 AM
5975	WG13 Issues	CIM Issues			New	Normal		CIM-61850 Harmonization - define a standard list of control types	09/21/2022 03:59 AM
5973	WG13 Issues	CIM Issues			New	Low		CIM-61850 Harmonization - consider Measurement classes with multiple values (vector, Wye ...)	09/21/2022 03:36 AM
5972	WG13 Issues	CIM Issues			New	Normal		CIM-61850 Harmonization - define a method of using IEC 61850 data object names as measurement types	09/21/2022 03:27 AM
5235	WG14 Issues	CIM Issues			New	Normal		Need to model Vehicles and Tools	09/13/2022 02:14 AM
5897	WG13 Issues	CIM Issues			New	Normal	61968-13	CDPSM Substation.Station and Substation.SupplyingStation	07/13/2022 02:22 PM
5896	WG13 Issues	CIM Issues			New	Normal	61968-13	CDPSM conflicting roles RotatingMachine.HydroPump and HydroPump.RotatingMachine	07/13/2022 02:20 PM
5895	WG13 Issues	CIM Issues			New	Normal	61968-13	CDPSM OperationalLimitSet.RateTemperature	07/13/2022 02:17 PM
5894	WG13 Issues	CIM Issues			New	Normal	61968-13	CDPSM conflicting roles OperationalLimitType.OperationalLimit and OperationalLimit.OperationalLimitType	07/13/2022 02:15 PM
5893	WG13 Issues	CIM Issues			New	Normal	61968-13	CDPSM conflicting roles HydroPowerPlant.HydroPumps and HydroPump.HydroPowerPlant	07/13/2022 02:13 PM
5892	WG13 Issues	CIM Issues			New	Normal	61968-13	CDPSM EquipmentContainer.WeatherStation	07/13/2022 02:10 PM
5891	WG13 Issues	CIM Issues			New	Normal	61968-13	CDPSM CurrentTransformer.CurrentTransformerPhase	07/13/2022 02:08 PM
5890	WG13 Issues	CIM Issues			New	Normal	61968-13	CDPSM WirePhaseInfo.WireEarthInfo	07/13/2022 02:05 PM
5889	WG13 Issues	CIM Issues			New	Normal	61968-13	CDPSM WireInfo.WireInfoType	07/13/2022 02:03 PM
5887	WG13 Issues	CIM Issues			New	Normal	61968-13	CDPSM CatalogAssetType.TypeAssetCatalogue	07/13/2022 01:59 PM
5886	WG13 Issues	CIM Issues			New	Normal	61968-13	CDPSM missing TransformerTank and TransformerTankEnd	07/13/2022 01:54 PM
5885	CIM Issues	CIM Issues			New	Normal	IEC 61970-301	Consider CIM measurement classes that can hold multiple measured values with the same timestamp and quality.	07/13/2022 10:50 AM
5884	CIM Issues	CIM Issues			New	Normal		Modify control model - create DiscreteCommand for enumerations such as raise/lower	07/13/2022 10:45 AM
5883	CIM Issues	CIM Issues			New	Normal	IEC 61970-301	Define a standard way to define IEC 61850 data object names for MeasurementTypes and ControlTypes	07/13/2022 10:31 AM

#	Project	Tracker	ID	Source	Status	Priority	Standard(s)	Subject	Updated
5882	CIM Issues	CIM Issues			New	Normal	IEC 61970-301	Model fans, motors, battery systems and similar auxiliary equipment with terminals	07/13/2022 10:24 AM
5340	WG13 Issues	CIM Issues			New	Normal	61968-13	CDPSM (61968-13) artifacts not published	04/07/2022 09:50 AM
5315	WG14 Part 1 Issues	CIM Issues			New	Normal		Rename Customer Site Installation Management to CSIM	02/12/2022 01:08 PM
5303	WG13 Issues	CIM Issues			New	Normal	61968-11, 61968-4, 61970-301, 61968-13	5302:5303 61970 portion of TransformerTank to TransformerTankInfo association	01/30/2022 05:32 AM
5301	WG14 Issues	CIM Issues			New	Normal	61968-11, 61968-4	5302:5301 61968 portion of TransformerTankInfo to TransformerTank association	01/30/2022 05:09 AM
5068	WG13 Issues	CIM Issues			New	Normal	61970-301	Energy allocation to devices	01/26/2022 11:05 AM
5214	WG14 Part 1 Issues	CIM Issues			New	Normal		Customer Installation Management (CIM) rename	01/12/2022 02:44 PM
5213	WG14 Part 1 Issues	CIM Issues			New	Normal		Customer Account Management (ACT) not following naming convention	01/12/2022 02:44 PM
5212	WG14 Part 1 Issues	CIM Issues			New	Normal		CompatibleUnit association to Conceptual Design Development	01/12/2022 02:44 PM
5211	WG14 Part 1 Issues	CIM Issues			New	Normal		Missing structural analysis function	01/12/2022 02:44 PM
5210	WG14 Part 1 Issues	CIM Issues			New	Normal		Consider to add Business Actor & Role into the IRM for Ed.4	01/12/2022 02:44 PM
5209	WG14 Part 1 Issues	CIM Issues			New	Normal		Outage Management Business Function	01/12/2022 02:44 PM
5208	WG14 Part 1 Issues	CIM Issues			New	Normal		To link ArchiMate to UML on how to use IRM for Part teams	01/12/2022 02:44 PM
5207	WG14 Part 1 Issues	CIM Issues			New	Normal		Add Business Roles into IRM Model (for Ed.4)	01/12/2022 02:44 PM
5206	WG14 Part 1 Issues	CIM Issues			New	Normal		TC57 WG13 / 14 scope	01/12/2022 02:44 PM
5205	WG14 Part 1 Issues	CIM Issues			New	Normal		Asset Decision Support (ADS)	01/12/2022 02:44 PM
5204	WG14 Part 1 Issues	CIM Issues			New	Normal		Use of IEC Cloud server for IRM model	01/12/2022 02:44 PM
5203	WG14 Part 1 Issues	CIM Issues			New	Normal		IRM team to review SyC work for 61850 actors	01/12/2022 02:44 PM
5202	WG14 Part 1 Issues	CIM Issues			New	Normal		Function decomposition	01/12/2022 02:44 PM
5201	WG14 Part 1 Issues	CIM Issues			New	Normal		Document the process on using IEC 62913 series business / system use cases	01/12/2022 02:44 PM
5200	WG14 Part 1 Issues	CIM Issues			New	Normal		Add an activity diagram example in Appendix A.5	01/12/2022 02:44 PM

#	Project	Tracker	ID	Source	Status	Priority	Standard(s)	Subject	Updated
5199	WG14 Part 1 Issues	CIM Issues			New	Normal		Need to include functions relevant to Transactive Energy	01/12/2022 02:44 PM
5198	WG14 Part 1 Issues	CIM Issues			New	Normal		Merge EXT business functions to individual Parts	01/12/2022 02:44 PM
5197	WG14 Part 1 Issues	CIM Issues			New	Normal		To align IRM with Archimate 2.x	01/12/2022 02:44 PM
5196	WG14 Part 1 Issues	CIM Issues			New	Normal		A consolidated IRM for WG13, WG14 and WG16	01/12/2022 02:44 PM
5195	WG14 Part 1 Issues	CIM Issues			New	Normal		Typos in Annex A	01/12/2022 02:44 PM
5194	WG14 Part 1 Issues	CIM Issues			New	Normal		Public Outage Data Distribution	01/12/2022 02:44 PM
5193	WG14 Part 1 Issues	CIM Issues			New	Normal		First Responder Outage Data Distribution	01/12/2022 02:44 PM
5192	WG14 Part 1 Issues	CIM Issues			New	Normal		Move message header (including verbs) and other structures into Part-100	01/12/2022 02:44 PM
5191	WG14 Part 1 Issues	CIM Issues			New	Normal		Discussion on the IEC 62913 Ed 1 SGAM to identify any gaps for Part-1 IRM	01/12/2022 02:44 PM
5190	WG14 Part 1 Issues	CIM Issues			New	Normal		IoT functions to be accommodated	01/12/2022 02:44 PM
5189	WG14 Part 1 Issues	CIM Issues			New	Normal		Merge EPRI / SGIP Use Case Actors list into Part-1 IRM	01/12/2022 02:44 PM
5188	WG14 Part 1 Issues	CIM Issues			New	Normal		Key ADMS functionalities:	01/12/2022 02:44 PM
5187	WG14 Part 1 Issues	CIM Issues			New	Normal		IRM sub-function issues from the Part 4 work	01/12/2022 02:44 PM
5186	WG14 Part 1 Issues	CIM Issues			New	Normal		Incomplete IEC 61968 Data Model, Profiles and Messages	01/12/2022 02:44 PM
5185	WG14 Part 1 Issues	CIM Issues			New	Normal		Use case harmonisation between SGIP and EPRI	01/12/2022 02:44 PM
5184	WG14 Part 1 Issues	CIM Issues			New	Normal		SGIP Function/Services missing in the Part-1 IRM	01/12/2022 02:44 PM
5183	WG14 Part 1 Issues	CIM Issues			New	Normal		Use SGIP actor list and TC8 actor list by reference	01/12/2022 02:43 PM
5182	WG14 Part 1 Issues	CIM Issues			New	Normal		Needs a centralized repository for common profiles of entire WG14	01/12/2022 02:43 PM
5181	WG14 Part 1 Issues	CIM Issues			New	Normal		Customer support (Part-8) on Demand Response	01/12/2022 02:43 PM
5180	WG14 Part 1 Issues	CIM Issues			New	Normal		Business functions on HAN / DER / EV	01/12/2022 02:43 PM

#	Project	Tracker	ID	Source	Status	Priority	Standard(s)	Subject	Updated
5179	WG14 Part 1 Issues	CIM Issues			New	Normal		To clarify interoperability	01/12/2022 02:43 PM
5178	WG14 Part 1 Issues	CIM Issues			New	Normal		Update Section 3.3 / Table 2	01/12/2022 02:43 PM
5177	WG14 Part 1 Issues	CIM Issues			New	Normal		Update Section 5.6 / Last paragraph	01/12/2022 02:43 PM
5176	WG14 Part 1 Issues	CIM Issues			New	Normal		Update Section A.6 / Table A.2	01/12/2022 02:43 PM
5175	WG14 Part 1 Issues	CIM Issues			New	Normal		Re-organize Figure 1	01/12/2022 02:43 PM
5174	WG14 Part 1 Issues	CIM Issues			New	Normal		Change "61968-1" to "61968" so "...Figure 1 clarifies the scope of IEC 61968 graphically in terms of"	01/12/2022 02:43 PM
5173	WG14 Part 1 Issues	CIM Issues			New	Normal		Consider to specify "automated geographical mapping"	01/12/2022 02:43 PM
5172	WG14 Part 1 Issues	CIM Issues			New	Normal		Are profiles related to grammar/syntax or only to an abstract definition of CIM subset ?	01/12/2022 02:43 PM
5171	WG14 Part 1 Issues	CIM Issues			New	Normal		61968 RDF statement	01/12/2022 02:43 PM
5170	WG14 Part 1 Issues	CIM Issues			New	Normal		Comments on Web Services (WS)	01/12/2022 02:43 PM
5169	WG14 Part 1 Issues	CIM Issues			New	Normal		Describe the meaning of "DAC" "VRU"	01/12/2022 02:43 PM
5168	WG14 Part 1 Issues	CIM Issues			New	Normal		Modify "enables a non-compliant software application to use the services."	01/12/2022 02:43 PM
5167	WG14 Part 1 Issues	CIM Issues			New	Normal		Typo	01/12/2022 02:43 PM
5166	WG14 Part 1 Issues	CIM Issues			New	Normal		Should the section refer to IEC/PAS 62559 ?	01/12/2022 02:43 PM
5165	WG14 Part 1 Issues	CIM Issues			New	Normal		Message type comment	01/12/2022 02:43 PM
5164	WG14 Part 1 Issues	CIM Issues			New	Normal		Recommendation / direction on foreign language support	01/12/2022 02:43 PM
5163	WG14 Part 1 Issues	CIM Issues			New	Normal		Mobile Workforce Management	01/12/2022 02:43 PM
5162	WG14 Part 1 Issues	CIM Issues			New	Normal		Missing actor AM-MAM in Part-1	01/12/2022 02:43 PM
5161	WG14 Part 1 Issues	CIM Issues			New	Normal		Refer to methodology document	01/12/2022 02:43 PM

#	Project	Tracker	ID	Source	Status	Priority	Standard(s)	Subject	Updated
5097	WG13 Issues	CIM Issues			New	Normal	61970-301, 61970-452	Allow OperationalLimitSet to be described by a Season by adding a new association between OperationalLimitSet and Season	10/01/2021 11:24 AM
757	WG14 Issues	CIM Issues			New	Normal		test	08/11/2021 11:29 AM
6764	WG16 Issues	CIM Issues			In Progress	Normal		ResourceCertification.qualificationFlag description is incorrect	04/18/2024 10:40 AM
6766	WG16 Issues	CIM Issues			In Progress	Normal		ResourceCertification attribute type is generic and could be renamed to a more describe attribute name	04/18/2024 10:37 AM
6765	WG16 Issues	CIM Issues			In Progress	Normal		ResourceCertification.type - update the description to describe the usage of the attribute "type"	04/18/2024 10:25 AM
6753	Server	Issues			In Progress	Normal		sGos20, sGos21 force DUT as Subscriber to ignore future edition dataset elements, while 61850-7-1 expects achievable forward compatibility	04/16/2024 08:45 AM
6685	GOOSE Performance	Issues			In Progress	Normal		Device need to be certified for Ed2.1 server first	04/16/2024 08:43 AM
6724	Client	Issues			In Progress	Normal		GOOSE Subscriber sGos12 test expects DUT to _send_ a GOOSE message	04/16/2024 08:42 AM
6723	Server	Issues			In Progress	Normal		GOOSE destination MAC address according Amd1: PIXIT Gs1 mismatches enhancement of sGos5	04/16/2024 08:41 AM
6728	Client	Issues			In Progress	Normal		cSg13 refers to PIXIT entry Sg5/Sg6 but not clarified in the expected result	04/16/2024 08:35 AM
6739	IEC 61850 User Feedback Task Force	Feature			In Progress	Normal		How to deal with 'Beh' and 'Health' of isolated functions	04/09/2024 08:43 AM
6452	WG13 Issues	CIM Issues			In Progress	Normal	61970-301,61970-452	Allow multiple RatioTapChanger on one TransformerEnd	03/12/2024 02:26 AM
6726	61850-7-5 and 61850-7-500	IEC61850-7-5		RTE	In Progress	Normal		New LN of group L (as "LTED") to represent the dynamic topology of the substation.	02/29/2024 09:07 AM
6725	61850-7-5 and 61850-7-500	IEC61850-7-5		RTE	In Progress	Normal		Simultaneous change of InRef.setSrcRef and InRef.setSrcCB for dynamic commutation	02/29/2024 09:07 AM
6711	61850-7-5 and 61850-7-500	IEC61850-7-5		WG10 Fall workshop	In Progress	Low		SCL Modelling of Fault Measurements (RFMX)	02/29/2024 08:33 AM
6451	WG13 Issues	CIM Issues			In Progress	Normal	61970-452	Cardinality inconsistency for PowerElectronicsConnection<->PowerElectronics Unit between canonical model and profile	02/14/2024 11:28 AM
5248	WG14 Part 6 Issues	CIM Issues			In Progress	High	61968-6	Contract work	11/09/2023 11:44 AM

#	Project	Tracker	ID	Source	Status	Priority	Standard(s)	Subject	Updated
611	IEC 61850 User Feedback Task Force	Bug	5	RTE	In Progress	Normal	IEC 61850-7-4 / IEC 61850-80-6	Need a new DO (ENUM) to identify the protocol used for the SCADA exchange, in LN ITCI	11/07/2023 08:29 AM
5336	IEC 61850 User Feedback Task Force	Feature	4	TF 61850-80-6	In Progress	Normal	IEC 61850-7-2; IEC 61850-8-1, 80-6	Extension of the AddCause required to reflect communication issues in multi level control	11/07/2023 08:28 AM
6175	IEC 61850 User Feedback Task Force	Bug		2022 IOP	In Progress	Normal	IEC 61850-6	SCL SICS requires SNTP even with 2.1 where PTP is the preferred method.	11/07/2023 08:21 AM
6414	IEC TC57 WG10 Future Work	WG10 Future Work		WG10 Fall workshop	In Progress	Urgent		Golden Single Line Diagram For All SCL/GCL/HCL Examples	10/26/2023 02:58 AM
6420	IEC TC57 WG10 Future Work	WG10 Future Work		WG10 Fall workshop	In Progress	Urgent	IEC 61850-6, IEC 61850-7-x, IEC 61850-8-1, IEC 61850-9-2	Validation of SCL Files Using Object Constraint Language (OCL)	10/26/2023 02:57 AM
5076	WG13 Issues	CIM Issues			In Progress	High	61970-301, 61970-452, 61970-456	Convention and usage of operational limits of GeneratingUnit and injections	10/18/2023 11:03 AM
5250	WG14 Part 11 Issues	CIM Issues			In Progress	High		Document identification	10/17/2023 03:04 AM
4943	WG13 Issues	CIM Issues			In Progress	High		ControlAreaGenratingUnit2: IOP suggest to clarify the usage	10/11/2023 11:14 AM
5063	WG13 Issues	CIM Issues			In Progress	Normal	61970-301, 61970-452, 61970-456	There are a variety of issues with RegulatingControl. Thes	10/08/2023 12:42 AM
6499	61850-7-5 and 61850-7-500	IEC61850-7-5			In Progress	Normal		Explanation text on the application of check conditions	10/05/2023 08:57 AM
6500	61850-7-5 and 61850-7-500	IEC61850-7-5			In Progress	Normal		Parameters to enforce the checking of interlocking and synchronism	10/05/2023 08:57 AM
6378	61850-7-5 and 61850-7-500	IEC61850-7-5			In Progress	Normal		Clarifications on the local/remote concept 1/8	10/05/2023 08:56 AM
6393	61850-7-5 and 61850-7-500	IEC61850-7-5			In Progress	Normal		Clarifications on the local/remote concept 7/8	10/05/2023 08:55 AM
6392	61850-7-5 and 61850-7-500	IEC61850-7-5			In Progress	Normal		Clarifications on the local/remote concept 6/8	10/05/2023 08:55 AM
6391	61850-7-5 and 61850-7-500	IEC61850-7-5			In Progress	Normal		Clarifications on the local/remote concept 5/8	10/05/2023 08:55 AM
6390	61850-7-5 and 61850-7-500	IEC61850-7-5			In Progress	Normal		Clarifications on the local/remote concept 4/8	10/05/2023 08:55 AM
6389	61850-7-5 and 61850-7-500	IEC61850-7-5			In Progress	Normal		Clarifications on the local/remote concept 3/8	10/05/2023 08:55 AM
6388	61850-7-5 and 61850-7-500	IEC61850-7-5			In Progress	Normal		Clarifications on the local/remote concept 2/8	10/05/2023 08:55 AM
6394	61850-7-5 and 61850-7-500	IEC61850-7-5			In Progress	Normal		Clarifications on the local/remote concept 8/8	09/14/2023 08:04 AM

#	Project	Tracker	ID	Source	Status	Priority	Standard(s)	Subject	Updated
6482	61850-7-5 and 61850-7-500	IEC61850-7-5			In Progress	Normal		Figures 36, 37, 38	09/14/2023 07:56 AM
6375	61850-7-5 and 61850-7-500	IEC61850-7-5			In Progress	Normal		XCBR LN new DO to describe withdrawable circuit breaker	08/24/2023 07:57 AM
4939	WG13 Issues	CIM Issues			In Progress	Low		Is schedules needed for HVDCThe use cases for HVDC schedul	07/12/2023 11:00 AM
4922	WG13 Issues	CIM Issues			In Progress	High		Temperature dependent and most restrictive operational limit	06/14/2023 09:50 AM
5375	WG13 Issues	CIM Issues			In Progress	Urgent		Clean up transformer documentation - Margaret removed paragraphs from Part-11 and see where they fit [GMDM #5] (align xf descriptions in 61870-301, -457 and 61968-11, -13)	06/14/2023 09:49 AM
6347	WG13 Issues	CIM Issues			In Progress	Normal		[GMDM #15] Add a limited amount of 'structure' modeling to distribution grid models	06/14/2023 09:47 AM
5302	CIM Joint Issues	CIM Issues			In Progress	Normal	61968-11, 61968-4, 61970-301, 61968-13	Explicit association between TransformerTank and TransformerTankInfo	05/24/2023 08:58 AM
5005	WG13 Issues	CIM Issues			In Progress	High	61970-301	GroundDisconnect examplesThe intended use of GroundDisco	04/12/2023 11:17 AM
6222	IEC 61850 User Feedback Task Force	Feature	57	RTE	In Progress	Normal	IEC 61850-7-4	Parameters not available in standardized GAPC LN - SetNb	02/28/2023 09:42 AM
6223	IEC 61850 User Feedback Task Force	Feature	58	RTE	In Progress	Normal	IEC 61850-7-4	Parameters not available in standardized GAPC LN - StrVal	02/28/2023 09:42 AM
6224	IEC 61850 User Feedback Task Force	Feature	59	RTE	In Progress	Normal	IEC 61850-7-4	Parameters not available in standardized GAPC LN - SetRef	02/28/2023 09:42 AM
6225	IEC 61850 User Feedback Task Force	Feature	60	RTE	In Progress	Normal	IEC 61850-7-4	Parameters not available in standardized LN - SetPhsOrig	02/28/2023 09:42 AM
5374	IEC 61850 User Feedback Task Force	Feature		RTE	In Progress	Normal	IEC 61850-7-4	Creation of a new LN for protection function	02/28/2023 09:42 AM
677	IEC 61850 User Feedback Task Force	Feature	50	RTE	In Progress	Normal	IEC 61850-7-4	Impact of IEC 61869-13 (SAMU)	02/28/2023 09:42 AM
6216	IEC 61850 User Feedback Task Force	Feature	51	RTE	In Progress	Normal	IEC 61850-7-4	Parameters not available in standardized LN - SetPhNum	02/28/2023 09:42 AM
6217	IEC 61850 User Feedback Task Force	Feature	52	RTE	In Progress	Normal	IEC 61850-7-4	Parameters not available in standardized LN - NamAccRtg	02/28/2023 09:42 AM

#	Project	Tracker	ID	Source	Status	Priority	Standard(s)	Subject	Updated
6218	IEC 61850 User Feedback Task Force	Feature	53	RTE	In Progress	Normal	IEC 61850-7-4	Parameters not available in standardized LN - PhyConnITF	02/28/2023 09:42 AM
6219	IEC 61850 User Feedback Task Force	Feature	54	RTE	In Progress	Normal	IEC 61850-7-4	Parameters not available in standardized LN - VRtg, ARtg and HzRtg	02/28/2023 09:42 AM
6221	IEC 61850 User Feedback Task Force	Feature	56	RTE	In Progress	Normal	IEC 61850-7-4	Parameters not available in standardized GAPC LN - OnOff	02/28/2023 09:42 AM
5309	WG13 Issues	CIM Issues			In Progress	High		Support on FACTS device modeling	02/14/2023 06:12 PM
5970	IEC 61850 User Feedback Task Force	Improvement		2022 f2F IOP	In Progress	Normal	IEC 61850-6	SCT behavior needs to be specified regarding mismatch between substation section and IED section	11/08/2022 08:24 AM
5015	WG13 Issues	CIM Issues			In Progress	Normal	61970-501	Create validation constraints for the UML model and profile	09/22/2022 03:11 PM
5952	WG13 Issues	CIM Issues			In Progress	Normal	61968-11	Clarification of how midnight is expressed in time-related CIM Compound classes	09/22/2022 02:21 PM
5947	WG13 Issues	CIM Issues			In Progress	Normal	61970-456	Description classes inheriting from IdentifiedObject	09/19/2022 02:50 PM
5803	WG16 Issues	CIM Issues			In Progress	Normal		Add meterReadingPeriodicity attribute (String) in the MarketEvaluationPoint class	09/15/2022 04:01 PM
556	IEC 61850 User Feedback Task Force	Support	3	H30	In Progress	Normal	IEC 61850-90-20	Rendundant CT/TT measurements	06/21/2022 02:09 AM
605	IEC 61850 User Feedback Task Force	Improvement	4	H30	In Progress	Normal	IEC 61850-10-3	Test and Simulation mode questions	06/21/2022 02:09 AM
607	IEC 61850 User Feedback Task Force	Support	6	H30	In Progress	Normal	IEC 61850-80-6 (90-2)	LPHD.Sim management	06/21/2022 02:09 AM
608	IEC 61850 User Feedback Task Force	Feature	7	H30	In Progress	Normal	IEC 61850-90-xx	Comprehensive set of requirements covering validation and supervision of all IEC 61850 communications	06/21/2022 02:09 AM
3098	IEC 61850 User Feedback Task Force	Improvement	1	WG17	In Progress	Normal		Need to Change 8-1 to allow multiple DOs to be written	03/29/2022 09:36 AM
5124	IEC 61850 User Feedback Task Force	Feature	3	TF 61850-80-6	In Progress	Normal	IEC 61850-80-6	Telemonitoring blocking	12/21/2021 09:26 AM
621	IEC 61850 User Feedback Task Force	Feature	17	RTE	In Progress	Normal	IEC 61850-7-4/7-500	New controllable DO in RREC to define the mode of the recloser of the circuit breaker	05/11/2021 10:08 AM

#	Project	Tracker	ID	Source	Status	Priority	Standard(s)	Subject	Updated
623	IEC 61850 User Feedback Task Force	Feature	19	RTE	In Progress	Normal		New LN of group L (as "LPLE") representing a group of LED	03/02/2021 09:42 AM
6749	Server	Issues			Resolved	High		Clarification of ExtRef attributes usage - TISSUE 1818	04/16/2024 08:31 AM
6750	Server	Issues			Resolved	High		sAddr length - TISSUE 1885	04/16/2024 08:17 AM
6751	IEC 61850 TPWG	Issues			Resolved	Normal		Update IEC 61850 QAP Addendum for adding requirement quickly	04/16/2024 08:16 AM
6738	IEC 61850 User Feedback Task Force	Improvement			Resolved	Normal		Amending TGSN LN class with settings for adapting the signal	04/09/2024 08:19 AM
6737	IEC 61850 User Feedback Task Force	Improvement			Resolved	Normal	IEC 61850-90-29	Amending TGSN LN class with signal characteristics	04/09/2024 08:10 AM
6710	Server	Issues			Resolved	Normal		sSrv13 does not specify that the lower hierarchy Mod.stVal shall not change	04/02/2024 02:42 PM
6688	Client	Issues			Resolved	Normal		cSrvN10 - Ed1 specific error codes do not exist for MMS GetNameList	04/02/2024 08:42 AM
6727	Client	Issues			Resolved	Normal		cDsN1bc, cFtN2 have no non-Ed2 specific error code	04/02/2024 08:42 AM
6697	Server	Issues			Resolved	Normal		sRpN9 does not specify the expected access error by negative response on SetURCBValues	04/02/2024 08:40 AM
6489	GOOSE Performance	Issues			Resolved	Normal		Reducing the needed resources for time correlated subscribed GOOSE not used for ping-pong	01/23/2024 08:05 AM
629	IEC 61850 User Feedback Task Force	Improvement	35	RTE	Resolved	Normal	IEC TR 61850-90-29	TCTR and TVTR new DO to identify physical terminal allocation in the IED	01/16/2024 08:11 AM
6631	SCL Tooling	Issues			Resolved	Normal		tTf1 (mustUnderstand) for the ICT test needs clarification	01/09/2024 08:59 AM
6655	Client	Issues			Resolved	Normal		cLogN5 is missing in table A4.2 and certificate template	01/09/2024 08:28 AM
6654	Client	Issues			Resolved	Normal		Tracking numbering mismatch Ed2 <> Ed2.1	01/09/2024 08:27 AM
6617	SCL Tooling	Issues			Resolved	Normal		tIeN1 - can a popup warning be considered as 'not allowed'	12/12/2023 08:58 AM
632	IEC 61850 User Feedback Task Force	Support	8	H30	Resolved	High	IEC 61850-9-2, IEC 61869-9	APPID 0x4000 - Sampled Values	12/05/2023 09:16 AM
626	IEC 61850 User Feedback Task Force	Improvement	23	RTE	Resolved	Normal	TR IEC 61850-90-4, IEC 61850-6	Extension of P-type to describe connexion type (PhysCon)	12/05/2023 08:52 AM

#	Project	Tracker	ID	Source	Status	Priority	Standard(s)	Subject	Updated
625	IEC 61850 User Feedback Task Force	Improvement	22	RTE	Resolved	Normal	IEC 61850-7-4	LN RADR evolution	12/05/2023 08:31 AM
438	IEC 61850 User Feedback Task Force	Feature	1	Vattenfall	Resolved	Normal	IEC 61850-4	The engineering-process is well defined for a green field / new IEC 61850 substation but needs clarification for refurbishment	12/05/2023 08:26 AM
633	IEC 61850 User Feedback Task Force	Improvement	1	ZIV	Resolved	Normal	IEC 61850-4	Initial values of paramRev and valRev	11/21/2023 09:09 AM
672	IEC 61850 User Feedback Task Force	Improvement	46	RTE	Resolved	Normal	TR IEC 61850-7-500	Create DO indicating the source of synchronisation	11/21/2023 08:49 AM
673	IEC 61850 User Feedback Task Force	Improvement	47	RTE	Resolved	Normal	TR IEC 61850-7-500	CPU monitoring	11/21/2023 08:40 AM
675	IEC 61850 User Feedback Task Force	Support	48	RTE	Resolved	Normal	IEC 61850-7-4 Ed2.1	Clarification of blocked mode	11/21/2023 08:38 AM
6596	IEC 61850 User Feedback Task Force	Bug			Resolved	Normal		Simulation Mode with Centralized Protection	11/21/2023 08:32 AM
6605	IEC 61850 User Feedback Task Force	Support		RTE	Resolved	Normal	TR IEC 61850-7-500	Identification of three phase trip with ACT DO	11/21/2023 08:13 AM
439	IEC 61850 User Feedback Task Force	Bug	2	Vattenfall	Resolved	High	IEC 61850-6	How to add utility process name to DOs	11/07/2023 09:04 AM
590	IEC 61850 User Feedback Task Force	Feature	1800	IOP_2019	Resolved	Normal	IEC 61850-6	ICT fails to check validity of the SCD file regarding the IED constraints	11/07/2023 08:22 AM
6483	Server	Issues			Resolved	Normal		Need to be able to test 61850-7-420	09/05/2023 08:14 AM
6488	GOOSE Performance	Issues			Resolved	Low		Incorrect reference	09/05/2023 08:08 AM
6490	Client	Issues			Resolved	Normal		UCAiug requires Ed2Amd1 Jan 2024 - expect testlabs/toolvendors need more time	08/22/2023 08:16 AM
6471	Client	Issues			Resolved	Normal		Select.response+ (Tissue 1753)	08/22/2023 08:10 AM
6465	GOOSE Performance	Issues			Resolved	Normal		The Ed2 GOOSE performance also apply for Ed2Amd1	08/08/2023 08:42 AM
6463	Client	Issues			Resolved	Normal		cSrv7, cSvrN3 some clients only read DA (not DO)	07/25/2023 08:07 AM
6464	Client	Issues			Resolved	Normal		cSrv5 change the condition to GetDataValues or Reporting	07/11/2023 08:38 AM

#	Project	Tracker	ID	Source	Status	Priority	Standard(s)	Subject	Updated
6370	IEC 61850 User Feedback Task Force	Improvement			Resolved	Normal		SBOs to be deprecated in future.	06/20/2023 09:39 AM
6263	IEC 61850 User Feedback Task Force	Bug			Resolved	Normal	IEC 61850-6	GOOSE MinTime / Max Time - Probable discrepancy between Part-6 and Part-8	06/20/2023 08:44 AM
6248	IEC 61850 User Feedback Task Force	Improvement		EDF	Resolved	Normal	IEC 61850-6	There are controls between IEDs for automatic control functions, we need to be able to represent those controls in SCL (for configuration in SCT, data flow documentation...)	06/14/2023 08:33 AM
6256	IEC 61850 User Feedback Task Force	Bug			Resolved	Normal	IEC 61850-7-4	IEC 61850-7-4 list of abbreviations	06/06/2023 08:32 AM
6303	IEC 61850 User Feedback Task Force	Support		RTE	Resolved	Normal	IEC 61850-7-500	LN PDIF – setting for nominal current	06/05/2023 01:58 AM
6246	IEC 61850 User Feedback Task Force	Feature			Resolved	Normal	IEC 61850-6	ExtRef cannot specify a Poll intended to be implemented as a GetDataSetValues request	06/05/2023 01:58 AM
6226	IEC 61850 User Feedback Task Force	Bug			Resolved	Normal		In the downgrading rules from ed 2.1 to ed 2.0 in part 6, it is mentioned to exclude ORS CDC (I.4.2.4). Why CDCs: CST, VSD and TCS that were also added in ed2.1 are not mentioned to be excluded also ?	06/05/2023 01:58 AM
6207	IEC 61850 User Feedback Task Force	Improvement			Resolved	Normal	IEC 61850-6	How to manage update of an IEDName or LDName for object references when vallmport is false	06/05/2023 01:58 AM
6167	IEC 61850 User Feedback Task Force	Support		email	Resolved	Normal	IEC 61850-90-6	IEC 61850-90-6 Voltage presence CDC for SVPI.Prs	06/05/2023 01:58 AM
5968	IEC 61850 User Feedback Task Force	Improvement			Resolved	Normal		Change the diagrams in 7-500 to not use yellow lines	06/05/2023 01:58 AM
5955	IEC 61850 User Feedback Task Force	Improvement		EDF	Resolved	Normal		Indicate typical SIUnit for every DO with CDC MV would help users + Add a dedicated attribute in NSD files instead of having it in the description ?	06/05/2023 01:58 AM
5876	IEC 61850 User Feedback Task Force	Improvement		FNN Germany	Resolved	Normal	IEC 61850-7-4 Ed.3	Proposal of a new LN class ASWI	06/05/2023 01:58 AM
5372	IEC 61850 User Feedback Task Force	Improvement		RTE	Resolved	Normal	IEC 61850-7-1	Simultaneous change of InRef.setSrcRef and InRef.setSrcCB for dynamic commutation	06/05/2023 01:58 AM

#	Project	Tracker	ID	Source	Status	Priority	Standard(s)	Subject	Updated
5335	IEC 61850 User Feedback Task Force	Improvement		Dustin Tessier	Resolved	Normal	IEC 61850-90-4	Adding Normative Requirements & Conformance Testing Pertaining to Broadcast Storms	06/05/2023 01:58 AM
5331	IEC 61850 User Feedback Task Force	Feature		SCL IOP 2021	Resolved	Normal	IEC 61850-6	Multiple LNodes implemented by same LN	06/05/2023 01:58 AM
5330	IEC 61850 User Feedback Task Force	Improvement		SCL IOP 2021	Resolved	Normal	IEC 61850-90-30	LNode iedName attribute usage needs to be clarified	06/05/2023 01:58 AM
5329	IEC 61850 User Feedback Task Force	Improvement		SCL IOP 2021	Resolved	Normal	IEC 61850-6	Clarify iedType attribute usage in DataTypeTemplates	06/05/2023 01:58 AM
5321	IEC 61850 User Feedback Task Force	Improvement	1	WG17	Resolved	Normal	IEC 61850-7-4,7-5	Schedules - allow 3 values per time point	06/05/2023 01:58 AM
5322	IEC 61850 User Feedback Task Force	Improvement	2	WG17	Resolved	Normal	IEC 61850-7-4,7-5	Schedules - add optional data objects to support irregular interval schedules	06/05/2023 01:58 AM
5123	IEC 61850 User Feedback Task Force	Feature	2	TF 61850-80-6	Resolved	Normal	IEC 61850-90-28	ACSI service for link supervision on application level	06/05/2023 01:58 AM
5323	IEC 61850 User Feedback Task Force	Improvement	3	WG17	Resolved	Normal	IEC 61850-7-4,7-5	Schedules - allow updates to single values while schedules are running	06/05/2023 01:58 AM
5122	IEC 61850 User Feedback Task Force	Feature	1	TF 61850-80-6	Resolved	Normal	IEC 61850-90-28	New LN in LN group L to reflect the status of TPAA between Proxy/Gateway and IED	06/05/2023 01:58 AM
5091	IEC 61850 User Feedback Task Force	Feature	10	H30	Resolved	Normal	IEC 61850-2	Devices types/acronyms	06/05/2023 01:58 AM
5086	IEC 61850 User Feedback Task Force	Feature	10	MH	Resolved	Normal	IEC 61850-7-4 Ed2.1 ,7-5	Clarifications on the local/remote concept 6/8	06/05/2023 01:58 AM
5087	IEC 61850 User Feedback Task Force	Feature	11	MH	Resolved	Normal	IEC 61850-7-4 Ed2.1 ,7-5	Clarifications on the local/remote concept 7/8	06/05/2023 01:58 AM
5088	IEC 61850 User Feedback Task Force	Feature	12	MH	Resolved	Normal	IEC 61850-7-4 Ed2.1 ,7-5	Clarifications on the local/remote concept 8/8	06/05/2023 01:58 AM
5089	IEC 61850 User Feedback Task Force	Improvement	13	MH	Resolved	Normal	IEC 61850 7-3 Ed2.1	Extension of CDC ASG	06/05/2023 01:58 AM

#	Project	Tracker	ID	Source	Status	Priority	Standard(s)	Subject	Updated
5085	IEC 61850 User Feedback Task Force	Feature	9	MH	Resolved	Normal	IEC 61850 7-1 / 7-4 Ed2.1,7-5	Clarifications on the local/remote concept 5/8	06/05/2023 01:58 AM
3099	IEC 61850 User Feedback Task Force	Improvement	1	TissueDB	Resolved	Normal	IEC 61850-7-4	IEC61850.Tissue #1756 Event driven schedules – Extend description	06/05/2023 01:58 AM
5078	IEC 61850 User Feedback Task Force	Feature	2	MH	Resolved	Normal	IEC 61850-7-1 / 7-2 Ed2.1 / 7-5/7-500	Clarification on the ctlModel 1/3	06/05/2023 01:58 AM
3100	IEC 61850 User Feedback Task Force	Improvement	2	TissueDB	Resolved	Normal	IEC 61850-7-4	IEC61850.Tissue #1754 Event driven schedules - Type of InSyn missing	06/05/2023 01:58 AM
5079	IEC 61850 User Feedback Task Force	Feature	3	MH	Resolved	Normal	IEC 61850-7-1 Ed2.1, 7-500	Clarification on the ctlModel 2/3	06/05/2023 01:58 AM
3101	IEC 61850 User Feedback Task Force	Bug	3	TissueDB	Resolved	Normal	IEC 61850-7-4	IEC61850.Tissue #1755 Event driven schedules – Add DO to stop schedule by event	06/05/2023 01:58 AM
5080	IEC 61850 User Feedback Task Force	Feature	4	MH	Resolved	Normal	IEC 61850-7-1 Ed2.1 ,7-500	Clarification on the ctlModel 3/3	06/05/2023 01:58 AM
676	IEC 61850 User Feedback Task Force	Support	49	RTE	Resolved	Normal	IEC 61850-7-5	Clarification of addCause	06/05/2023 01:58 AM
5081	IEC 61850 User Feedback Task Force	Feature	5	MH	Resolved	Normal	IEC 61850-7-1 Ed2.1/7-4 Ed2.1 Annex B/7-500	Clarifications on the local/remote concept 1/8	06/05/2023 01:58 AM
5082	IEC 61850 User Feedback Task Force	Feature	6	MH	Resolved	Normal	IEC 61850-7-4,7-5	Clarifications on the local/remote concept 2/8	06/05/2023 01:58 AM
5083	IEC 61850 User Feedback Task Force	Feature	7	MH	Resolved	Normal	IEC 61850-7-1 Ed2.1,7-5	Clarifications on the local/remote concept 3/8	06/05/2023 01:58 AM
5084	IEC 61850 User Feedback Task Force	Feature	8	MH	Resolved	Normal	IEC 61850-7-1 Ed2.1,7-5	Clarifications on the local/remote concept 4/8	06/05/2023 01:58 AM
519	IEC 61850 User Feedback Task Force	Support	1	UFTF	Resolved	Normal	80-7	Optionality in DOI NamPlt, PhyNam resp. in ICD/IID file: IED.manufacturer, .IED.type, makes a device recognition in a machine to	06/05/2023 01:58 AM
599	IEC 61850 User Feedback Task Force	Feature	12	IOP_2019	Resolved	Normal		ICD files do not match requirements (several issues) - increase in engineering efforts	06/05/2023 01:58 AM

#	Project	Tracker	ID	Source	Status	Priority	Standard(s)	Subject	Updated
667	IEC 61850 User Feedback Task Force	Improvement	4	WG10	Resolved	Normal	IEC 61850-7-4	Report of current active setting group	06/05/2023 01:58 AM
6327	SCL Tooling	Issues			Resolved	Normal		tTf2 - export CID file only for Ed2.1?	05/16/2023 08:20 AM
6326	SCL Tooling	Issues			Resolved	Normal		tlie1 - remove step 10-14 to undo previous changes	05/16/2023 08:09 AM
6325	SCL Tooling	Issues			Resolved	Normal		PIXIT missing entries on tlie1 "when supported"	05/16/2023 08:04 AM
624	IEC 61850 User Feedback Task Force	Support	21	RTE	Resolved	Normal	IEC 61850-6	Clarification of using of ValKind, VallImport.	05/09/2023 09:32 AM
627	IEC 61850 User Feedback Task Force	Feature	29	RTE	Resolved	Normal	IEC 61850-7-4	Activation and deactivation of a function by configuration.	05/09/2023 09:32 AM
630	IEC 61850 User Feedback Task Force	Improvement	43	RTE	Resolved	Normal	IEC 61850-7-500	XCBR LN new DO to describe withdrawable circuit breaker	05/09/2023 09:32 AM
647	IEC 61850 User Feedback Task Force	Support	57	ENTSO-E	Resolved	Normal	IEC 61850-7-500	Single phase and multi phase trip indication for the autorecloser	05/09/2023 09:32 AM
612	IEC 61850 User Feedback Task Force	Feature	11	RTE	Resolved	Normal	IEC 61850-7-4	Need to create a new LN of group P (Protection), as "PCDP" to represent the Pole Discrepancy Protection.	05/09/2023 09:32 AM
618	IEC 61850 User Feedback Task Force	Improvement	14	RTE	Resolved	Normal	IEC 61850-90-3	Evolution of DO SumSqA of LN SPTRExt	05/09/2023 09:32 AM
619	IEC 61850 User Feedback Task Force	Feature	15	RTE	Resolved	Normal		New LN of group L (as "LTED") to represent the dynamic topology of the substation.	05/09/2023 09:32 AM
602	IEC 61850 User Feedback Task Force	Feature	1742	IOP_2019	Resolved	Normal	IEC 61850-9-3	Merging Unit standard requires MU clock to jump on PTP time jumps, which is not true for Boundary Clocks.	05/09/2023 09:32 AM
610	IEC 61850 User Feedback Task Force	Improvement	2	RTE	Resolved	Normal	IEC 61850-6	Mapping of another phases system description to the generic phases phsA, phsB, phsC	05/09/2023 09:32 AM
554	IEC 61850 User Feedback Task Force	Support	1	H30	Resolved	Normal		Performance requirement for SV and implications to Protection applications	05/09/2023 09:32 AM
597	IEC 61850 User Feedback Task Force	Feature	1120	IOP_2019	Resolved	Normal	61850-90-28	SCTs updating the confRev of 9-2 LE Sampled Value streams - problem with subscription to test tool SV injection	05/09/2023 09:32 AM
553	IEC 61850 User Feedback Task Force	Support	34	IOP_2017/55	Resolved	Normal	IEC 61850-9-3	IEC/IEEE 61850-9-3 should clarify the meaning and use of TimeTraceable and FrequencyTraceable	05/09/2023 09:32 AM

#	Project	Tracker	ID	Source	Status	Priority	Standard(s)	Subject	Updated
572	IEC 61850 User Feedback Task Force	Support	44	ENTSO-E	Resolved	Normal	IEC 61850-7-500	S/S related applications: Auxiliary circuit supervision	05/09/2023 09:32 AM
579	IEC 61850 User Feedback Task Force	Support	51	ENTSO-E	Resolved	Normal	IEC 61850-7-500	Voltage protection: Overvoltage protection - 3ph operate	05/09/2023 09:32 AM
580	IEC 61850 User Feedback Task Force	Support	52	ENTSO-E	Resolved	Normal	IEC 61850-7-500	Voltage protection: Undervoltage protection - 3ph operate	05/09/2023 09:32 AM
548	IEC 61850 User Feedback Task Force	Support	29	IOP_2017/50	Resolved	Normal	IEC 61850-9-3	The start-up behaviour of Boundary Clocks	05/09/2023 09:32 AM
549	IEC 61850 User Feedback Task Force	Support	30	IOP_2017/51	Resolved	Normal	IEC 61850-9-3	Standard should clarify the relation between the PTP clock clockQuality signals and the timeQuality in TimeStamp	05/09/2023 09:32 AM
550	IEC 61850 User Feedback Task Force	Support	31	IOP_2017/52	Resolved	Normal	IEC 61850-9-3	Incorrect variance adjustment for Time Masters with degradation (loss of GPS)	05/09/2023 09:32 AM
551	IEC 61850 User Feedback Task Force	Support	32	IOP_2017/53	Resolved	Normal	IEC 61850-9-3	IEC/IEEE 61850-9-3 - Sync messages have to be padded to the same length as the Pdelay_Req/Pdelay_Resp messages	05/09/2023 09:32 AM
552	IEC 61850 User Feedback Task Force	Support	33	IOP_2017/54	Resolved	Normal	IEC 61850-9-3	Disruption of network when TC are not set to the correct domain	05/09/2023 09:32 AM
547	IEC 61850 User Feedback Task Force	Support	28	IOP_2017/49	Resolved	Normal	IEC 61850-9-3	Requirement for Boundary Clocks to adjust the clock accuracy to reflect their actual accuracy, not that of their grandmaster	05/09/2023 09:32 AM
525	IEC 61850 User Feedback Task Force	Support	6	IOP_2017/8	Resolved	Normal	IEC 61850-6	IEC 61850-6 does not allow the authentication configuration (none, password, weak, strong or certificate) to be used for Client	05/09/2023 09:32 AM
6323	SCL Tooling	Issues			Resolved	Normal		tTf5 IED name=None is not allowed tissue #1365	05/02/2023 08:20 AM
6200	SCL Tooling	Issues			Resolved	Normal		tTf1 change Ed2/2007B to Ed2.1/2007B4	01/24/2023 08:33 AM
6172	Client	Issues			Resolved	Normal		client check bits must be tested	12/13/2022 08:34 AM
5926	SCL Tooling	Issues			Resolved	Normal		Review ICT TP	11/29/2022 07:23 AM
5347	Server	Issues			Resolved	Normal		How should time correlated GOOSE change status in GOOSE Performance test	10/04/2022 09:11 AM
5921	General Testing Issues	Improvement			Resolved	Normal		Start using Vendor and Lab Submission Information	09/06/2022 09:33 AM
5120	SCL Tooling	Issues			Resolved	Normal		LGOS/LSVS reference with functional naming (SCL)	08/09/2022 08:40 AM
5327	Client	Issues			Resolved	Normal		PIXIT - add processing/mapping of quality bits	06/28/2022 09:44 AM

#	Project	Tracker	ID	Source	Status	Priority	Standard(s)	Subject	Updated
3115	Client	Issues			Resolved	Normal		Forward compatibility to Amd1 server with pre-assigned URCB/BRCB	06/14/2022 08:35 AM
748	Server	Issues			Resolved	Normal		sGos9 use SPS when INS subscribe is not supported	07/27/2021 10:07 AM
658	Client	Issues			Resolved	Normal		Verify Client does process a report before RptEna write respond+	06/01/2021 08:23 AM
636	Client	Issues			Resolved	High		Mandate RCB reservation for Ed2.0 client and Amd1 server	04/20/2021 02:23 PM
6653	Server	Issues			Rejected	Normal		sFt2c does deletable means everything else is not deletable	01/09/2024 08:19 AM
6622	IEC 61850 TPWG	Bug			Rejected	Normal		Test case Ttf1 (mustUnderstand) for the ICT conformance test needs clarification	12/12/2023 08:19 AM
5265	WG14 Part 6 Issues	CIM Issues			Rejected	Normal	61968-7, 61968-6	DesignLocation association to WorkTask	11/16/2023 11:51 AM
6565	Server	Issues			Rejected	Normal		Added more precise qualifications to TmSrcTyp - 1883	11/14/2023 09:03 AM
6590	Server	Issues			Rejected	Normal		sGopN2 - The clear meaning of too large a dataset	11/14/2023 08:58 AM
6589	Server	Issues			Rejected	Normal		Create DataSets with Multiple Clients (for example, sDsN4)	11/14/2023 08:48 AM
6591	Server	Issues			Rejected	Normal		sSg11 - Non-volatile property test (for various FCs)	11/14/2023 08:38 AM
6568	Server	Issues			Rejected	Normal		The definition of LTMS.TmSrc is different in the actual AMD1 and Consolidated Version - 1846	11/14/2023 08:37 AM
6520	SCL Tooling	Issues			Rejected	Normal		ICT Ed2.1 refers to TICS but there no part 6 tissues	10/31/2023 08:35 AM
5268	WG14 Part 6 Issues	CIM Issues			Rejected	Low	61968-6	Add rank as attribute to WorkOrder	10/17/2023 03:21 AM
5246	WG14 Issues	CIM Issues			Rejected	High		Object status	10/17/2023 02:45 AM
5269	WG14 Part 6 Issues	CIM Issues			Rejected	Normal	61968-6	Status attributes in WorkOrder	10/16/2023 03:17 PM
6472	Server	Issues			Rejected	Normal		Concept of smpRate for input analogue signal acquisition is misleading (Tissue 1857)	08/22/2023 08:22 AM
6466	Server	Issues			Rejected	Normal		TP1.2 sSvs1 step 6 shall be removed	07/11/2023 08:33 AM
6365	Server	Issues			Rejected	Normal		Considering PTP version 2.1	07/11/2023 08:12 AM
6324	SCL Tooling	Issues			Rejected	Normal		sCnf6 - not all extRef require intAddr not referring to external device	05/16/2023 08:44 AM
6208	Server	Issues			Rejected	Normal		sSvsN2 in TP1.2 does not check the situation where the DUT checks ConfRev	03/21/2023 08:20 AM

#	Project	Tracker	ID	Source	Status	Priority	Standard(s)	Subject	Updated
6174	Server	Issues			Rejected	Normal		Amend sCtl7 to test both interlocking check and check synchronizing ?	02/07/2023 08:24 AM
653	Server	Issues			Rejected	Low		Subscriber can use maximum number of dataset elements	01/24/2023 09:03 AM
654	Server	Issues			Rejected	Low		Publish/subscribe minimum length data GOOSE	01/24/2023 09:02 AM
651	Server	Issues			Rejected	Low		Verify subscriber can accept maximum size GOOSE	01/24/2023 08:40 AM

...