

Issues

#	Project	Tracker	ID	Source	Status	Priority	Standard(s)	Subject	Updated
6770	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		EdgeHub DataWorX	04/24/2024 02:00 PM
6769	Server	Issues			New	Normal		sGop9 should allow NdsCom to be set	04/23/2024 07:19 AM
6768	61850-7-5 and 61850-7-500	IEC61850-7-5			New	Normal		Control of substituted or blocked objects	04/19/2024 05:08 AM
6767	IEC 61850 User Feedback Task Force	Bug			New	Normal		Specifying virtualized physical devices and LN's	04/17/2024 10:45 AM
6766	WG16 Issues	CIM Issues			In Progress	Normal		ResourceCertification attribute type is generic and could be renamed to a more describe attribute name	04/18/2024 10:37 AM
6765	WG16 Issues	CIM Issues			In Progress	Normal		ResourceCertification.type - update the description to describe the usage of the attribute "type"	04/18/2024 10:25 AM
6764	WG16 Issues	CIM Issues			In Progress	Normal		ResourceCertification.qualificationFlag description is incorrect	04/18/2024 10:40 AM
6763	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		ETOPD1000	04/15/2024 07:33 AM
6762	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		YH-HSA-ICD	04/25/2024 07:23 AM
6761	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		YH-HSA-ICD	04/25/2024 07:22 AM
6760	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		SEL-751 and SEL-787L (Variant)	04/15/2024 06:52 AM
6759	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		PCM600	04/15/2024 06:45 AM
6758	WG13 Issues	CIM Issues			New	High		Measurement issues	04/13/2024 12:42 AM
6757	WG13 Issues	CIM Issues			New	High		BasicIntervalSchedule and RegularIntervalSchedule	04/17/2024 11:31 AM
6755	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		Multilin N60	04/07/2024 11:11 AM
6754	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		N60	04/07/2024 11:06 AM
6753	Server	Issues			In Progress	Normal		sGos20, sGos21 force DUT as Subscriber to ignore future edition dataset elements, while 61850-7-1 expects achievable forward compatibility	04/16/2024 08:45 AM
6752	WG14 Part 5 Issues	CIM Issues			New	High		Deprecate Part 5 Modelling	04/02/2024 10:49 AM
6751	IEC 61850 TPWG	Issues			Resolved	Normal		Update IEC 61850 QAP Addendum for adding requirement quickly	04/16/2024 08:16 AM
6750	Server	Issues			Resolved	High		sAddr length - TISSUE 1885	04/16/2024 08:17 AM
6749	Server	Issues			Resolved	High		Clarification of ExtRef attributes usage - TISSUE 1818	04/16/2024 08:31 AM

#	Project	Tracker	ID	Source	Status	Priority	Standard(s)	Subject	Updated
6748	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		IED1-E11D1	03/29/2024 09:16 AM
6747	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		WAGO 750-8212/0040-0001	03/29/2024 09:06 AM
6746	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		DW61850CLIENT	03/29/2024 09:07 AM
6745	WG16 Issues	CIM Issues			Open	High		Need for consistent approach for Market Products	04/18/2024 10:41 AM
6744	WG14 Part 3 Issues	CIM Issues			New	Normal	61968-3	CrewStatusKind enumeration is missing values for deassignment	03/26/2024 11:59 AM
6742	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		V321 Arc Flash Protection System	03/24/2024 02:16 PM
6741	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		SA-G3000	03/24/2024 02:10 PM
6740	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		ALARM ANNUNCIATOR MBAS 0600	03/24/2024 01:50 PM
6739	IEC 61850 User Feedback Task Force	Feature			In Progress	Normal		How to deal with 'Beh' and 'Health' of isolated functions	04/09/2024 08:43 AM
6738	IEC 61850 User Feedback Task Force	Improvement			Resolved	Normal		Amending TGSN LN class with settings for adapting the signal	04/09/2024 08:19 AM
6737	IEC 61850 User Feedback Task Force	Improvement			Resolved	Normal	IEC 61850-90-29	Amending TGSN LN class with signal characteristics	04/09/2024 08:10 AM
6736	WG13 Issues	CIM Issues			New	Normal	IEC 61970-301	Quality61850 Class does not match the definition of Quality in IEC 61850-7-2	03/12/2024 04:05 PM
6735	WG16 Issues	CIM Issues			New	Normal		new disclaimer note on every Inf* UML diagram indicating to "use at your own risk"	03/11/2024 02:54 PM
6734	WG16 Issues	CIM Issues			New	Normal		Review use/inheritance of Document by UCA TF 16 classes, profile, standards	03/11/2024 09:58 AM
6733	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		ETLID1000	03/11/2024 08:38 AM
6732	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		ETMDU1000	03/11/2024 08:39 AM
6731	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		Micom P40 Agile 5th Generation P84	03/11/2024 08:24 AM
6730	CIM Joint Issues	CIM Issues			New	Normal		Evaluation of the Pipeline Open Data Standard (PODS)	03/07/2024 11:09 AM
6729	CIM Joint Issues	CIM Issues			New	Normal		Multi-commodity Support	03/07/2024 11:10 AM
6728	Client	Issues			In Progress	Normal		cSg13 refers to PIXIT entry Sg5/Sg6 but not clarified in the expected result	04/16/2024 08:35 AM
6727	Client	Issues			Resolved	Normal		cDsN1bc, cFtN2 have no non-Ed2 specific error code	04/02/2024 08:42 AM

#	Project	Tracker	ID	Source	Status	Priority	Standard(s)	Subject	Updated
6726	61850-7-5 and 61850-7-500	IEC61850-7-5		RTE	In Progress	Normal		New LN of group L (as "LTED") to represent the dynamic topology of the substation.	02/29/2024 09:07 AM
6725	61850-7-5 and 61850-7-500	IEC61850-7-5		RTE	In Progress	Normal		Simultaneous change of InRef.setSrcRef and InRef.setSrcCB for dynamic commutation	02/29/2024 09:07 AM
6724	Client	Issues			In Progress	Normal		GOOSE Subscriber sGos12 test expects DUT to _send_ a GOOSE message	04/16/2024 08:42 AM
6723	Server	Issues			In Progress	Normal		GOOSE destination MAC address according Amd1: PIXIT Gs1 mismatches enhancement of sGos5	04/16/2024 08:41 AM
6722	Server	Issues			New	Normal		sGop10 PIXIT reference needed ?	04/17/2024 05:02 AM
6721	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		SPiN-MDAS	02/24/2024 11:09 AM
6720	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		SPiN-CNAS	02/24/2024 11:10 AM
6719	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		SPiN-CNAS	02/24/2024 11:11 AM
6718	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		SPiN-CMAS	02/24/2024 10:52 AM
6717	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		PowerLogic™ P5F30 protection relays	02/24/2024 10:42 AM
6716	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		ETR600-T	02/24/2024 10:35 AM
6715	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		ETR600-BC	02/24/2024 10:29 AM
6714	IEC TC57 WG10 Future Work	WG10 Future Work		IEC PAS 61850-90-3	New	Normal		Improve the models used for power regulation	02/20/2024 11:04 AM
6713	WG13 Issues	CIM Issues			New	Normal		Update namespace and profile from http to https	02/18/2024 08:35 AM
6712	WG13 Issues	CIM Issues			Review	Normal		UML descriptions for <<Primitive>> types in the Domain package need review and references to W3C and other standards migration into IS publications.	02/28/2024 10:27 AM
6711	61850-7-5 and 61850-7-500	IEC61850-7-5		WG10 Fall workshop	In Progress	Low		SCL Modelling of Fault Measurements (RFMX)	02/29/2024 08:33 AM
6710	Server	Issues			Resolved	Normal		sSrv13 does not specify that the lower hierarchy Mod.stVal shall not change	04/02/2024 02:42 PM
6709	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		DRTS 66L	02/13/2024 10:10 AM
6708	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		DRTS 66L	02/13/2024 10:09 AM
6707	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		SLP-K140	02/11/2024 10:55 AM

#	Project	Tracker	ID	Source	Status	Priority	Standard(s)	Subject	Updated
6706	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		STP-K120	02/10/2024 11:35 AM
6705	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		VIPAMj3500II-TR	02/10/2024 10:43 AM
6704	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		VIPAM3500plusFM	02/10/2024 10:38 AM
6703	IEC TC57 WG10 Future Work	WG10 Future Work		Ed 3 review	New	Normal	IEC 61850-7-4, IEC TS 61850-80-4	Part 80-4 Mapping to COSEM : add reactive and apparent energy data objects to MMTR and MMTN	02/09/2024 02:43 PM
6702	WG13 Issues	CIM Issues			Open	Normal	61970-301	Grid Package: PhaselmpedanceData to support electrical parameters templates	02/08/2024 10:23 AM
6701	IEC TC57 WG10 Future Work	WG10 Future Work			New	Normal	IEC 61850-7-3	Integration of proposed and canceled amendment 2 of part 7-3	02/08/2024 05:25 AM
6700	IEC TC57 WG10 Future Work	WG10 Future Work			New	Normal	IEC 61850-6	Investigate to align to the new CIM model of transformers	02/08/2024 05:26 AM
6699	61850-7-5 and 61850-7-500	IEC61850-7-5			New	Normal		Behavior of a function while being dynamically blocked	02/07/2024 04:55 AM
6698	61850-7-5 and 61850-7-500	IEC61850-7-5			New	Normal		Integrate work from AHTF Control Between Functions	02/07/2024 02:29 AM
6697	Server	Issues			Resolved	Normal		sRpN9 does not specify the expected access error by negative response on SetURCBValues	04/02/2024 08:40 AM
6696	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		REX610	02/05/2024 07:49 AM
6695	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		PCS-221S Merging Unit	02/05/2024 06:50 AM
6694	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		PCS-902S Line Distance Relay	02/05/2024 08:53 AM
6692	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		PowerLogic™ P3	02/03/2024 11:00 AM
6691	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		PowerLogic™ P3U30	02/03/2024 10:55 AM
6690	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		PCS-9710S Remote Terminal Unit	02/03/2024 10:49 AM
6689	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		PowerLogic™ P3	02/03/2024 10:19 AM
6688	Client	Issues			Resolved	Normal		cSrvN10 - Ed1 specific error codes do not exist for MMS GetNameList	04/02/2024 08:42 AM
6687	61850-7-5 and 61850-7-500	IEC61850-7-5		SEL	Waiting for Release	Normal		Incorrect signal direction for GOOSE messages between CSWI and XCBR	02/29/2024 08:10 AM
6686	61850-7-5 and 61850-7-500	IEC61850-7-5		Tissue #1892	New	Normal		Description of the different control methods to change position of OLTC (in automatic, manual modes)	01/23/2024 11:02 AM

#	Project	Tracker	ID	Source	Status	Priority	Standard(s)	Subject	Updated
6685	GOOSE Performance	Issues			In Progress	Normal		Device need to be certified for Ed2.1 server first	04/16/2024 08:43 AM
6684	61850-7-5 and 61850-7-500	IEC61850-7-5		discussion	New	Normal		Proposal to deprecate 'LocSta' in X and Y group LN classes	01/22/2024 02:50 AM
6683	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		Prometer 540	01/21/2024 11:03 AM
6682	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		NS3560	01/22/2024 07:08 AM
6681	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		NSR-385AG	01/21/2024 10:50 AM
6680	WG13 Issues	CIM Issues			New	High	61970-456	Support time series/schedule for SSH	01/17/2024 10:19 AM
6679	WG14 Part 11 Issues	CIM Issues			New	Normal		Document class description	01/16/2024 11:54 AM
6678	WG14 Part 11 Issues	CIM Issues			New	Normal		Refactoring Outage Class Modeling	01/16/2024 11:45 AM
6677	CIM Joint Issues	CIM Issues			New	Normal	IEC61968-11 Edition 4, IEC62325-301 Edition 4	Document Class Generalization Refinement	02/08/2024 10:33 AM
6676	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		P841 (GE MiCOM Agile P841)	01/13/2024 08:37 AM
6675	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		Prometer 100	01/13/2024 08:27 AM
6673	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		G-ISD	01/08/2024 09:12 AM
6672	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		Apex 540	01/08/2024 08:48 AM
6671	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		DRTS 66L Test SEt	01/08/2024 10:35 AM
6670	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		DRTS 66L Test Set	01/08/2024 10:36 AM
6669	Market Management	CIM Issues			New	Normal		Add VATLevel attribute to ChargeType	01/05/2024 09:17 AM
6668	Market Management	CIM Issues			New	Normal		Add VATObligated attribute to ChargeType	01/05/2024 09:03 AM
6667	Market Management	CIM Issues			New	Normal		Add an association from ChargeType to Period	01/05/2024 07:58 AM
6666	Market Management	CIM Issues			New	Normal		Add PhaseCount to ESMP	01/05/2024 07:27 AM
6665	Market Management	CIM Issues			New	Normal		Add ChargeGroup to ESMP and move ChargeGroup to MarketCommon	01/05/2024 07:08 AM
6664	Market Management	CIM Issues			New	Normal		Add an association from MktActivityRecord to ChargeGroup	01/05/2024 06:44 AM
6663	WG13 Issues	CIM Issues			Open	High	IEC 61970-456	The SSH profile needs to be revisited and updated for consistency.	02/04/2024 12:14 AM
6662	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		PowerLogicTM P7	12/28/2023 08:44 AM

#	Project	Tracker	ID	Source	Status	Priority	Standard(s)	Subject	Updated
6661	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		REX615	12/28/2023 08:38 AM
6660	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		PSF640 Feeder Protection and Control	12/28/2023 08:10 PM
6659	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		CSI-200E-ER	12/28/2023 08:15 AM
6656	CIM Joint Issues	CIM Issues			New	Normal		Add altitudeCompensation to EndDeviceInfo	12/21/2023 10:20 AM
6655	Client	Issues			Resolved	Normal		cLogN5 is missing in table A4.2 and certificate template	01/09/2024 08:28 AM
6654	Client	Issues			Resolved	Normal		Tracking numbering mismatch Ed2 <> Ed2.1	01/09/2024 08:27 AM
6653	Server	Issues			Rejected	Normal		sFt2c does deletable means everything else is not deletable	01/09/2024 08:19 AM
6649	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		HGMAP-BCS	12/16/2023 10:49 AM
6648	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		DCAP-6701	12/16/2023 10:45 AM
6647	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		DCAP-6701	12/16/2023 10:32 AM
6646	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		SPiN-IMCU	12/16/2023 09:27 AM
6645	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		F8300	12/16/2023 09:21 AM
6644	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		DCAP-6701	12/13/2023 09:13 AM
6643	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		AXC F 2152	12/13/2023 08:42 AM
6642	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		AXC F 3152	12/13/2023 08:37 AM
6641	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		Arkens PR Line L301	12/13/2023 08:26 AM
6640	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		ECU-4784	12/13/2023 07:59 AM
6639	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		ECU-4784	12/13/2023 07:55 AM
6638	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		HP-Z8-G4	12/13/2023 07:48 AM
6637	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		PCM600	01/21/2024 10:44 AM
6636	WG14 Issues	CIM Issues			New	Normal	61968-3;61968-4;61968-5;61968-6	Update Name model for all XSD based profiles	12/13/2023 07:27 AM
6634	WG13 Issues	CIM Issues			New	Normal	61970-301; 61970-452	Simplify Name model using enum	12/13/2023 07:58 AM

#	Project	Tracker	ID	Source	Status	Priority	Standard(s)	Subject	Updated
6632	WG13 Issues	CIM Issues			New	Normal	61970-301	update definition of deprecated	03/11/2024 03:56 PM
6631	SCL Tooling	Issues			Resolved	Normal		tTf1 (mustUnderstand) for the ICT test needs clarification	01/09/2024 08:59 AM
6630	WG13 Issues	CIM Issues			New	Normal	61970-301	Update Identity and naming description	12/11/2023 04:43 AM
6629	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		T-MU MERGING UNIT - IED	12/09/2023 11:47 AM
6628	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		EnOSTM Monitoring & Control	12/09/2023 11:22 AM
6627	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		CSC-285 - Multifunction Voltage Protection IED	12/09/2023 11:14 AM
6626	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		CSC-283 - Motor Protection IED	01/08/2024 08:34 AM
6625	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		CSC-281 Multifunction Feeder Protection LED	12/09/2023 11:10 AM
6624	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		CDP0100	12/09/2023 11:02 AM
6623	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		CPD0100	12/09/2023 11:03 AM
6622	IEC 61850 TPWG	Bug			Rejected	Normal		Test case Ttf1 (mustUnderstand) for the ICT conformance test needs clarification	12/12/2023 08:19 AM
6621	WG14 Issues	CIM Issues			Review	High		Add the Design sub-package to the Enterprise package	12/05/2023 01:41 PM
6620	WG14 Issues	CIM Issues			New	High		Enterprise Package Name Related Model Updates	12/05/2023 01:07 PM
6619	CIM Joint Issues	CIM Issues			New	High	IEC61968-3 thru IEC61968-11, IEC61970-301, IEC62325-301	Renaming the CIM UML Model Packages	12/05/2023 12:37 PM
6617	SCL Tooling	Issues			Resolved	Normal		tlieN1 - can a popup warning be considered as 'not allowed'	12/12/2023 08:58 AM
6616	WG13 Issues	CIM Issues			New	Normal	61970-301; 61970-452	Add SubstationKind	03/11/2024 06:57 AM
6613	IEC TC57 WG10 Future Work	WG10 Future Work		TissueDB	New	Normal	IEC 61850-6	IEC61850 Tissue 1833: Service SettingGroups.ConfSG clarification	02/08/2024 01:38 AM
6611	WG14 Part 9 Issues	CIM Issues			New	Normal	61968-9	Formulaic UOMs	11/27/2023 07:09 PM
6610	WG13 Issues	CIM Issues			New	High	61970-301; 61970-452	Multiple issue Measurement and Control	11/27/2023 10:27 AM
6607	61850-7-5 and 61850-7-500	IEC61850-7-5		RTE	New	Normal		Create DO indicating the source of synchronisation	11/21/2023 08:49 AM
6606	61850-7-5 and 61850-7-500	IEC61850-7-5		RTE	New	Normal		CPU monitoring	11/21/2023 08:40 AM
6605	IEC 61850 User Feedback Task Force	Support		RTE	Resolved	Normal	TR IEC 61850-7-500	Identification of three phase trip with ACT DO	11/21/2023 08:13 AM
6604	IEC TC57 WG10 Future Work	WG10 Future Work		TissueDB	New	Normal	IEC 61850-7-4	IEC61850.Tissue #1754 Event driven schedules - Type of InSyn missing	02/08/2024 01:42 AM

#	Project	Tracker	ID	Source	Status	Priority	Standard(s)	Subject	Updated
6603	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		BCU 500	02/05/2024 08:52 AM
6602	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		GIPAM1000	11/22/2023 07:33 AM
6601	WG14 Part 11 Issues	CIM Issues			New	Normal	61968-Common	Revise TimeSchedule class	11/16/2023 11:46 AM
6600	WG14 Part 9 Issues	CIM Issues			New	Normal	61968-9	Multipliers	11/16/2023 11:33 AM
6597	CIM Joint Issues	CIM Issues			New	Normal		MarketManagement::Quantity has attribute and relation with the same name "quantity"	11/14/2023 08:00 AM
6596	IEC 61850 User Feedback Task Force	Bug			Resolved	Normal		Simulation Mode with Centralized Protection	11/21/2023 08:32 AM
6594	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		YH-HSA-OPD	11/09/2023 07:23 AM
6593	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		YH-HSA-LID	11/09/2023 07:16 AM
6592	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		ZEN-LS002	11/09/2023 07:16 AM
6591	Server	Issues			Rejected	Normal		sSg11 - Non-volatile property test (for various FCs)	11/14/2023 08:38 AM
6590	Server	Issues			Rejected	Normal		sGopN2 - The clear meaning of too large a dataset	11/14/2023 08:58 AM
6589	Server	Issues			Rejected	Normal		Create DataSets with Multiple Clients (for example, sDsN4)	11/14/2023 08:48 AM
6588	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		ECU-4784	11/08/2023 07:11 PM
6587	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		ECU-4784	11/08/2023 07:06 PM
6586	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		HP-Z8-G4	11/08/2023 07:07 PM
6585	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		DW-SPiN-LID	11/08/2023 08:32 AM
6584	CIM Joint Issues	CIM Issues			New	High		Handling unit multiplier needs joint WG consensus on approach	11/08/2023 07:03 AM
6583	WG14 Part 4 Issues	CIM Issues			New	Normal		Inheritance of Tower and Pole	11/07/2023 02:05 PM
6582	WG14 Part 4 Issues	CIM Issues			New	Normal		May need to add "kind" attribute to OverheadStructure to be consistent with UndergroundStructure.kind	11/07/2023 02:04 PM
6579	IEC TC57 WG10 Future Work	WG10 Future Work		Vattenfall	New	High	IEC 61850-6	How to add utility process name to DOs	02/19/2024 10:43 AM
6578	IEC TC57 WG10 Future Work	WG10 Future Work		TF 61850-80-6	New	Normal	IEC 61850-7-2; IEC 61850-8-1, 80-6	Extension of the AddCause required to reflect communication issues in multi level control	02/08/2024 01:50 AM
6577	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		P14DL	11/07/2023 06:34 AM

#	Project	Tracker	ID	Source	Status	Priority	Standard(s)	Subject	Updated
6576	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		ZEN-WT001	11/03/2023 06:14 PM
6575	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		ZEN-LS001	11/03/2023 06:15 PM
6574	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		WTG001 Hardware Server	11/03/2023 12:59 PM
6573	CIM Joint Issues	CIM Issues			New	Normal		Profile class duplicates	11/03/2023 03:34 AM
6572	WG14 Part 11 Issues	CIM Issues			New	Normal		IEC61968CIMVersion class is in triplicate	11/02/2023 04:07 PM
6568	Server	Issues			Rejected	Normal		The definition of LTMS.TmSrc is different in the actual AMD1 and Consolidated Version - 1846	11/14/2023 08:37 AM
6565	Server	Issues			Rejected	Normal		Added more precise qualifications to TmSrcTyp - 1883	11/14/2023 09:03 AM
6562	61850-7-5 and 61850-7-500	IEC61850-7-5		Redmine: 6155	New	Normal		Missing LN for Miniature Circuit Breaker (MCB)	10/26/2023 05:17 AM
6561	IEC TC57 WG10 Future Work	WG10 Future Work			New	Normal	IEC 61850-7-4	Modeling of primary equipment	10/26/2023 04:20 AM
6560	61850-7-5 and 61850-7-500	IEC61850-7-5		Redmine: 6443	New	Normal		Multiple information sources	10/26/2023 04:02 AM
6559	61850-7-5 and 61850-7-500	IEC61850-7-5		Redmine: 6443	New	Normal		Modelling of a Lockout/trip seal-in relay	04/19/2024 09:19 AM
6558	61850-7-5 and 61850-7-500	IEC61850-7-5		Redmine: 6443	New	Normal		How to model composed functions	10/26/2023 04:01 AM
6557	61850-7-5 and 61850-7-500	IEC61850-7-5		Redmine: 6443	New	Normal		Modelling of various MCB trips	10/26/2023 04:00 AM
6556	61850-7-5 and 61850-7-500	IEC61850-7-5		Redmine: 6443	New	Normal		How to impact the data quality of a data with respect to the communication links, the intermediate processing, the device hosting it.	10/26/2023 04:00 AM
6555	61850-7-5 and 61850-7-500	IEC61850-7-5			New	Normal		Behaviour of output contacts when LN is in blocked mode	02/07/2024 03:14 AM
6554	61850-7-5 and 61850-7-500	IEC61850-7-5			Waiting for Release	Normal		SwModKey seems to overwrite the CheckCondition.interlockCheck	02/29/2024 07:52 AM
6553	WG13 Issues	CIM Issues			New	High		Removal of InfGrid package InfSIPS	11/15/2023 10:48 AM
6552	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		P14DZ	10/25/2023 09:42 AM
6551	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		STC-K120	10/25/2023 09:23 AM
6550	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		VIPAM7000	10/25/2023 09:16 AM
6549	WG14 Part 9 Issues	CIM Issues			New	High	61968-3, 61968-5, 61968-9	Switch Contention Issue	03/07/2024 10:38 AM

#	Project	Tracker	ID	Source	Status	Priority	Standard(s)	Subject	Updated
6545	61850-7-5 and 61850-7-500	IEC61850-7-5		TC92 WG2	Waiting for Release	Normal		Propagation of detailQual	02/29/2024 07:17 AM
6544	WG14 Part 9 Issues	CIM Issues			New	Normal	61968-9, 61968-4	Meter Asset Accuracy Class	11/16/2023 11:17 AM
6543	WG14 Part 9 Issues	CIM Issues			New	Normal	IEC 61968-9 and others	AccuracyClass for sensors	10/19/2023 09:43 AM
6542	WG14 Part 9 Issues	CIM Issues			New	Normal	61968-9 and 61968-5	Group Management	10/19/2023 08:48 AM
6540	WG14 Part 11 Issues	CIM Issues			Review	Normal		Class names for ElectronicAddress and TelephoneNumber	10/17/2023 04:35 AM
6539	WG14 Part 6 Issues	CIM Issues			Review	Normal	61968-6, 61968-Common	Crew type identification	10/17/2023 04:33 AM
6538	WG14 Part 6 Issues	CIM Issues			Review	Normal	61968-6, 61968-Common	CrewMember Inheritance	10/17/2023 04:32 AM
6537	61850-7-5 and 61850-7-500	IEC61850-7-5			New	Normal		Harmonizing expressions in 7-500 Ed.1	10/06/2023 08:13 AM
6536	Market Management	CIM Issues			New	Normal		Add an association from ChargeType to MarketParticipant	09/28/2023 10:17 AM
6535	Market Management	CIM Issues			New	Normal		Add ChargeComponent to IEC 62325-351	09/28/2023 10:58 AM
6534	Market Management	CIM Issues			New	Normal		Add an association from Series to ChargeType	12/19/2023 10:32 AM
6533	Market Management	CIM Issues			New	Normal		Add ChargeType to IEC 62325-351	09/28/2023 10:56 AM
6532	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		ZEN-WT001	09/26/2023 09:38 AM
6531	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		Superconductivity IED ZEN-LS001	09/26/2023 09:33 AM
6530	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		Easergy MiCOM P746 Numerical Busbar Protection	09/26/2023 08:36 AM
6529	WG14 Part 9 Issues	CIM Issues			New	Normal	61968-9	Load Control Capabilities	10/19/2023 08:32 AM
6528	WG13 Issues	CIM Issues			New	Normal	61968-13	Evaluate information provided by IntraphaseSpacing class	09/20/2023 01:04 PM
6524	IEC TC57 WG10 Future Work	WG10 Future Work			New	Normal	IEC 61850-7-4	https://iec61850.tissue-db.com/tissue/670 - enable/disable LN via setting / new DO SetMod	10/26/2023 03:54 AM
6522	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		SEL-851	09/12/2023 02:41 PM
6521	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		PGC-6060	09/12/2023 02:33 PM
6520	SCL Tooling	Issues			Rejected	Normal		ICT Ed2.1 refers to TICS but there no part 6 tissues	10/31/2023 08:35 AM
6516	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		IM2	09/05/2023 07:49 AM
6515	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		PSF640 Feeder Protection and Control	09/03/2023 03:56 PM
6514	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		ET-CCI	09/03/2023 03:46 PM
6513	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		PowerLogic(TM) P7	09/03/2023 03:39 PM

#	Project	Tracker	ID	Source	Status	Priority	Standard(s)	Subject	Updated
6512	WG14 Part 9 Issues	CIM Issues			New	Normal	61968-9	Support measurements of configuration status	09/21/2023 03:05 PM
6511	WG14 Part 9 Issues	CIM Issues			New	Normal	61968-9	Support gas metering with additional event codes and measurements	08/29/2023 03:29 PM
6510	Market Management	CIM Issues			New	Normal		Add an association between MarketEvaluationPoint and MktPSRType	08/21/2023 10:11 AM
6509	WG14 Part 4 Issues	CIM Issues			Open	Normal		WorkAsset, Vehicle, Tool	10/14/2023 10:43 AM
6508	WG14 Part 9 Issues	CIM Issues			New	Normal	61968-9	Support the means to identify the accuracy of the measurement in <MeterReadings>	10/19/2023 11:28 AM
6507	WG14 Part 9 Issues	CIM Issues			New	Normal	61968-9	Support IoT sensors by adding durations of time in the seconds range.	09/21/2023 02:11 PM
6506	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		SOC-K110	08/23/2023 06:54 AM
6505	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		ETR500-FV	08/16/2023 10:56 AM
6504	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		SBP-K110	08/16/2023 10:57 AM
6503	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		BCU-50-M	08/15/2023 02:26 PM
6502	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		Easergy MiCOM P443 Fast Multifunction Distance Protection Relay	08/03/2023 03:39 PM
6501	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		K-IED T100	08/03/2023 03:32 PM
6500	61850-7-5 and 61850-7-500	IEC61850-7-5			In Progress	Normal		Parameters to enforce the checking of interlocking and synchronism	10/05/2023 08:57 AM
6499	61850-7-5 and 61850-7-500	IEC61850-7-5			In Progress	Normal		Explanation text on the application of check conditions	10/05/2023 08:57 AM
6498	61850-7-5 and 61850-7-500	IEC61850-7-5			Waiting for Release	Normal		Explanation text on the usage of SwModKey	02/29/2024 07:52 AM
6497	61850-7-5 and 61850-7-500	IEC61850-7-5			New	Normal		Explanation text of IEC/TR 61850-7-500 clause 10.1.1.2	08/02/2023 10:43 AM
6496	61850-7-5 and 61850-7-500	IEC61850-7-5			New	Normal		Typo in section 13.3	08/02/2023 08:54 AM
6495	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		SEL-451-6	07/28/2023 12:45 PM
6494	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		SEL-451-5	07/28/2023 12:39 PM
6493	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		WAGO 750-8212/0040-0001	07/28/2023 12:31 PM
6492	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		PS700 v2 - FACTS Main Controller	07/28/2023 12:32 PM

#	Project	Tracker	ID	Source	Status	Priority	Standard(s)	Subject	Updated
6490	Client	Issues			Resolved	Normal		UCAiug requires Ed2Amd1 Jan 2024 - expect testlabs/toolvendors need more time	08/22/2023 08:16 AM
6489	GOOSE Performance	Issues			Resolved	Normal		Reducing the needed resources for time correlated subscribed GOOSE not used for ping-pong	01/23/2024 08:05 AM
6488	GOOSE Performance	Issues			Resolved	Low		Incorrect reference	09/05/2023 08:08 AM
6487	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		Protection IED (SUF-K110)	07/26/2023 10:56 AM
6486	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		ECU-4784	07/26/2023 10:35 AM
6485	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		ECU-4784	07/26/2023 10:25 AM
6484	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		xGrids Transfer DAUMIT_ISD	07/26/2023 10:19 AM
6483	Server	Issues			Resolved	Normal		Need to be able to test 61850-7-420	09/05/2023 08:14 AM
6482	61850-7-5 and 61850-7-500	IEC61850-7-5			In Progress	Normal		Figures 36, 37, 38	09/14/2023 07:56 AM
6481	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		AXC F 3152	07/19/2023 07:30 AM
6480	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		SA IMD YSSMD-7300	07/19/2023 07:22 AM
6479	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		SA IMD DAONSYS MSA-SMD-ED2	07/19/2023 08:55 PM
6478	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		FTU-R200i	07/19/2023 07:08 AM
6477	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		YH-SAMDD	07/19/2023 07:08 AM
6475	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		SAM600 Process Interface Unit	07/11/2023 11:15 AM
6474	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		SAM600 Process Interface Unit	08/24/2023 11:31 AM
6472	Server	Issues			Rejected	Normal		Concept of smpRate for input analogue signal acquisition is misleading (Tissue 1857)	08/22/2023 08:22 AM
6471	Client	Issues			Resolved	Normal		Select.response+ (Tissue 1753)	08/22/2023 08:10 AM
6467	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		MRD-HB (101PYA) Biased differential relay	07/10/2023 03:38 PM
6466	Server	Issues			Rejected	Normal		TP1.2 sSvs1 step 6 shall be removed	07/11/2023 08:33 AM
6465	GOOSE Performance	Issues			Resolved	Normal		The Ed2 GOOSE performance also apply for Ed2Amd1	08/08/2023 08:42 AM
6464	Client	Issues			Resolved	Normal		cSrv5 change the condition to GetDataValues or Reporting	07/11/2023 08:38 AM
6463	Client	Issues			Resolved	Normal		cSrv7, cSvrN3 some clients only read DA (not DO)	07/25/2023 08:07 AM

#	Project	Tracker	ID	Source	Status	Priority	Standard(s)	Subject	Updated
6454	CIM Issues	CIM Issues			New	Normal	61970-301	RemoteUnit minor typo in 301 description	06/28/2023 04:27 PM
6452	WG13 Issues	CIM Issues			In Progress	Normal	61970-301,61970-452	Allow multiple RatioTapChanger on one TransformerEnd	03/12/2024 02:26 AM
6451	WG13 Issues	CIM Issues			In Progress	Normal	61970-452	Cardinality inconsistency for PowerElectronicsConnection<->PowerElectronicsUnit between canonical model and profile	02/14/2024 11:28 AM
6450	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		AXRTU62351CCI_UP-DM_DC_MC_UVR-P_Q_F-PMU-BMU-CU_MCE_DCM/ET-CCI	06/22/2023 08:44 AM
6449	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		SIPROTEC V4 7SJ80 Overcurrent protection	06/21/2023 10:15 AM
6448	IEC TC57 WG10 Future Work	WG10 Future Work		WG10 Fall workshop	New	Urgent	TR IEC 61850-7-5	GOOSE treatment as a command	02/08/2024 01:53 AM
6447	IEC TC57 WG10 Future Work	WG10 Future Work		WG10 Fall workshop	New	Low		Enhanced Quality Information for Measurements (accuracy classes, update periods, filter applied, algorithm applied, etc.)	02/08/2024 03:16 AM
6446	IEC TC57 WG10 Future Work	WG10 Future Work		WG10 Fall workshop	New	Low	TR IEC 61850-7-500	SCL Modelling of Fault Measurements (RFMX)	02/08/2024 02:12 AM
6441	IEC TC57 WG10 Future Work	WG10 Future Work		WG10 Fall workshop	New	Normal	TR IEC 61850-90-14	Extensions to "Z" Logical Nodes (e.g. ZBAT)	10/26/2023 04:10 AM
6439	IEC TC57 WG10 Future Work	WG10 Future Work		WG10 Fall workshop	New	High		Inter-substation GOOSE Naming convention (90-1)	10/26/2023 03:42 AM
6437	IEC TC57 WG10 Future Work	WG10 Future Work		WG10 Fall workshop	New	High	TR IEC 61850-7-5	Logical Device Inheritance Rules for LocSta	10/26/2023 03:43 AM
6436	IEC TC57 WG10 Future Work	WG10 Future Work		WG10 Fall workshop	New	Low	TR IEC 61850-10-3	SCL Modelling of the Test Equipment	02/08/2024 02:36 AM
6435	IEC TC57 WG10 Future Work	WG10 Future Work		WG10 Fall workshop	New	Low	IEC 61850-9-2	Compression of Sample Value Messages	02/08/2024 05:36 AM
6433	IEC TC57 WG10 Future Work	WG10 Future Work		WG10 Fall workshop	New	Low		SCL Extensions (partial configuration updates in a top-down approach, mixed editions with private CDCs, etc.)	02/08/2024 03:03 AM
6432	IEC TC57 WG10 Future Work	WG10 Future Work		WG10 Fall workshop	New	Normal	TR IEC 61850-90-30	SCL Engineering Lifecycle, Types and Security for SCL files and Elements	10/26/2023 04:26 AM
6430	IEC TC57 WG10 Future Work	WG10 Future Work		WG10 Fall workshop	New	Low	IEC 61850-6	Management of SCL File Sizes (Compression Techniques, Handling of Privates)	02/08/2024 03:17 AM
6429	IEC TC57 WG10 Future Work	WG10 Future Work		WG10 Fall workshop	New	Normal	IEC 61850-7-4xx	Logical Node Groups with Dedicated Namespaces	10/26/2023 04:28 AM
6428	IEC TC57 WG10 Future Work	WG10 Future Work		WG10 Fall workshop	New	Urgent	IEC 61850-6	Next Steps with IEC 61850-90-11 (Publish versus Corrigenda)	10/26/2023 02:47 AM
6427	IEC TC57 WG10 Future Work	WG10 Future Work		WG10 Fall workshop	New	Normal	TR IEC 61850-90-3	New Logical Nodes - Battery Charger	10/26/2023 04:31 AM
6423	IEC TC57 WG10 Future Work	WG10 Future Work		WG10 Fall workshop	New	Normal	TS IEC 61850-80-7	SCL Control Block	10/26/2023 04:32 AM

#	Project	Tracker	ID	Source	Status	Priority	Standard(s)	Subject	Updated
6422	IEC TC57 WG10 Future Work	WG10 Future Work		WG10 Fall workshop	New	Urgent	IEC 61850-7-4xx	Consistent Handling of Abbreviations for Data Object Names Within/Across All Domains and Namespaces	10/26/2023 02:52 AM
6420	IEC TC57 WG10 Future Work	WG10 Future Work		WG10 Fall workshop	In Progress	Urgent	IEC 61850-6, IEC 61850-7-x, IEC 61850-8-1, IEC 61850-9-2	Validation of SCL Files Using Object Constraint Language (OCL)	10/26/2023 02:57 AM
6419	IEC TC57 WG10 Future Work	WG10 Future Work		WG10 Fall workshop	New	Normal		Logical Nodes for SLD/Topology Aware Functions	02/09/2024 04:55 AM
6417	IEC TC57 WG10 Future Work	WG10 Future Work		WG10 Fall workshop	New	Normal	TR IEC 61850-90-4	SCL Modelling of the Communication Network and All its Components	10/26/2023 04:40 AM
6414	IEC TC57 WG10 Future Work	WG10 Future Work		WG10 Fall workshop	In Progress	Urgent		Golden Single Line Diagram For All SCL/GCL/HCL Examples	10/26/2023 02:58 AM
6413	IEC TC57 WG10 Future Work	WG10 Future Work		WG10 Fall workshop	New	Low	IEC 61850-80-7	Asset Management of Setting & Configuration Data	02/08/2024 05:32 AM
6412	IEC TC57 WG10 Future Work	WG10 Future Work		WG10 Fall workshop	New	Normal	IEC 61850-7-3	Improved SCL Modelling of Function Inputs (InRef/ExtRef)	10/26/2023 04:41 AM
6411	IEC TC57 WG10 Future Work	WG10 Future Work		WG10 Fall workshop	New	Urgent	TR IEC 61850-7-500, TR IEC 61850-90-3	Update the Model of Circuit Breaker/Disconnecter Switch	10/26/2023 03:08 AM
6410	IEC TC57 WG10 Future Work	WG10 Future Work		UCA Test. Committee	New	Normal	IEC 61850-7-2	SBOs to be deprecated in future.	10/26/2023 04:42 AM
6408	61850-7-5 and 61850-7-500	IEC61850-7-5			New	Normal		Clarification of addCause	06/20/2023 08:37 AM
6407	61850-7-5 and 61850-7-500	IEC61850-7-5			New	Normal		Schedules - allow 3 values per time point	06/20/2023 08:36 AM
6406	61850-7-5 and 61850-7-500	IEC61850-7-5			New	Normal		Schedules - add optional data objects to support irregular interval schedules	06/20/2023 08:36 AM
6405	61850-7-5 and 61850-7-500	IEC61850-7-5			New	Normal		Schedules - allow updates to single values while schedules are running	06/20/2023 08:35 AM
6395	61850-7-5 and 61850-7-500	IEC61850-7-5			Waiting for Release	Normal		Figure 15 SelOpn and SelCls are incorrect	02/29/2024 08:06 AM
6394	61850-7-5 and 61850-7-500	IEC61850-7-5			In Progress	Normal		Clarifications on the local/remote concept 8/8	09/14/2023 08:04 AM
6393	61850-7-5 and 61850-7-500	IEC61850-7-5			In Progress	Normal		Clarifications on the local/remote concept 7/8	10/05/2023 08:55 AM
6392	61850-7-5 and 61850-7-500	IEC61850-7-5			In Progress	Normal		Clarifications on the local/remote concept 6/8	10/05/2023 08:55 AM
6391	61850-7-5 and 61850-7-500	IEC61850-7-5			In Progress	Normal		Clarifications on the local/remote concept 5/8	10/05/2023 08:55 AM
6390	61850-7-5 and 61850-7-500	IEC61850-7-5			In Progress	Normal		Clarifications on the local/remote concept 4/8	10/05/2023 08:55 AM

#	Project	Tracker	ID	Source	Status	Priority	Standard(s)	Subject	Updated
6389	61850-7-5 and 61850-7-500	IEC61850-7-5			In Progress	Normal		Clarifications on the local/remote concept 3/8	10/05/2023 08:55 AM
6388	61850-7-5 and 61850-7-500	IEC61850-7-5			In Progress	Normal		Clarifications on the local/remote concept 2/8	10/05/2023 08:55 AM
6387	61850-7-5 and 61850-7-500	IEC61850-7-5			New	Normal		S/S related applications: Auxiliary circuit supervision	06/14/2023 08:20 AM
6386	61850-7-5 and 61850-7-500	IEC61850-7-5			New	Normal		Voltage protection: Overvoltage protection - 3ph operate	06/14/2023 08:20 AM
6385	61850-7-5 and 61850-7-500	IEC61850-7-5			New	Normal		Voltage protection: Undervoltage protection - 3ph operate	06/14/2023 08:19 AM
6384	61850-7-5 and 61850-7-500	IEC61850-7-5			New	Normal		New controllable DO in RREC to define the mode of the recloser of the circuit breaker	06/14/2023 08:19 AM
6383	61850-7-5 and 61850-7-500	IEC61850-7-5			New	Normal		Single phase and multi phase trip indication for the autorecloser	06/14/2023 08:19 AM
6382	61850-7-5 and 61850-7-500	IEC61850-7-5			New	Normal		Clarification on the ctlModel 1/3	06/14/2023 08:18 AM
6380	61850-7-5 and 61850-7-500	IEC61850-7-5			New	Normal		Clarification on the ctlModel 2/3	06/14/2023 08:18 AM
6379	61850-7-5 and 61850-7-500	IEC61850-7-5			New	Normal		Clarification on the ctlModel 3/3	06/14/2023 08:17 AM
6378	61850-7-5 and 61850-7-500	IEC61850-7-5			In Progress	Normal		Clarifications on the local/remote concept 1/8	10/05/2023 08:56 AM
6377	61850-7-5 and 61850-7-500	IEC61850-7-5			New	High		Update the Switchgear / Breaker Model	06/14/2023 08:17 AM
6376	61850-7-5 and 61850-7-500	IEC61850-7-5			New	Normal		LN PDIF – setting for nominal current	02/13/2024 05:59 AM
6375	61850-7-5 and 61850-7-500	IEC61850-7-5			In Progress	Normal		XCBR LN new DO to describe withdrawable circuit breaker	08/24/2023 07:57 AM
6374	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		Protection IED (K-IED BC100)	06/12/2023 09:58 AM
6373	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		Protection IED (K-IED V100)	06/12/2023 09:45 AM
6372	CIM Joint Issues	CIM Issues			New	High		Inconsistencies in Nameplate data for DERs	06/12/2023 08:18 AM
6370	IEC 61850 User Feedback Task Force	Improvement			Resolved	Normal		SBOs to be deprecated in future.	06/20/2023 09:39 AM
6369	WG14 Part 9 Issues	CIM Issues			New	Normal	61968-9	Support EVSE by adding new ReadingTypeID and EndDeviceEvent codes	10/24/2023 05:09 PM
6368	WG14 Part 9 Issues	CIM Issues			New	High	61968-9	The interplay between events and status measurements should be supported more cleanly	06/01/2023 11:03 AM
6367	WG14 Part 9 Issues	CIM Issues			New	Normal	61968-9	Prepay Metering	06/01/2023 08:51 AM

#	Project	Tracker	ID	Source	Status	Priority	Standard(s)	Subject	Updated
6366	WG14 Part 9 Issues	CIM Issues			New	Normal	61968-9	Ground as a phase	08/17/2023 10:29 AM
6365	Server	Issues			Rejected	Normal		Considering PTP version 2.1	07/11/2023 08:12 AM
6364	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		SA-ICD (Substation Automation Information Connecting Device) DW-IPC-A-20000	05/31/2023 11:27 AM
6363	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		SA ICD (Substation Automation Information Connecting Device) DW-IPC-A-20000	05/31/2023 11:27 AM
6362	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		SA-OPD (Substation Automation Operation Processing Device) Z8 G4	05/31/2023 11:16 AM
6361	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		APEX 150 P3E	05/31/2023 11:07 AM
6360	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		MPU70 Nexus OnCore Control Module	05/31/2023 11:00 AM
6358	IEC TC57 WG10 Future Work	WG10 Future Work			New	Normal	IEC 61850	IEC 61850-7-4 list of abbreviations	10/26/2023 04:56 AM
6357	WG13 Issues	CIM Issues			New	Normal	61970-301, 61970-452, 61968-13	[GMDM #9] Modeling behind the inverter	06/14/2023 04:13 AM
6356	WG13 Issues	CIM Issues			Review	Normal	61968-13	[GMDM #22] 61968-13 has SwitchPhase.closed attribute in Functional not SSH.	06/14/2023 04:21 AM
6355	WG13 Issues	CIM Issues			Review	Normal	61970-501?	[GMDM #20] Clarification of extension association expression in rdfs	06/14/2023 04:38 AM
6354	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		IED T-IED 170kV	05/24/2023 12:34 PM
6353	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		IED T-IED 23kV	05/25/2023 06:29 AM
6352	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		PROTECTION IED VIPAM5000-KF PT	05/24/2023 12:16 PM
6351	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		PROTECTION IED VIPAM5000-KF V1	05/24/2023 12:11 PM
6350	WG13 Issues	CIM Issues			Review	Normal	61970-4xx, 61968-13	[GMDM #18] Rationalise 61968-13 and 61970-4xx profiles	06/28/2023 11:08 AM
6349	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		Protection IED (SBP-K110)	05/24/2023 11:51 AM
6347	WG13 Issues	CIM Issues			In Progress	Normal		[GMDM #15] Add a limited amount of 'structure' modeling to distribution grid models	06/14/2023 09:47 AM
6346	WG13 Issues	CIM Issues			New	Normal	61970-301,, 61968-13	[GMDM #14] Indicating starting point for feeder tracing	11/06/2023 10:55 AM
6345	WG13 Issues	CIM Issues			New	Normal	61970-301, 61970-452, 61968-13	[GMDM #13] Overhead / underground indicator on equipment	06/28/2023 11:07 AM
6344	WG13 Issues	CIM Issues			New	Normal	61970-301, 61970-452, 61968-13	[GMDM #10] Add .orderedPhases attribute on LinearShuntCompensatorPhase	05/24/2023 09:36 AM

#	Project	Tracker	ID	Source	Status	Priority	Standard(s)	Subject	Updated
6343	WG13 Issues	CIM Issues			New	Normal	61970-301, 61970-452, 61968-13	[GMDM #7] Convention for use of xxxPhase classes	05/24/2023 09:36 AM
6342	WG13 Issues	CIM Issues			New	Normal	61970-301, 61970-452, 61968-13	[GMDM #8] Phase modeling on the low side of residential and commercial service transformers	05/24/2023 09:35 AM
6341	WG13 Issues	CIM Issues			New	Normal	61970-301, 61970-452	[GMDM #4] Support for transformer type designation / determination	05/24/2023 09:34 AM
6340	DNP Conformance Certificates	DNP Conformance Certificate			Approved	Normal		CYG SUNRI PRS-3351	05/19/2023 10:38 AM
6338	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		xGrids Transfer DAUMIT_ISD	05/16/2023 02:33 PM
6337	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		Siemens 7SS85	05/16/2023 02:26 PM
6336	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		6MD85 (SIP 5) - BAY CONTROLLER	05/12/2023 06:32 AM
6329	WG13 Issues	CIM Issues			New	High	IEC61970-301, IEC61970-456	VsConverter required and optional attributes in SSH and SV Profiles	05/10/2023 11:18 AM
6328	WG13 Issues	CIM Issues			New	High	IEC 61970-301, IEC 61970-452, IEC 61070-600	Required usage of BusbarSection	02/07/2024 10:41 AM
6327	SCL Tooling	Issues			Resolved	Normal		tTf2 - export CID file only for Ed2.1?	05/16/2023 08:20 AM
6326	SCL Tooling	Issues			Resolved	Normal		tlie1 - remove step 10-14 to undo previous changes	05/16/2023 08:09 AM
6325	SCL Tooling	Issues			Resolved	Normal		PIXIT missing entries on tlie1 "when supported"	05/16/2023 08:04 AM
6324	SCL Tooling	Issues			Rejected	Normal		sCnf6 - not all extRef require intAddr not referring to external device	05/16/2023 08:44 AM
6323	SCL Tooling	Issues			Resolved	Normal		tTf5 IED name=None is not allowed tissue #1365	05/02/2023 08:20 AM
6322	WG14 Part 9 Issues	CIM Issues			New	Normal	61968-9	New "Low Loss Potential" Quality Code needed in Part 9	06/01/2023 08:37 AM
6321	CIM Issues	CIM Issues			New	Normal		Update the description of MktActivityRecord	04/20/2023 03:46 AM
6319	IEC TC57 WG10 Future Work	WG10 Future Work			New	Normal	IEC 61850-6	maxAttributes - conflicting requirements between GOOSE and reporting	10/26/2023 04:58 AM
6317	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		Siemens 7SL86	04/13/2023 07:26 AM
6316	IEC TC57 WG10 Future Work	WG10 Future Work		RTE	New	Normal	IEC 61850-6	Clarification of using of ValKind, VallImport.	10/26/2023 04:58 AM
6315	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		SA IMD DW-IPC-A-10000	04/11/2023 07:45 AM
6314	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		Protection IED (PAC-XG100)	04/09/2023 07:54 AM
6313	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		Protection IED (PAC-XF100)	04/09/2023 07:51 AM

#	Project	Tracker	ID	Source	Status	Priority	Standard(s)	Subject	Updated
6312	WG14 Issues	CIM Issues			Review	Normal		Clarify x, y, z attributes in PositionPoint	10/14/2023 10:40 AM
6311	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		PSL 603U	04/02/2023 12:12 PM
6310	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		MiCOM P40 Agile	03/30/2023 01:41 PM
6309	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		MiCOM P40 Agile	03/30/2023 01:37 PM
6308	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		K-IED ABK100	03/29/2023 04:55 PM
6307	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		(SUR5000-LP	03/29/2023 04:51 PM
6306	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		K-IED ABK100	03/29/2023 04:55 PM
6305	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		Protection IED (SUR5000-LP)	03/29/2023 04:40 PM
6303	IEC 61850 User Feedback Task Force	Support		RTE	Resolved	Normal	IEC 61850-7-500	LN PDIF – setting for nominal current	06/05/2023 01:58 AM
6302	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		REC670 Bay control	03/27/2023 10:47 AM
6301	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		REC670 Bay control	03/27/2023 10:42 AM
6300	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		DW-IPC-A-50000 SA LID (Substation Automation Local Information processing Device)	03/26/2023 10:38 AM
6299	WG13 Issues	CIM Issues			New	Normal		OperationalLimitType; add an attribute to hold the "type" of limit, such as Emergency, Normal, ...	02/07/2024 02:30 PM
6298	WG14 Part 9 Issues	CIM Issues			New	Normal	61968-9	New Event codes needed in Part 9 for overvoltage and undervoltage	03/22/2023 08:48 AM
6297	WG14 Part 9 Issues	CIM Issues			New	Normal	61968-9	New Event code needed in Part 9 for DC Voltage	04/20/2023 09:54 AM
6296	WG14 Part 9 Issues	CIM Issues			New	Normal	61968-9	New "Transformer Compensated" Quality Code needed in Part 9	06/01/2023 08:10 AM
6295	WG14 Issues	CIM Issues			New	Normal	61968-9	Publication of meter firmware versions from Part 9 to Part 4.	03/21/2023 03:54 PM
6294	WG14 Issues	CIM Issues			New	Normal	61968-9	IRM	03/21/2023 03:46 PM
6293	Market Management	CIM Issues			Open	Normal		Add energyFlowCategory (string) to the AccountingPoint class	07/06/2023 10:57 AM
6292	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		Siemens 7UT86 TRANSFORMER DIFFERENTIAL PROTECTION	03/17/2023 08:14 AM
6290	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		SG B750	03/15/2023 02:49 PM
6289	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		PST 671U	03/15/2023 02:44 PM

#	Project	Tracker	ID	Source	Status	Priority	Standard(s)	Subject	Updated
6288	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		HSC RTU for Industrial Automation and Control Systems	03/10/2023 01:33 PM
6287	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		Teamware CCI-Central Plant controller	03/10/2023 01:23 PM
6286	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		Landis Gyr AG E65C CU-XE Grid Edge Gateway with S650 and E660	03/10/2023 01:24 PM
6285	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		Teleport: Real-time controller of energy assets	03/10/2023 01:10 PM
6284	WG14 Issues	CIM Issues			Open	Normal		Need to refine modeling of special need information	10/14/2023 10:39 AM
6275	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		PSL 641UX	02/28/2023 07:43 AM
6273	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		xGrids Transfer KPG-v1	02/24/2023 07:40 AM
6272	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		xGrids Transfer KPG-v1	02/24/2023 07:40 AM
6271	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		SUR-K220 Protection IED	06/01/2023 07:46 AM
6270	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		TC-BCU21 Bay Control Unit (BCU)	02/22/2023 08:01 AM
6267	CIM Joint Issues	CIM Issues			New	High	IEC61968-11	Person and Organization Relationships	02/15/2023 09:31 AM
6266	CIM Issues	CIM Issues			New	Normal	IEC61968-11	Person and Person Role Modeling	02/15/2023 09:21 AM
6265	IEC TC57 WG10 Future Work	WG10 Future Work			New	Normal	IEC 61850-6	track changes in SCL to know when a device needs to be updated based on new SCD version	02/19/2024 10:56 AM
6264	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		SIPROTEC 5 - 7VU85 High Speed Busbar Transfer	02/05/2024 08:52 AM
6263	IEC 61850 User Feedback Task Force	Bug			Resolved	Normal	IEC 61850-6	GOOSE MinTime / Max Time - Probable discrepancy between Part-6 and Part-8	06/20/2023 08:44 AM
6262	WG14 Part 4 Issues	CIM Issues			Review	Normal	61968 part 4	One AssetInfo Datasheet can contain multiple sheets for each component	07/03/2023 08:05 AM
6261	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		xGrids Transfer YH-ISD	02/13/2023 07:18 AM
6256	IEC 61850 User Feedback Task Force	Bug			Resolved	Normal	IEC 61850-7-4	IEC 61850-7-4 list of abbreviations	06/06/2023 08:32 AM
6249	CIM Issues	CIM Issues			New	Normal		Update CIM namespace	02/06/2023 01:17 PM
6248	IEC 61850 User Feedback Task Force	Improvement		EDF	Resolved	Normal	IEC 61850-6	There are controls between IEDs for automatic control functions, we need to be able to represent those controls in SCL (for configuration in SCT, data flow documentation...)	06/14/2023 08:33 AM
6247	WG13 Issues	CIM Issues			New	Normal	61970-301	Missing support for fault indicators	06/14/2023 04:32 AM

#	Project	Tracker	ID	Source	Status	Priority	Standard(s)	Subject	Updated
6246	IEC 61850 User Feedback Task Force	Feature			Resolved	Normal	IEC 61850-6	ExtRef cannot specify a Poll intended to be implemented as a GetDataSetValues request	06/05/2023 01:58 AM
6245	WG14 Part 3 Issues	CIM Issues			New	Normal		It is not possible to convey that an UnplannedOutage is frozen (prediction is suspended).	02/01/2023 02:29 PM
6244	WG14 Part 3 Issues	CIM Issues			New	Normal		Part 3 should specify that you can use 'updated' verb	01/31/2023 03:32 PM
6243	WG14 Part 3 Issues	CIM Issues			New	Normal		UnplannedOutages is missing OutageArea and AreaKind	01/31/2023 03:29 PM
6242	WG14 Part 3 Issues	CIM Issues			New	Normal		OutageArea has nowhere to put the name of the outage area	01/31/2023 03:26 PM
6241	WG14 Part 3 Issues	CIM Issues			New	Normal		UnplannedOutages does not provide a way to capture affected kVA for IEEE load-based indices	01/31/2023 03:23 PM
6240	WG14 Part 3 Issues	CIM Issues			New	Normal		UnplannedOutages has no way to indicate that the outage should be excluded from reliability reporting.	01/31/2023 02:59 PM
6239	WG14 Part 3 Issues	CIM Issues			New	Normal		UnplannedOutages profile needs ability to capture de-energized and energized times per UsagePoint	01/31/2023 02:26 PM
6238	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		HMI VICOM-PES	01/30/2023 08:07 AM
6237	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		IED VIPAM-PBAS	01/30/2023 08:02 AM
6236	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		SA LID (Substation Automation Local Information processing Device) ECU-4784	02/17/2023 04:01 PM
6235	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		SA MD (Substation Automation Monitoring & diagnosis Device) VertexCOM-MD3	02/17/2023 03:59 PM
6234	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		SA ICD (Substation Automation Information Connecting Device) ECU-4784	02/17/2023 03:58 PM
6233	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		SA ICD (Substation Automation Information Connecting Device) ECU-4784	02/15/2023 09:53 AM
6232	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		SA OPD (Substation Automation Operation Processing Device) Z8	01/30/2023 07:33 AM
6231	Market Management	CIM Issues			New	Normal		Add the new datatype ESMPDataTypes / SettlementMethodType_String and enumeration	01/30/2023 10:21 AM
6229	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		MiCOM P40 Agile	01/25/2023 08:16 AM
6226	IEC 61850 User Feedback Task Force	Bug			Resolved	Normal		In the downgrading rules from ed 2.1 to ed 2.0 in part 6, it is mentioned to exclude ORS CDC (1.4.2.4). Why CDCs: CST, VSD and TCS that were also added in ed2.1 are not mentioned to be excluded also ?	06/05/2023 01:58 AM
6225	IEC 61850 User Feedback Task Force	Feature	60	RTE	In Progress	Normal	IEC 61850-7-4	Parameters not available in standardized LN - SetPhsOrig	02/28/2023 09:42 AM
6224	IEC 61850 User Feedback Task Force	Feature	59	RTE	In Progress	Normal	IEC 61850-7-4	Parameters not available in standardized GAPC LN - SetRef	02/28/2023 09:42 AM

#	Project	Tracker	ID	Source	Status	Priority	Standard(s)	Subject	Updated
6223	IEC 61850 User Feedback Task Force	Feature	58	RTE	In Progress	Normal	IEC 61850-7-4	Parameters not available in standardized GAPC LN - StrVal	02/28/2023 09:42 AM
6222	IEC 61850 User Feedback Task Force	Feature	57	RTE	In Progress	Normal	IEC 61850-7-4	Parameters not available in standardized GAPC LN - SetNb	02/28/2023 09:42 AM
6221	IEC 61850 User Feedback Task Force	Feature	56	RTE	In Progress	Normal	IEC 61850-7-4	Parameters not available in standardized GAPC LN - OnOff	02/28/2023 09:42 AM
6220	IEC TC57 WG10 Future Work	WG10 Future Work			New	Normal	IEC 61850-7-4	Parameters not available in standardized GAPC LN - opDITmms, DITmms	10/26/2023 05:00 AM
6219	IEC 61850 User Feedback Task Force	Feature	54	RTE	In Progress	Normal	IEC 61850-7-4	Parameters not available in standardized LN - VRtg, ARtg and HzRtg	02/28/2023 09:42 AM
6218	IEC 61850 User Feedback Task Force	Feature	53	RTE	In Progress	Normal	IEC 61850-7-4	Parameters not available in standardized LN - PhyConnITF	02/28/2023 09:42 AM
6217	IEC 61850 User Feedback Task Force	Feature	52	RTE	In Progress	Normal	IEC 61850-7-4	Parameters not available in standardized LN - NamAccRtg	02/28/2023 09:42 AM
6216	IEC 61850 User Feedback Task Force	Feature	51	RTE	In Progress	Normal	IEC 61850-7-4	Parameters not available in standardized LN - SetPhNum	02/28/2023 09:42 AM
6212	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		MiCOM P40 Agile Enhanced P14D	01/12/2023 08:25 AM
6208	Server	Issues			Rejected	Normal		sSvsN2 in TP1.2 does not check the situation where the DUT checks ConfRev	03/21/2023 08:20 AM
6207	IEC 61850 User Feedback Task Force	Improvement			Resolved	Normal	IEC 61850-6	How to manage update of an IEDName or LDName for object references when vallmport is false	06/05/2023 01:58 AM
6206	Server	Issues			Rejected	Normal		Type and size of Length field value (TLV) encoding in SV	01/11/2023 06:19 AM
6205	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		SNI 61850 Server Protocol Converter (SNIIT)	01/19/2023 08:37 AM
6204	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		ETCPU650 DC Protection Relay	01/03/2023 08:18 AM
6200	SCL Tooling	Issues			Resolved	Normal		tTf1 change Ed2/2007B to Ed2.1/2007B4	01/24/2023 08:33 AM
6199	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		MiCOM 940 Agile P546 Line Differential Relay	12/14/2022 08:20 AM
6197	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		MiCOM 940 Agile P746	12/06/2022 02:37 PM
6196	WG14 Part 4 Issues	CIM Issues			Review	Normal		Facility Kind	07/03/2023 08:05 AM
6195	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		TC-CCI Power Plant Control System	12/02/2022 02:18 PM
6194	WG14 Part 3 Issues	CIM Issues			New	Normal		PlannedOutageNotifications needs to support energize/de-energize time/date per UsagePoint.	11/29/2022 12:50 PM
6191	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		SIPROTEC 7SJ686	11/29/2022 08:15 AM

#	Project	Tracker	ID	Source	Status	Priority	Standard(s)	Subject	Updated
6187	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		UR N60 Edition 2 Server	11/24/2022 08:18 AM
6185	IEC TC57 WG10 Future Work	WG10 Future Work		2022 IOP	New	Normal	IEC 61850-6	SCL Need to differentiate the difference in the number of GOOSE vs R-GOOSE	10/26/2023 05:01 AM
6183	DNP Conformance Certificates	DNP Conformance Certificate			Approved	Normal		Lucy Electric Gemini 3 mini	11/13/2022 11:34 PM
6182	DNP Conformance Certificates	DNP Conformance Certificate			Approved	Normal		IDS ACOS 750	11/13/2022 11:25 PM
6181	DNP Conformance Certificates	DNP Conformance Certificate			Approved	Normal		Schneider Electric SCADAPack 535E	11/13/2022 11:18 PM
6180	DNP Conformance Certificates	DNP Conformance Certificate			Approved	Normal		Moxa MGate 5109	11/13/2022 11:13 PM
6179	DNP Conformance Certificates	DNP Conformance Certificate			Approved	Normal		Instituto Nacional de Electricidad y Energias Limpias UCM-CFE	11/13/2022 11:06 PM
6178	WG13 Issues	CIM Issues			New	Low		Relation between ResourcePerformanceEvaluation and ResourcePerformanceGlobalFactor contains a typo at the source side (role) of the association.	11/11/2022 08:12 AM
6177	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		PNC FTU-P200T Server Edition 2	11/09/2022 07:00 AM
6176	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		Schneider Easergy MiCOM P545 Edition 2 Server	11/08/2022 08:39 AM
6175	IEC 61850 User Feedback Task Force	Bug		2022 IOP	In Progress	Normal	IEC 61850-6	SCL SICS requires SNTP even with 2.1 where PTP is the preferred method.	11/07/2023 08:21 AM
6174	Server	Issues			Rejected	Normal		Amend sCtl7 to test both interlocking check and check synchronizing ?	02/07/2023 08:24 AM
6173	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		FTU PNC Technologies Edition 2 Server	11/02/2022 07:36 AM
6172	Client	Issues			Resolved	Normal		client check bits must be tested	12/13/2022 08:34 AM
6171	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		REX640 Protection and Control Relay	10/27/2022 12:12 PM
6170	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		EcoStruxure Power Operation Edition 2 Client	10/25/2022 01:25 PM
6168	Market Management	CIM Issues			Open	Normal		Deprecate the three attributes in Series	04/19/2023 09:48 AM
6167	IEC 61850 User Feedback Task Force	Support		email	Resolved	Normal	IEC 61850-90-6	IEC 61850-90-6 Voltage presence CDC for SVPI.Prs	06/05/2023 01:58 AM

#	Project	Tracker	ID	Source	Status	Priority	Standard(s)	Subject	Updated
6165	IEC TC57 WG10 Future Work	WG10 Future Work		Tissue DB	New	Normal	TR IEC 61850-7-500	https://iec61850.tissue-db.com/tissue/1844 - Implementation of SumSwARs in 3-phase circuit breaker inaccurate	10/26/2023 05:01 AM
6164	IEC TC57 WG10 Future Work	WG10 Future Work		Tissue DB	New	Normal	IEC 61850-7-4	https://iec61850.tissue-db.com/tissue/1825 - Permission mode for control/setting of a scheduled entity from a client	10/26/2023 05:03 AM
6163	IEC TC57 WG10 Future Work	WG10 Future Work		Tissue DB	New	Normal	TR IEC 61850-7-5	https://iec61850.tissue-db.com/tissue/1804 - When e.g. LocSta = false, result of command to switch DO Mod with "station-control" not clear.	10/26/2023 05:06 AM
6162	IEC TC57 WG10 Future Work	WG10 Future Work		Tissue DB	New	Normal	TR IEC 61850-7-500	https://iec61850.tissue-db.com/tissue/1803 - Mechanical Blocking of 3 way switches	10/26/2023 05:07 AM
6161	IEC TC57 WG10 Future Work	WG10 Future Work		Tissue DB	New	Normal	TR IEC 61850-7-5	https://iec61850.tissue-db.com/tissue/1797 - SwModKey dependency of CSWI from LLN0	10/26/2023 05:08 AM
6160	IEC TC57 WG10 Future Work	WG10 Future Work		Tissue DB	New	Normal	TR IEC 61850-90-29	https://iec61850.tissue-db.com/tissue/1796 LPHD.PwrSupAlm as OMulti	10/26/2023 05:13 AM
6159	IEC TC57 WG10 Future Work	WG10 Future Work		Tissue DB	New	Normal	TR IEC 61850-90-3	https://iec61850.tissue-db.com/tissue/1789 SCBR - Coilxxx-Data-Objects shall be OMulti	10/26/2023 05:14 AM
6158	IEC TC57 WG10 Future Work	WG10 Future Work		Tissue DB	New	Normal	IEC 61850-7-4	https://iec61850.tissue-db.com/tissue/1760 - OMulti for MMET data objects	10/26/2023 05:14 AM
6156	IEC TC57 WG10 Future Work	WG10 Future Work		Tissue DB	New	Normal	IEC 61850-7-3	https://iec61850.tissue-db.com/tissue/1748 Arrays of CDC	10/26/2023 05:15 AM
6155	IEC TC57 WG10 Future Work	WG10 Future Work		Tissue DB	New	Normal	TR IEC 61850-7-500	https://iec61850.tissue-db.com/tissue/1706 Missing LN for Miniature Circuit Breaker (MCB)	10/26/2023 05:19 AM
6154	IEC TC57 WG10 Future Work	WG10 Future Work		Tissue DB	New	Normal	IEC 61850-7-4	https://iec61850.tissue-db.com/tissue/1698 AnOut in GAPC	10/26/2023 05:19 AM
6153	IEC TC57 WG10 Future Work	WG10 Future Work		Tissue DB	New	Normal	IEC 61850-7-4	https://iec61850.tissue-db.com/tissue/1691 Contradictory statement for Mod.stVal	10/26/2023 05:19 AM
6152	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		xGrids Transfer YH-ISD	10/11/2022 01:12 PM
6151	IEC TC57 WG10 Future Work	WG10 Future Work		Tissue DB	New	Normal	IEC 61850-7-3	Use and configuration of ORG within the scope of InRef 7 BlkRef	10/26/2023 05:20 AM
6150	DNP Conformance Certificates	DNP Conformance Certificate			Approved	Normal		Ingeteam INGESAS IC3	10/31/2022 08:54 AM
6149	DNP Conformance Certificates	DNP Conformance Certificate			Approved	Normal		SEL-411L-0	07/27/2023 09:57 AM
6148	WG13 Issues	CIM Issues			Review	Normal		[GMDM #2] TapChanger and TapChangerInfo .ctRating, .ctRatio and .ptRatio attributes	06/13/2023 09:51 AM
6147	WG13 Issues	CIM Issues			New	Normal		[GMDM #1] Streamlining of tank-based transformer modelling	06/13/2023 10:01 AM
6146	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		Siemens 6MD85	01/19/2023 08:38 AM

#	Project	Tracker	ID	Source	Status	Priority	Standard(s)	Subject	Updated
6144	IEC TC57 WG10 Future Work	WG10 Future Work		IOP 2022	New	Normal	IEC 61850-6	Need to add SCL mechanism to define a minimum MinTime	10/26/2023 05:21 AM
6143	IEC TC57 WG10 Future Work	WG10 Future Work			New	High	TR IEC 61850-7-500, TR IEC 61850-90-3	Update the Switchgear / Breaker Model	10/26/2023 03:50 AM
6141	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		FOX612 with BIGO1 IEC61850 interface Server Edition 2	09/22/2022 07:28 PM
6140	WG14 Part 11 Issues	CIM Issues			Open	Normal	61968-6, 61968-9	Alignment of Part 6 WorkTasks profile with Part 9 MeterConfig profile	06/12/2023 07:26 AM
6139	WG14 Part 6 Issues	CIM Issues			Open	Normal	61968-4, 61968-6	Alignment of Part 6 WorkTasks profile with Part 4 AssetDetail profile	10/16/2023 03:00 PM
6138	WG14 Part 4 Issues	CIM Issues			Open	Normal		WorkAsset current location	07/10/2023 10:27 AM
6137	WG14 Part 4 Issues	CIM Issues			Review	Normal	61968-4	ProcedureDataSet association to Asset and Measurement	11/04/2023 12:57 PM
5979	WG14 Part 9 Issues	CIM Issues			New	Normal	IEC 61968-9 and others	Meter to UsagePoint relationship should be many-to-many	06/15/2023 09:32 AM
5978	WG13 Issues	CIM Issues			New	Normal	61968-301	Remove serialization instructions from the UML description of mRID	12/11/2023 04:32 AM
5977	WG13 Issues	CIM Issues			New	Normal	61968-13, 61968-11, 61970-600-2	Cardinality of PowerSystemResource to Location	02/28/2024 10:49 AM
5976	WG13 Issues	CIM Issues			New	Normal		CIM-61850 Harmonization - revise control model for DiscreteCommand (e.g. raise/lower)	09/21/2022 04:13 AM
5975	WG13 Issues	CIM Issues			New	Normal		CIM-61850 Harmonization - define a standard list of control types	09/21/2022 03:59 AM
5974	WG13 Issues	CIM Issues			New	Normal		CIM-61850 Harmonization - allow direct association IED to MeasurementValue	09/21/2022 04:07 AM
5973	WG13 Issues	CIM Issues			New	Low		CIM-61850 Harmonization - consider Measurement classes with multiple values (vector, Wye ...)	09/21/2022 03:36 AM

...