Issues

#	Project	Tracker	ID	Source	Status	Priority	Standard(s)	Subject	Updated
7010	Client	Issues			New	Low		UCA logo is missing on the certificate template of the goose performance	10/01/2024 08:16 AM
6711	61850-7-5 and 61850-7-500	IEC61850-7-5		WG10 Fall workshop	In Progress	Low		SCL Modelling of Fault Measurements (RFMX)	02/29/2024 08:33 AM
6488	GOOSE Performance	Issues			Resolved	Low		Incorrect reference	09/05/2023 08:08 AM
6447	IEC TC57 WG10 Future Work	WG10 Future Work		WG10 Fall workshop	New	Low		Enhanced Quality Information for Measurements (accuracy classes, update periods, filter applied, algorithm applied, etc.)	02/08/2024 03:16 AM
6433	IEC TC57 WG10 Future Work	WG10 Future Work		WG10 Fall workshop	New	Low		SCL Extensions (partial configuration updates in a top-down approach, mixed editions with private CDCs, etc.)	02/08/2024 03:03 AM
6178	Market Operations	CIM Issues			Open	Low		Relation between ResourcePerformanceEvaluation and ResourcePerformanceGlobalFactor contains a typo at the source side (role) of the association.	09/20/2024 10:18 AM
5973	WG13 Issues	CIM Issues			Open	Low		CIM-61850 Harmonization - consider Measurement classes with multiple values (vector, Wye ...)	09/16/2024 02:56 PM
5971	WG13 Issues	CIM Issues			Open	Low		CIM-61850 Harmonization - Consider modelling fans, pump motors and battery systems as types of auxiliary equipment	09/30/2024 06:22 PM
5816	WG16 Issues	CIM Issues			Open	Low		Associate the class BusinessSector with the MktActivityRecord class (many-many-association).	09/22/2022 11:40 AM
5815	WG16 Issues	CIM Issues			Open	Low		Associate the class BusinessSector with the TimeSeries class (many-many-association).	09/22/2022 11:40 AM
5814	WG16 Issues	CIM Issues			Open	Low		Associate the class BusinessSector with the MarketDocument class (many-many-association).	09/22/2022 11:41 AM
5813	WG16 Issues	CIM Issues			Open	Low		Add attribute type (string) in the BusinessSector class to tell the specific Businss sector [required].	09/22/2022 11:41 AM
5812	WG16 Issues	CIM Issues			Open	Low		Add a new BusinessSector class in the MarketManagement package.	09/22/2022 11:41 AM
5313	WG13 Issues	CIM Issues			Open	Low		Better description for governorSCD	09/19/2024 03:33 PM
5218	WG14 Part 4 Issues	CIM Issues			Review	Low		Deprecate AssetOrganisationRole	07/03/2023 09:25 AM
5216	WG14 Part 4 Issues	CIM Issues			Review	Low		Add kindOther to Asset	07/03/2023 09:48 AM
5062	WG13 Issues	CIM Issues			Open	Low		DC auxiliary equipment support	09/19/2024 11:40 AM
4946	WG13 Issues	CIM Issues			Open	Low		HydroPowerPlant inherit PSR There is Plant class that inher	09/14/2021 03:47 PM
654	Server	Issues			Rejected	Low		Publish/subscribe minimum length data GOOSE	01/24/2023 09:02 AM
653	Server	Issues			Rejected	Low		Subscriber can use maximum number of dataset elements	01/24/2023 09:03 AM
651	Server	Issues			Rejected	Low		Verify subscriber can accept maximum size GOOSE	01/24/2023 08:40 AM
7025	CIM Joint Issues	CIM Issues			New	Normal		Standardized the use of flow/direction across working groups and CIM packages (Grid, Enterprise, Market)	10/10/2024 11:19 AM

#	Project	Tracker	ID	Source	Status	Priority	Standard(s)	Subject	Updated
7023	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		Digital Tap Changer Controller - Transformer Monitoring System	10/09/2024 07:56 AM
7022	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		RD55UP12-V Intelligent Function Module with iQ-R R32PCPU CPU Module	10/09/2024 07:49 AM
7021	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		TAS-GW	10/06/2024 06:45 PM
7020	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		TAS-GW	10/06/2024 06:39 PM
7013	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		7SL87	10/01/2024 09:07 AM
7011	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		MIED12 (Multifunction Protection Relay)	09/30/2024 07:08 AM
7009	Market Management	CIM Issues			New	Normal		Addition of EnergyCharacteristics to MarketManagement	10/10/2024 11:17 AM
7008	Server	Issues			Rejected	Normal		Proposal to change Mandatory test items related to compatibility to Conditional	10/01/2024 08:19 AM
7001	IEC 61850 User Feedback Task Force	Bug			In Progress	Normal		Presence condition of DO in statistic Logical Nodes	09/24/2024 09:05 AM
7000	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		KSE(Kepco Substation Explorer)	09/22/2024 07:14 PM
6999	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		DRTS 66L	09/22/2024 02:06 PM
6998	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		SIPROTEC 5 7ST86	09/20/2024 12:59 PM
6997	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		DRTS 66L	09/24/2024 07:24 AM
6996	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		RD55UP12-V Intelligent Function Module with iQ-R R32PCPU CPU Module	09/20/2024 01:01 PM
6995	WG13 Issues	CIM Issues			New	Normal		Add transmission composite load model	09/20/2024 11:26 AM
6993	WG13 Issues	CIM Issues			New	Normal		Modeling of multiple inverters mapping to PCC	09/20/2024 10:24 AM
6991	Server	Issues			New	Normal		sCnf75 not all devices have control objects	10/01/2024 08:30 AM
6990	Server	Issues			New	Normal		sSvp9 step 4 PTP class not 6/7 with/without holdover time?	10/01/2024 08:46 AM
6989	Server	Issues			New	Normal		sSvp14 for Backwards the max MSVID is 34 char not 32	09/20/2024 06:29 AM
6988	Server	Issues			New	Normal		sCtl16 in TP1.3 is in conflict with 7-4 Table B.1	09/20/2024 06:10 AM
6983	WG13 Issues	CIM Issues			New	Normal		Diagram HyperLink	10/02/2024 10:09 AM
6926	WG13 Issues	CIM Issues			New	Normal		Domain RotationSpeed	09/17/2024 09:07 AM
6924	WG13 Issues	CIM Issues			New	Normal		Add subclasses of SubSchedulingArea	09/16/2024 04:17 PM
6911	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		TAS-LID	09/12/2024 06:11 AM

#	Project	Tracker	ID	Source	Status	Priority	Standard(s)	Subject	Updated
6910	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		TAS-LID	10/06/2024 06:24 PM
6905	Server	Issues			New	Normal		sSBOes8 why is time validated for Cancel but not for the Operate	09/11/2024 10:19 AM
6904	Server	Issues			In Progress	Normal		sCtl14 in TP1.3 does not reflect the Issue #6214 resolution	09/27/2024 03:40 AM
6903	Server	Issues			New	Normal		sGos20 requires the ICT to accept invalid SCD files due to FC out of tFCEnum	09/11/2024 04:13 AM
6902	Client	Issues			New	Normal		cLogN5 has no Ed1 specific error code	09/11/2024 02:27 AM
6897	Server	Issues			New	Normal		sCnf7, sCnf66 services can be defined on IED and AccessPoint when identical	09/05/2024 07:27 AM
6896	Server	Issues			In Progress	Normal		sSrv17	10/01/2024 08:03 AM
6894	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		SA-LID DWSA-SPC	08/30/2024 06:48 AM
6893	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		SA-LID DWSA-SPC	09/02/2024 07:51 AM
6890	Market Management	CIM Issues			New	Normal		Addition of Permission class to MarketManagement	10/01/2024 01:50 AM
6888	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		REF650	08/27/2024 05:32 PM
6887	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		REF650	08/27/2024 05:26 PM
6886	Server	Issues			In Progress	Normal		Tissue 1897Data-change and data-update inclusion bitstring bits set in a report	10/01/2024 08:04 AM
6884	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		UC 500 S	08/27/2024 05:43 PM
6883	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		IET600	08/23/2024 07:40 AM
6881	SCL Tooling	Issues			New	Normal		tDfe6b the SCT is not allowed to create new bindings	10/01/2024 08:12 AM
6875	Client	Issues			In Progress	Normal		Update Client certificate template following the server certificate template	10/01/2024 08:12 AM
6870	WG14 Part 4 Issues	CIM Issues			New	Normal		Cable Info classes	09/06/2024 01:27 PM
6869	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		SIPROTEC 5 7ST86	08/13/2024 07:45 AM
6841	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		DM100	08/08/2024 02:23 PM
6835	Test Procedure Issues	Issues			New	Normal		Impact of publication of IEC 61850-6 Edition 2.2 on Edition 2.1 certification of Server/Client and Tools	08/07/2024 01:58 AM
6834	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		SA-IMD DWSA-WATCHER	08/06/2024 01:04 PM
6833	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		SA-IMD DWSA-WATCHER	08/06/2024 01:05 PM

#	Project	Tracker	ID	Source	Status	Priority	Standard(s)	Subject	Updated
6832	61850-7-5 and 61850-7-500	IEC61850-7-5			New	Normal		CPOW interface with CSWI and XCBR needs to be revise.	07/25/2024 10:10 AM
6831	WG14 Part 11 Issues	CIM Issues			Open	Normal		ProductAssetModel.weightTotal and SwitchInfo.gasWeigthPerTank have type Mass as a string and not as a link to CIMDataType Mass	09/19/2024 03:59 PM
6830	Server	Issues			Resolved	Normal		Testing max number of persistent and non-persistent datasets	08/06/2024 08:11 AM
6829	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		Easergy MiCOM P849	07/16/2024 12:24 PM
6828	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		DRTS 66L	07/16/2024 12:16 PM
6826	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		K-IMD	10/06/2024 06:26 PM
6825	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		K-IMD	10/06/2024 06:25 PM
6824	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		SO-52	07/11/2024 12:30 PM
6823	Server	Issues			Resolved	Normal		sAss4 - Step 2 indicates two different situations with localDetailCalling	08/06/2024 08:15 AM
6822	WG13 Issues	CIM Issues			Open	Normal		Why are WindTurbineType1or2Dynamics models required to link to another AsynchronousMachineDynamics model rather than directly associating with the AsynchronousMachine?	09/04/2024 10:44 AM
6821	Server	Issues			Resolved	Normal		Missing SMVsc check - sCnf130	07/23/2024 08:37 AM
6820	61850-7-5 and 61850-7-500	IEC61850-7-5			New	Normal		Revising IEC/TR 61860-7-500 clause 11.1.3 about the use of GGIO and GAPC, Figures 12 and 23	07/26/2024 03:02 AM
6819	61850-7-5 and 61850-7-500	IEC61850-7-5		discussion	New	Normal		Reworking IEC/TR 61860-7-500 clause 10.1.1.2 about pole discrepancy	07/26/2024 04:43 AM
6818	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		TAS-GW	06/30/2024 09:11 AM
6817	Server	Issues			Resolved	Normal		sBr25 purge only when attribute value change	08/06/2024 08:20 AM
6816	Client	Issues			Rejected	Normal		cBr31 is mandatory but for not applicable "small" client controllers	07/23/2024 08:51 AM
6815	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		PGA-2001 Remote Terminal Unit	06/19/2024 10:26 AM
6814	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		SA-G2000	06/19/2024 10:17 AM
6813	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		SA-G2000	06/19/2024 10:11 AM
6812	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		SA-T8000	06/19/2024 10:06 AM
6805	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		SEL-2411	06/10/2024 08:24 AM

#	Project	Tracker	ID	Source	Status	Priority	Standard(s)	Subject	Updated
6804	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		MRZS-F	06/10/2024 08:15 AM
6801	61850-7-5 and 61850-7-500	IEC61850-7-5			New	Normal		Modelling of 3 position switches	06/05/2024 08:49 AM
6800	WG13 Issues	CIM Issues			Open	Normal		Ambiguous associations between RelayDynamics and ConductingEquipment(end role name = ProtectedEquipment) and ProtectionEquipment (end role name = ProtectedEquipment)	09/04/2024 10:45 AM
6799	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		Danit-61850	05/30/2024 08:25 AM
6798	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		YCS IEC 61850 Module	05/30/2024 08:19 AM
6794	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		P3F60	05/26/2024 09:05 AM
6793	Client	Issues			Resolved	Normal		cCnf13 the ICT tool shall refuse the configuration	05/28/2024 09:04 AM
6791	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		YH-HSA-ICD	05/19/2024 11:54 AM
6790	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		YH-HSA-ICD	05/19/2024 11:47 AM
6789	CIM Joint Issues	CIM Issues			New	Normal		Need new cdPerm2 enumerated value for Unit Symbol	05/16/2024 03:29 PM
6788	61850-7-5 and 61850-7-500	IEC61850-7-5			New	Normal		Integration of the "Regensburg" decisions on local/remote into the relevant parts of IEC 61850	05/16/2024 11:17 AM
6787	61850-7-5 and 61850-7-500	IEC61850-7-5			In Progress	Normal		Harmonization of Table 4 with Figure 22	06/13/2024 08:44 AM
6784	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		iRTU	05/03/2024 04:14 PM
6783	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		CCI Power Plant Controller	05/03/2024 03:02 PM
6782	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		iCE-CPU	05/03/2024 02:51 PM
6781	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		EcoStruxure™ Power Automation System Engineering	05/03/2024 02:34 PM
6778	Market Operations	CIM Issues			Rejected	Normal		RegisteredDistributedResource vs RegisteredResource attributes	06/10/2024 09:42 AM
6777	Client	Issues			Resolved	Normal		SCD import and Tool Functionality test procedures	05/28/2024 08:05 AM
6776	Client	Issues			Resolved	Normal		cSBOns4 requires different control value	05/28/2024 08:07 AM
6772	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		EcoStruxure Foxboro SCADA SCD6000 CPU	04/28/2024 08:38 AM
6771	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		EcoStruxure Foxboro SCADA SCD6000 CPU	04/30/2024 08:28 AM

#	Project	Tracker	ID	Source	Status	Priority	Standard(s)	Subject	Updated
6770	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		EdgeHub DataWorX	04/24/2024 02:00 PM
6768	61850-7-5 and 61850-7-500	IEC61850-7-5			New	Normal		Control of substituted or blocked objects	04/19/2024 05:08 AM
6767	IEC 61850 User Feedback Task Force	Feature			Resolved	Normal		Specifying virtualized physical devices and LN's	06/03/2024 03:10 AM
6766	WG16 Issues	CIM Issues			Rejected	Normal		ResourceCertification attribute type is generic and could be renamed to a more describe attribute name	06/10/2024 10:31 AM
6763	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		ETOPD1000	04/15/2024 07:33 AM
6762	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		YH-HSA-ICD	04/25/2024 07:23 AM
6761	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		YH-HSA-ICD	04/25/2024 07:22 AM
6760	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		SEL-751 and SEL-787L (Variant)	04/15/2024 06:52 AM
6759	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		PCM600	04/15/2024 06:45 AM
6755	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		Multilin N60	04/07/2024 11:11 AM
6754	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		N60	04/30/2024 08:37 AM
6751	IEC 61850 TPWG	Issues			Resolved	Normal		Update IEC 61850 QAP Addendum for adding requirement quickly	04/16/2024 08:16 AM
6748	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		IED1-E11D1	03/29/2024 09:16 AM
6747	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		WAGO 750-8212/0040-0001	03/29/2024 09:06 AM
6746	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		DW61850CLIENT	03/29/2024 09:07 AM
6742	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		V321 Arc Flash Protection System	03/24/2024 02:16 PM
6741	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		SA-G3000	03/24/2024 02:10 PM
6740	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		ALARM ANNUNCIATOR MBAS 0600	03/24/2024 01:50 PM
6739	IEC 61850 User Feedback Task Force	Feature			In Progress	Normal		How to deal with 'Beh' and 'Health' of isolated functions	04/09/2024 08:43 AM
6738	IEC 61850 User Feedback Task Force	Improvement			Resolved	Normal		Amending TGSN LN class with settings for adapting the signal	04/09/2024 08:19 AM

#	Project	Tracker	ID	Source	Status	Priority	Standard(s)	Subject	Updated
6734	WG16 Issues	CIM Issues			New	Normal		Review use/inheritance of Document by UCA TF 16 classes, profile, standards	03/11/2024 09:58 AM
6733	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		ETLID1000	03/11/2024 08:38 AM
6732	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		ETMDU1000	03/11/2024 08:39 AM
6731	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		Micom P40 Agile 5th Generation P84	03/11/2024 08:24 AM
6730	CIM Joint Issues	CIM Issues			New	Normal		Evaluation of the Pipeline Open Data Standard (PODS)	03/07/2024 11:09 AM
6729	CIM Joint Issues	CIM Issues			New	Normal		Multi-commodity Support	03/07/2024 11:10 AM
6728	Client	Issues			Resolved	Normal		cSg13 refers to PIXIT entry Sg5/Sg6 but not clarified in the expected result	05/28/2024 08:17 AM
6727	Client	Issues			Resolved	Normal		cDsN1bc, cFtN2 have no non-Ed2 specific error code	04/02/2024 08:42 AM
6726	61850-7-5 and 61850-7-500	IEC61850-7-5		RTE	In Progress	Normal		New LN of group L (as "LTED") to represent the dynamic topology of the substation.	02/29/2024 09:07 AM
6725	61850-7-5 and 61850-7-500	IEC61850-7-5		RTE	In Progress	Normal		Simultaneous change of InRef.setSrcRef and InRef.setSrcCB for dynamic commutation	02/29/2024 09:07 AM
6724	Client	Issues			Resolved	Normal		GOOSE Subscriber sGos12 test expects DUT to _send_ a GOOSE message	08/06/2024 08:49 AM
6721	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		SPiN-MDAS	02/24/2024 11:09 AM
6720	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		SPiN-CNAS	02/24/2024 11:10 AM
6719	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		SPiN-CNAS	02/24/2024 11:11 AM
6718	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		SPiN-CMAS	02/24/2024 10:52 AM
6717	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		PowerLogic™ P5F30 protection relays	02/24/2024 10:42 AM
6716	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		ETR600-T	02/24/2024 10:35 AM
6715	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		ETR600-BC	02/24/2024 10:29 AM
6714	IEC TC57 WG10 Future Work	WG10 Future Work		IEC PAS 61850-90-3	New	Normal		Improve the models used for power regulation	02/20/2024 11:04 AM
6712	WG13 Issues	CIM Issues			Review	Normal		UML descriptions for <<Primitive>> types in the Domain package need review and references to W3C and other standards migration into IS publications.	09/16/2024 02:06 PM
6709	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		DRTS 66L	02/13/2024 10:10 AM

#	Project	Tracker	ID	Source	Status	Priority	Standard(s)	Subject	Updated
6708	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		DRTS 66L	02/13/2024 10:09 AM
6707	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		SLP-K140	02/11/2024 10:55 AM
6706	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		STP-K120	02/10/2024 11:35 AM
6705	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		VIPAMj3500II-TR	02/10/2024 10:43 AM
6704	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		VIPAM3500plusFM	02/10/2024 10:38 AM
6699	61850-7-5 and 61850-7-500	IEC61850-7-5			New	Normal		Behavior of a function while being dynamically blocked	06/13/2024 08:28 AM
6698	61850-7-5 and 61850-7-500	IEC61850-7-5			New	Normal		Integrate work from AHTF Control Between Functions	02/07/2024 02:29 AM
6696	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		REX610	02/05/2024 07:49 AM
6695	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		PCS-221S Merging Unit	02/05/2024 06:50 AM
6694	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		PCS-902S Line Distance Relay	02/05/2024 08:53 AM
6692	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		PowerLogic™ P3	02/03/2024 11:00 AM
6691	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		PowerLogic™ P3U30	02/03/2024 10:55 AM
6690	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		PCS-9710S Remote Terminal Unit	02/03/2024 10:49 AM
6689	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		PowerLogicTM P3	02/03/2024 10:19 AM
6688	Client	Issues			Resolved	Normal		cSrvN10 - Ed1 specific error codes do not exist for MMS GetNameList	04/02/2024 08:42 AM
6687	61850-7-5 and 61850-7-500	IEC61850-7-5		SEL	Waiting for Release	Normal		Incorrect signal direction for GOOSE messages between CSWI and XCBR	02/29/2024 08:10 AM
6686	61850-7-5 and 61850-7-500	IEC61850-7-5		Tissue #1892	New	Normal		Description of the different control methods to change position of OLTC (in automatic, manual modes)	01/23/2024 11:02 AM
6685	GOOSE Performance	Issues			Resolved	Normal		Device need to be certified for Ed2.1 server first	06/11/2024 08:28 AM
6684	61850-7-5 and 61850-7-500	IEC61850-7-5		discussion	New	Normal		Proposal to deprecate 'LocSta' in X and Y group LN classes	01/22/2024 02:50 AM
6683	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		Prometer 540	01/21/2024 11:03 AM
6682	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		NS3560	01/22/2024 07:08 AM

#	Project	Tracker	ID	Source	Status	Priority	Standard(s)	Subject	Updated
6681	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		NSR-385AG	01/21/2024 10:50 AM
6679	WG14 Part 11 Issues	CIM Issues			Open	Normal		Document class description	06/19/2024 07:46 AM
6678	WG14 Part 11 Issues	CIM Issues			New	Normal		Refactoring Outage Class Modeling	01/16/2024 11:45 AM
6676	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		P841 (GE MiCOM Agile P841)	01/13/2024 08:37 AM
6675	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		Prometer 100	01/13/2024 08:27 AM
6673	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		G-ISD	01/08/2024 09:12 AM
6672	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		Apex 540	01/08/2024 08:48 AM
6671	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		DRTS 66L Test SEt	01/08/2024 10:35 AM
6670	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		DRTS 66L Test Set	01/08/2024 10:36 AM
6669	Market Management	CIM Issues			New	Normal		Add VATLevel attribute to ChargeType	01/05/2024 09:17 AM
6668	Market Management	CIM Issues			New	Normal		Add VATObliged attribute to ChargeType	01/05/2024 09:03 AM
6667	Market Management	CIM Issues			New	Normal		Add an association from ChargeType to Period	01/05/2024 07:58 AM
6666	Market Management	CIM Issues			New	Normal		Add PhaseCount to ESMP	01/05/2024 07:27 AM
6665	Market Management	CIM Issues			New	Normal		Add ChargeGroup to ESMP and move ChargeGroup to MarketCommon	01/05/2024 07:08 AM
6664	Market Management	CIM Issues			New	Normal		Add an association from MktActivityRecord to ChargeGroup	01/05/2024 06:44 AM
6662	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		PowerLogicTM P7	12/28/2023 08:44 AM
6661	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		REX615	12/28/2023 08:38 AM
6660	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		PSF640 Feeder Protection and Control	12/28/2023 08:10 PM
6659	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		CSI-200E-ER	12/28/2023 08:15 AM
6656	CIM Joint Issues	CIM Issues			New	Normal		Add altitudeCompensation to EndDeviceInfo	12/21/2023 10:20 AM
6655	Client	Issues			Resolved	Normal		cLogN5 is missing in table A4.2 and certificate template	01/09/2024 08:28 AM
6654	Client	Issues			Resolved	Normal		Tracking numbering mismatch Ed2 <> Ed2.1	01/09/2024 08:27 AM
6653	Server	Issues			Rejected	Normal		sFt2c does deletable means everything else is not deletable	01/09/2024 08:19 AM
6649	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		HGMAP-BCS	12/16/2023 10:49 AM

#	Project	Tracker	ID	Source	Status	Priority	Standard(s)	Subject	Updated
6648	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		DCAP-6701	12/16/2023 10:45 AM
6647	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		DCAP-6701	12/16/2023 10:32 AM
6646	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		SPiN-IMCU	12/16/2023 09:27 AM
6645	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		F8300	12/16/2023 09:21 AM
6644	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		DCAP-6701	12/13/2023 09:13 AM
6643	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		AXC F 2152	12/13/2023 08:42 AM
6642	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		AXC F 3152	12/13/2023 08:37 AM
6641	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		Arkens PR Line L301	12/13/2023 08:26 AM
6640	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		ECU-4784	12/13/2023 07:59 AM
6639	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		ECU-4784	12/13/2023 07:55 AM
6638	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		HP-Z8-G4	12/13/2023 07:48 AM
6637	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		PCM600	01/21/2024 10:44 AM
6631	SCL Tooling	Issues			Resolved	Normal		tTf1 (mustUnderstand) for the ICT test needs clarification	01/09/2024 08:59 AM
6629	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		T-MU MERGING UNIT - IED	12/09/2023 11:47 AM
6628	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		EnOSTM Monitoring & Control	12/09/2023 11:22 AM
6627	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		CSC-285 - Multifunction Voltage Protection IED	12/09/2023 11:14 AM
6626	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		CSC-283 - Motor Protection IED	01/08/2024 08:34 AM
6625	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		CSC-281 Multifunction Feeder Protection LED	12/09/2023 11:10 AM
6624	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		CDP0100	12/09/2023 11:02 AM
6623	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		CPD0100	12/09/2023 11:03 AM

#	Project	Tracker	ID	Source	Status	Priority	Standard(s)	Subject	Updated
6622	IEC 61850 TPWG	Bug			Rejected	Normal		Test case Ttf1 (mustUnderstand) for the ICT conformance test needs clarification	12/12/2023 08:19 AM
6617	SCL Tooling	Issues			In Progress	Normal		tlieN1 - can a popup warning be considered as 'not allowed'	10/01/2024 08:15 AM
6607	61850-7-5 and 61850-7-500	IEC61850-7-5		RTE	New	Normal		Create DO indicating the source of synchronisation	11/21/2023 08:49 AM
6606	61850-7-5 and 61850-7-500	IEC61850-7-5		RTE	New	Normal		CPU monitoring	11/21/2023 08:40 AM
6603	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		BCU 500	02/05/2024 08:52 AM
6602	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		GIPAM1000	11/22/2023 07:33 AM
6597	CIM Joint Issues	CIM Issues			New	Normal		MarketManagement::Quantity has attribute and relation with the same name "quantity"	11/14/2023 08:00 AM
6596	IEC 61850 User Feedback Task Force	Bug			Resolved	Normal		Simulation Mode with Centralized Protection	11/21/2023 08:32 AM
6594	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		YH-HSA-OPD	11/09/2023 07:23 AM
6593	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		YH-HSA-LID	11/09/2023 07:16 AM
6592	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		ZEN-LS002	11/09/2023 07:16 AM
6591	Server	Issues			Rejected	Normal		sSg11 - Non-volatile property test (for various FCs)	11/14/2023 08:38 AM
6590	Server	Issues			Rejected	Normal		sGopN2 - The clear meaning of too large a dataset	11/14/2023 08:58 AM
6589	Server	Issues			Rejected	Normal		Create DataSets with Multiple Clients (for example, sDsN4)	11/14/2023 08:48 AM
6588	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		ECU-4784	11/08/2023 07:11 PM
6587	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		ECU-4784	11/08/2023 07:06 PM
6586	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		HP-Z8-G4	11/08/2023 07:07 PM
6585	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		DW-SPiN-LID	11/08/2023 08:32 AM
6583	WG14 Part 4 Issues	CIM Issues			New	Normal		Inheritance of Tower and Pole	11/07/2023 02:05 PM
6582	WG14 Part 4 Issues	CIM Issues			New	Normal		May need to add "kind" attribute to OverheadStructure to be consistent with UndergroundStructure.kind	11/07/2023 02:04 PM
6577	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		P14DL	08/22/2024 06:54 AM
6576	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		ZEN-WT001	11/03/2023 06:14 PM

#	Project	Tracker	ID	Source	Status	Priority	Standard(s)	Subject	Updated
6575	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		ZEN-LS001	11/03/2023 06:15 PM
6574	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		WTG001 Hardware Server	11/03/2023 12:59 PM
6573	CIM Joint Issues	CIM Issues			New	Normal		Profile class duplicates	11/03/2023 03:34 AM
6572	WG14 Part 11 Issues	CIM Issues			New	Normal		IEC61968CIMVersion class is in triplicate	11/02/2023 04:07 PM
6568	Server	Issues			Rejected	Normal		The definition of LTMS.TmSrc is different in the actual AMD1 and Consolidated Version - 1846	11/14/2023 08:37 AM
6565	Server	Issues			Rejected	Normal		Added more precise qualifications to TmSrcTyp - 1883	11/14/2023 09:03 AM
6562	61850-7-5 and 61850-7-500	IEC61850-7-5		Redmine: 6155	New	Normal		Missing LN for Miniature Circuit Breaker (MCB)	10/26/2023 05:17 AM
6560	61850-7-5 and 61850-7-500	IEC61850-7-5		Redmine: 6443	New	Normal		Multiple information sources	10/26/2023 04:02 AM
6559	61850-7-5 and 61850-7-500	IEC61850-7-5		Redmine: 6443	New	Normal		Modelling of a Lockout/trip seal-in relay	06/13/2024 07:47 AM
6558	61850-7-5 and 61850-7-500	IEC61850-7-5		Redmine: 6443	New	Normal		How to model composed functions	10/26/2023 04:01 AM
6557	61850-7-5 and 61850-7-500	IEC61850-7-5		Redmine: 6443	New	Normal		Modelling of various MCB trips	06/13/2024 08:25 AM
6556	61850-7-5 and 61850-7-500	IEC61850-7-5		Redmine: 6443	New	Normal		How to impact the data quality of a data with respect to the communication links, the intermediate processing, the device hosting it.	10/26/2023 04:00 AM
6555	61850-7-5 and 61850-7-500	IEC61850-7-5			New	Normal		Behaviour of output contacts when LN is in blocked mode	02/07/2024 03:14 AM
6554	61850-7-5 and 61850-7-500	IEC61850-7-5			Waiting for Release	Normal		SwModKey seems to overwrite the CheckCondition.interlockCheck	02/29/2024 07:52 AM
6552	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		P14DZ	10/25/2023 09:42 AM
6551	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		STC-K120	10/25/2023 09:23 AM
6550	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		VIPAM7000	10/25/2023 09:16 AM
6545	61850-7-5 and 61850-7-500	IEC61850-7-5		TC92 WG2	Waiting for Release	Normal		Propagation of detailQual	02/29/2024 07:17 AM
6540	WG14 Part 11 Issues	CIM Issues			Review	Normal		Class names for ElectronicAddress and TelephoneNumber	10/17/2023 04:35 AM
6537	61850-7-5 and 61850-7-500	IEC61850-7-5			New	Normal		Harmonizing expressions in 7-500 Ed.1	06/13/2024 08:20 AM
6536	Market Management	CIM Issues			New	Normal		Add an association from ChargeType to MarketParticipant	09/28/2023 10:17 AM
6535	Market Management	CIM Issues			New	Normal		Add ChargeComponent to IEC 62325-351	09/28/2023 10:58 AM

#	Project	Tracker	ID	Source	Status	Priority	Standard(s)	Subject	Updated
6534	Market Management	CIM Issues			New	Normal		Add an association from Series to ChargeType	12/19/2023 10:32 AM
6533	Market Management	CIM Issues			New	Normal		Add ChargeType to IEC 62325-351	09/28/2023 10:56 AM
6532	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		ZEN-WT001	09/26/2023 09:38 AM
6531	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		Superconductivity IED ZEN-LS001	09/26/2023 09:33 AM
6530	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		Easergy MiCOM P746 Numerical Busbar Protection	09/26/2023 08:36 AM
6522	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		SEL-851	09/12/2023 02:41 PM
6521	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		PGC-6060	09/12/2023 02:33 PM
6520	SCL Tooling	Issues			Rejected	Normal		ICT Ed2.1 refers to TICS but there no part 6 tissues	10/31/2023 08:35 AM
6516	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		IM2	09/05/2023 07:49 AM
6515	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		PSF640 Feeder Protection and Control	09/03/2023 03:56 PM
6514	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		ET-CCI	09/03/2023 03:46 PM
6513	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		PowerLogic(TM) P7	09/03/2023 03:39 PM
6510	Market Management	CIM Issues			New	Normal		Add an association between MarketEvaluationPoint and MktPSRType	08/21/2023 10:11 AM
6509	WG14 Part 4 Issues	CIM Issues			Open	Normal		WorkAsset, Vehicle, Tool	10/14/2023 10:43 AM
6506	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		SOC-K110	08/23/2023 06:54 AM
6505	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		ETR500-FV	08/16/2023 10:56 AM
6504	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		SBP-K110	08/16/2023 10:57 AM
6503	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		BCU-50-M	08/15/2023 02:26 PM
6502	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		Easergy MiCOM P443 Fast Multifunction Distance Protection Relay	08/03/2023 03:39 PM
6501	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		K-IED T100	08/03/2023 03:32 PM
6500	61850-7-5 and 61850-7-500	IEC61850-7-5			In Progress	Normal		Parameters to enforce the checking of interlocking and synchronism	10/05/2023 08:57 AM
6499	61850-7-5 and 61850-7-500	IEC61850-7-5			In Progress	Normal		Explanation text on the application of check conditions	10/05/2023 08:57 AM

#	Project	Tracker	ID	Source	Status	Priority	Standard(s)	Subject	Updated
6498	61850-7-5 and 61850-7-500	IEC61850-7-5			Waiting for Release	Normal		Explanation text on the usage of SwModKey	02/29/2024 07:52 AM
6497	61850-7-5 and 61850-7-500	IEC61850-7-5			New	Normal		Explanation text of IEC/TR 61850-7-500 clause 10.1.1.2	08/02/2023 10:43 AM
6496	61850-7-5 and 61850-7-500	IEC61850-7-5			Waiting for Release	Normal		Typo in section 13.3	06/13/2024 08:12 AM
6495	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		SEL-451-6	07/28/2023 12:45 PM
6494	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		SEL-451-5	07/28/2023 12:39 PM
6493	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		WAGO 750-8212/0040-0001	07/28/2023 12:31 PM
6492	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		PS700 v2 - FACTS Main Controller	07/28/2023 12:32 PM
6490	Client	Issues			Resolved	Normal		UCAiug requires Ed2Amd1 Jan 2024 - expect testlabs/toolvendors need more time	08/22/2023 08:16 AM
6489	GOOSE Performance	Issues			Resolved	Normal		Reducing the needed resources for time correlated subscribed GOOSE not used for ping-pong	01/23/2024 08:05 AM
6487	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		Protection IED (SUF-K110)	07/26/2023 10:56 AM
6486	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		ECU-4784	07/26/2023 10:35 AM
6485	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		ECU-4784	07/26/2023 10:25 AM
6484	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		xGrids Transfer DAUMIT_ISD	07/26/2023 10:19 AM
6483	Server	Issues			Resolved	Normal		Need to be able to test 61850-7-420 (Ed2)	06/10/2024 09:25 AM
6482	61850-7-5 and 61850-7-500	IEC61850-7-5			In Progress	Normal		Figures 36, 37, 38	09/14/2023 07:56 AM
6481	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		AXC F 3152	07/19/2023 07:30 AM
6480	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		SA IMD YSSMD-7300	07/19/2023 07:22 AM
6479	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		SA IMD DAONSYS MSA-SMD-ED2	07/19/2023 08:55 PM
6478	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		FTU-R200i	07/19/2023 07:08 AM
6477	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		YH-SAMDD	07/19/2023 07:08 AM

#	Project	Tracker	ID	Source	Status	Priority	Standard(s)	Subject	Updated
6475	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		SAM600 Process Interface Unit	07/11/2023 11:15 AM
6474	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		SAM600 Process Interface Unit	08/24/2023 11:31 AM
6472	Server	Issues			Rejected	Normal		Concept of smpRate for input analogue signal acquisition is misleading (Tissue 1857)	08/22/2023 08:22 AM
6471	Client	Issues			Resolved	Normal		Select.response+ (Tissue 1753)	08/22/2023 08:10 AM
6467	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		MRD-HB (101PYA) Biased differential relay	07/10/2023 03:38 PM
6466	Server	Issues			Rejected	Normal		TP1.2 sSvs1 step 6 shall be removed	07/11/2023 08:33 AM
6465	GOOSE Performance	Issues			Resolved	Normal		The Ed2 GOOSE performance also apply for Ed2Amd1	08/08/2023 08:42 AM
6464	Client	Issues			Resolved	Normal		cSrv5 change the condition to GetDataValues or Reporting	07/11/2023 08:38 AM
6463	Client	Issues			Resolved	Normal		cSrv7, cSvrN3 some clients only read DA (not DO)	07/25/2023 08:07 AM
6450	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		AXRTU62351CCI_UP-DM_DC_MC_UVR-P_Q_F-PMU-BMU-CU_MCE_DCM/ET-CCI	06/22/2023 08:44 AM
6449	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		SIPROTEC V4 7SJ80 Overcurrent protection	06/21/2023 10:15 AM
6419	IEC TC57 WG10 Future Work	WG10 Future Work		WG10 Fall workshop	New	Normal		Logical Nodes for SLD/Topology Aware Functions	02/09/2024 04:55 AM
6408	61850-7-5 and 61850-7-500	IEC61850-7-5			New	Normal		Clarification of addCause	06/20/2023 08:37 AM
6407	61850-7-5 and 61850-7-500	IEC61850-7-5			New	Normal		Schedules - allow 3 values per time point	06/20/2023 08:36 AM
6406	61850-7-5 and 61850-7-500	IEC61850-7-5			New	Normal		Schedules - add optional data objects to support irregular interval schedules	06/20/2023 08:36 AM
6405	61850-7-5 and 61850-7-500	IEC61850-7-5			New	Normal		Schedules - allow updates to single values while schedules are running	06/20/2023 08:35 AM
6395	61850-7-5 and 61850-7-500	IEC61850-7-5			Waiting for Release	Normal		Figure 15 SelOpn and SelCls are incorrect	02/29/2024 08:06 AM
6394	61850-7-5 and 61850-7-500	IEC61850-7-5			In Progress	Normal		Clarifications on the local/remote concept 8/8	09/14/2023 08:04 AM
6393	61850-7-5 and 61850-7-500	IEC61850-7-5			In Progress	Normal		Clarifications on the local/remote concept 7/8	10/05/2023 08:55 AM
6392	61850-7-5 and 61850-7-500	IEC61850-7-5			In Progress	Normal		Clarifications on the local/remote concept 6/8	10/05/2023 08:55 AM
6391	61850-7-5 and 61850-7-500	IEC61850-7-5			In Progress	Normal		Clarifications on the local/remote concept 5/8	10/05/2023 08:55 AM
6390	61850-7-5 and 61850-7-500	IEC61850-7-5			In Progress	Normal		Clarifications on the local/remote concept 4/8	10/05/2023 08:55 AM

#	Project	Tracker	ID	Source	Status	Priority	Standard(s)	Subject	Updated
6389	61850-7-5 and 61850-7-500	IEC61850-7-5			In Progress	Normal		Clarifications on the local/remote concept 3/8	10/05/2023 08:55 AM
6388	61850-7-5 and 61850-7-500	IEC61850-7-5			In Progress	Normal		Clarifications on the local/remote concept 2/8	10/05/2023 08:55 AM
6387	61850-7-5 and 61850-7-500	IEC61850-7-5			New	Normal		S/S related applications: Auxiliary circuit supervision	06/14/2023 08:20 AM
6386	61850-7-5 and 61850-7-500	IEC61850-7-5			New	Normal		Voltage protection: Overvoltage protection - 3ph operate	06/14/2023 08:20 AM
6385	61850-7-5 and 61850-7-500	IEC61850-7-5			New	Normal		Voltage protection: Undervoltage protection - 3ph operate	06/14/2023 08:19 AM
6384	61850-7-5 and 61850-7-500	IEC61850-7-5			New	Normal		New controllable DO in RREC to define the mode of the recloser of the circuit breaker	06/14/2023 08:19 AM
6383	61850-7-5 and 61850-7-500	IEC61850-7-5			New	Normal		Single phase and multi phase trip indication for the autorecloser	06/14/2023 08:19 AM
6382	61850-7-5 and 61850-7-500	IEC61850-7-5			New	Normal		Clarification on the ctlModel 1/3	06/14/2023 08:18 AM
6380	61850-7-5 and 61850-7-500	IEC61850-7-5			New	Normal		Clarification on the ctlModel 2/3	06/14/2023 08:18 AM
6379	61850-7-5 and 61850-7-500	IEC61850-7-5			New	Normal		Clarification on the ctlModel 3/3	06/14/2023 08:17 AM
6378	61850-7-5 and 61850-7-500	IEC61850-7-5			In Progress	Normal		Clarifications on the local/remote concept 1/8	10/05/2023 08:56 AM
6376	61850-7-5 and 61850-7-500	IEC61850-7-5			New	Normal		LN PDIF – setting for nominal current	02/13/2024 05:59 AM
6375	61850-7-5 and 61850-7-500	IEC61850-7-5			In Progress	Normal		XCBR LN new DO to describe withdrawable circuit breaker	08/24/2023 07:57 AM
6374	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		Protection IED (K-IED BC100)	06/12/2023 09:58 AM
6373	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		Protection IED (K-IED V100)	06/12/2023 09:45 AM
6370	IEC 61850 User Feedback Task Force	Improvement			Resolved	Normal		SBOns to be deprecated in future.	06/20/2023 09:39 AM
6365	Server	Issues			Rejected	Normal		Considering PTP version 2.1	07/11/2023 08:12 AM
6364	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		SA-ICD (Substation Automation Information Connecting Device) DW-IPC-A-20000	05/31/2023 11:27 AM
6363	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		SA ICD (Substation Automation Information Connecting Device) DW-IPC-A-20000	05/31/2023 11:27 AM
6362	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		SA-OPD (Substation Automation Operation Processing Device) Z8 G4	05/31/2023 11:16 AM

#	Project	Tracker	ID	Source	Status	Priority	Standard(s)	Subject	Updated
6361	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		APEX 150 P3E	05/31/2023 11:07 AM
6360	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		MPU70 Nexus OnCore Control Module	05/31/2023 11:00 AM
6354	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		IED T-IED 170kV	05/24/2023 12:34 PM
6353	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		IED T-IED 23kV	05/25/2023 06:29 AM
6352	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		PROTECTION IED VIPAM5000-KF PT	05/24/2023 12:16 PM
6351	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		PROTECTION IED VIPAM5000-KF V1	05/24/2023 12:11 PM
6349	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		Protection IED (SBP-K110)	05/24/2023 11:51 AM
6347	WG13 Issues	CIM Issues			In Progress	Normal		[GMDM #15] Add a limited amount of ‘structure’ modeling to distribution grid models	09/19/2024 10:15 AM
6340	DNP Conformance Certificates	DNP Conformance Certificate			Approved	Normal		CYG SUNRI PRS-3351	05/19/2023 10:38 AM
6338	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		xGrids Transfer DAUMIT_ISD	05/16/2023 02:33 PM
6337	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		Siemens 7SS85	05/16/2023 02:26 PM
6336	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		6MD85 (SIP 5) - BAY CONTROLLER	05/12/2023 06:32 AM
6327	SCL Tooling	Issues			Resolved	Normal		tTf2 - export CID file only for Ed2.1?	05/16/2023 08:20 AM
6326	SCL Tooling	Issues			Resolved	Normal		tIie1 - remove step 10-14 to undo previous changes	05/16/2023 08:09 AM
6325	SCL Tooling	Issues			Resolved	Normal		PIXIT missing entries on tIie1 "when supported"	05/16/2023 08:04 AM
6324	SCL Tooling	Issues			Rejected	Normal		sCnf6 - not all extRef require intAddr not referring to external device	05/16/2023 08:44 AM
6323	SCL Tooling	Issues			Resolved	Normal		tTtf5 IED name=None is not allowed tissue #1365	05/02/2023 08:20 AM
6321	CIM Issues	CIM Issues			New	Normal		Update the description of MktActivityRecord	04/20/2023 03:46 AM
6317	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		Siemens 7SL86	04/13/2023 07:26 AM
6315	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		SA IMD DW-IPC-A-10000	04/11/2023 07:45 AM
6314	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		Protection IED (PAC-XG100)	04/09/2023 07:54 AM
6313	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		Protection IED (PAC-XF100)	04/09/2023 07:51 AM
6312	WG14 Issues	CIM Issues			Review	Normal		Clarify x, y, z attributes in PositionPoint	10/14/2023 10:40 AM

#	Project	Tracker	ID	Source	Status	Priority	Standard(s)	Subject	Updated
6311	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		PSL 603U	04/02/2023 12:12 PM
6310	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		MiCOM P40 Agile	03/30/2023 01:41 PM
6309	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		MiCOM P40 Agile	03/30/2023 01:37 PM
6308	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		K-IED ABK100	03/29/2023 04:55 PM
6307	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		(SUR5000-LP	03/29/2023 04:51 PM
6306	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		K-IED ABK100	03/29/2023 04:55 PM
6305	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		Protection IED (SUR5000-LP)	03/29/2023 04:40 PM
6302	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		REC670 Bay control	03/27/2023 10:47 AM
6301	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		REC670 Bay control	03/27/2023 10:42 AM
6300	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		DW-IPC-A-50000 SA LID (Substation Automation Local Information processing Device)	03/26/2023 10:38 AM
6299	WG13 Issues	CIM Issues			In Progress	Normal		OperationalLimitType; add an attribute to hold the "type" of limit, such as Emergency, Normal, ...	09/18/2024 12:05 PM
6293	Market Management	CIM Issues			Open	Normal		Add energyFlowCategory (string) to the AccountingPoint class	09/26/2024 09:01 AM
6292	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		Siemens 7UT86 TRANSFORMER DIFFERENTIAL PROTECTION	03/17/2023 08:14 AM
6290	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		SG B750	03/15/2023 02:49 PM
6289	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		PST 671U	03/15/2023 02:44 PM
6288	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		HSC RTU for Industrial Automation and Control Systems	03/10/2023 01:33 PM
6287	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		Teamware CCI-Central Plant controller	03/10/2023 01:23 PM
6286	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		Landis Gyr AG E65C CU-XE Grid Edge Gateway with S650 and E660	03/10/2023 01:24 PM
6285	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		Teleport: Real-time controller of energy assets	03/10/2023 01:10 PM
6284	WG14 Issues	CIM Issues			Open	Normal		Need to refine modeling of special need information	10/14/2023 10:39 AM
6275	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		PSL 641UX	02/28/2023 07:43 AM

#	Project	Tracker	ID	Source	Status	Priority	Standard(s)	Subject	Updated
6273	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		xGrids Transfer KPG-v1	02/24/2023 07:40 AM
6272	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		xGrids Transfer KPG-v1	02/24/2023 07:40 AM
6271	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		SUR-K220 Protection IED	06/01/2023 07:46 AM
6270	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		TC-BCU21 Bay Control Unit (BCU)	02/22/2023 08:01 AM
6264	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		SIPROTEC 5 - 7VU85 High Speed Busbar Transfer	02/05/2024 08:52 AM
6261	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		xGrids Transfer YH-ISD	02/13/2023 07:18 AM
6249	CIM Issues	CIM Issues			New	Normal		Update CIM namespace	02/06/2023 01:17 PM
6245	WG14 Part 3 Issues	CIM Issues			New	Normal		It is not possible to convey that an UnplannedOutage is frozen (prediction is suspended).	02/01/2023 02:29 PM
6244	WG14 Part 3 Issues	CIM Issues			New	Normal		Part 3 should specify that you can use 'updated' verb	01/31/2023 03:32 PM
6243	WG14 Part 3 Issues	CIM Issues			New	Normal		UnplannedOutages is missing OutageArea and AreaKind	01/31/2023 03:29 PM
6242	WG14 Part 3 Issues	CIM Issues			New	Normal		OutageArea has nowhere to put the name of the outage area	01/31/2023 03:26 PM
6241	WG14 Part 3 Issues	CIM Issues			New	Normal		UnplannedOutages does not provide a way to capture affected kVA for IEEE load-based indices	01/31/2023 03:23 PM
6240	WG14 Part 3 Issues	CIM Issues			New	Normal		UnplannedOutages has no way to indicate that the outage should be excluded from reliability reporting.	01/31/2023 02:59 PM
6239	WG14 Part 3 Issues	CIM Issues			New	Normal		UnplannedOutages profile needs ability to capture de-energized and energized times per UsagePoint	01/31/2023 02:26 PM
6238	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		HMI VICOM-PES	01/30/2023 08:07 AM
6237	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		IED VIPAM-PBAS	01/30/2023 08:02 AM
6236	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		SA LID (Substation Automation Local Information processing Device) ECU-4784	02/17/2023 04:01 PM
6235	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		SA MD (Substation Automation Monitoring & diagnosis Device) VertexCOM-MD3	02/17/2023 03:59 PM
6234	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		SA ICD (Substation Automation Information Connecting Device) ECU-4784	02/17/2023 03:58 PM
6233	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		SA ICD (Substation Automation Information Connecting Device) ECU-4784	02/15/2023 09:53 AM
6232	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		SA OPD (Substation Automation Operation Processing Device) Z8	01/30/2023 07:33 AM

#	Project	Tracker	ID	Source	Status	Priority	Standard(s)	Subject	Updated
6231	Market Management	CIM Issues			New	Normal		Add the new datatype ESMPDataTypes / SettlementMethodType_String and enumeration	01/30/2023 10:21 AM
6229	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		MiCOM P40 Agile	01/25/2023 08:16 AM
6226	IEC 61850 User Feedback Task Force	Bug			Resolved	Normal		In the downgrading rules from ed 2.1 to ed 2.0 in part 6, it is mentionned to exclude ORS CDC (I.4.2.4). Why CDCs: CST, VSD and TCS that were also added in ed2.1 are not mentionned to be excluded also ?	06/05/2023 01:58 AM
6212	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		MiCOM P40 Agile Enhanced P14D	01/12/2023 08:25 AM
6208	Server	Issues			Rejected	Normal		sSvsN2 in TP1.2 does not check the situation where the DUT checks ConfRev	03/21/2023 08:20 AM
6206	Server	Issues			Rejected	Normal		Type and size of Length field value (TLV) encoding in SV	01/11/2023 06:19 AM
6205	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		SNI 61850 Server Protocol Converter (SNIIT)	01/19/2023 08:37 AM
6204	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		ETCPU650 DC Protection Relay	01/03/2023 08:18 AM
6200	SCL Tooling	Issues			Resolved	Normal		tTf1 change Ed2/2007B to Ed2.1/2007B4	01/24/2023 08:33 AM
6199	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		MiCOM 940 Agile P546 Line Differential Relay	12/14/2022 08:20 AM
6197	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		MICOM 940 Agile P746	12/06/2022 02:37 PM
6196	WG14 Part 4 Issues	CIM Issues			Review	Normal		Facility Kind	07/03/2023 08:05 AM
6195	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		TC-CCI Power Plant Control System	12/02/2022 02:18 PM
6194	WG14 Part 3 Issues	CIM Issues			New	Normal		PlannedOutageNotifications needs to support energize/de-energize time/date per UsagePoint.	11/29/2022 12:50 PM
6191	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		SIPROTEC 7SJ686	11/29/2022 08:15 AM
6187	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		UR N60 Edition 2 Server	11/24/2022 08:18 AM
6183	DNP Conformance Certificates	DNP Conformance Certificate			Approved	Normal		Lucy Electric Gemini 3 mini	11/13/2022 11:34 PM
6182	DNP Conformance Certificates	DNP Conformance Certificate			Approved	Normal		IDS ACOS 750	11/13/2022 11:25 PM
6181	DNP Conformance Certificates	DNP Conformance Certificate			Approved	Normal		Schneider Electric SCADAPack 535E	11/13/2022 11:18 PM
6180	DNP Conformance Certificates	DNP Conformance Certificate			Approved	Normal		Moxa MGate 5109	11/13/2022 11:13 PM

#	Project	Tracker	ID	Source	Status	Priority	Standard(s)	Subject	Updated
6179	DNP Conformance Certificates	DNP Conformance Certificate			Approved	Normal		Instituto Nacional de Electricidad y Energias Limpias UCM-CFE	11/13/2022 11:06 PM
6177	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		PNC FTU-P200T Server Edition 2	11/09/2022 07:00 AM
6176	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		Schneider Easergy MiCOM P545 Edition 2 Server	11/08/2022 08:39 AM
6174	Server	Issues			Rejected	Normal		Amend sCtl7 to test both interlocking check and check synchronizing ?	02/07/2023 08:24 AM
6173	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		FTU PNC Technologies Edition 2 Server	11/02/2022 07:36 AM
6172	Client	Issues			Resolved	Normal		client check bits must be tested	12/13/2022 08:34 AM
6171	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		REX640 Protection and Control Relay	10/27/2022 12:12 PM
6170	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		EcoStruxure Power Operation Edition 2 Client	10/25/2022 01:25 PM
6168	Market Management	CIM Issues			Open	Normal		Deprecate the three attributes in Series	04/19/2023 09:48 AM
6152	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		xGrids Transfer YH-ISD	10/11/2022 01:12 PM
6150	DNP Conformance Certificates	DNP Conformance Certificate			Approved	Normal		Ingeteam INGESAS IC3	10/31/2022 08:54 AM
6149	DNP Conformance Certificates	DNP Conformance Certificate			Approved	Normal		SEL-411L-0	07/27/2023 09:57 AM
6147	WG13 Issues	CIM Issues			In Progress	Normal		[GMDM #1] Streamlining of tank-based transformer modelling	09/18/2024 09:26 AM
6146	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		Siemens 6MD85	01/19/2023 08:38 AM
6141	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		FOX612 with BIGO1 IEC61850 interface Server Edition 2	09/22/2022 07:28 PM
6138	WG14 Part 4 Issues	CIM Issues			Open	Normal		WorkAsset current location	07/10/2023 10:27 AM
5976	WG13 Issues	CIM Issues			Open	Normal		CIM-61850 Harmonization - revise control model for DiscreteCommand (e.g. raise/lower)	09/16/2024 02:53 PM
5975	WG13 Issues	CIM Issues			Open	Normal		CIM-61850 Harmonization - define a standard list of control types	09/16/2024 02:55 PM
5974	WG13 Issues	CIM Issues			Open	Normal		CIM-61850 Harmonization - allow direct association IED to MeasurementValue	09/16/2024 02:55 PM
5972	WG13 Issues	CIM Issues			Open	Normal		CIM-61850 Harmonization - define a method of using IEC 61850 data object names as measurement types	09/16/2024 02:56 PM
5969	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		VITZRO VIPAM-CU Edition 2 Server	09/22/2022 07:32 AM
5968	IEC 61850 User Feedback Task Force	Improvement			Resolved	Normal		Change the diagrams in 7-500 to not use yellow lines	06/05/2023 01:58 AM

#	Project	Tracker	ID	Source	Status	Priority	Standard(s)	Subject	Updated
5966	IEC TC57 WG10 Future Work	WG10 Future Work		EDF	New	Normal		Indicate typical SIUnit for every DO with CDC MV would help users + Add a dedicated attribute in NSD files instead of having it in the description ?	02/09/2024 04:02 AM
5962	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		Siemens SIPROTEC 7SJ66 Multifunction protection Relay	09/12/2022 06:38 AM
5955	IEC 61850 User Feedback Task Force	Improvement		EDF	Resolved	Normal		Indicate typical SIUnit for every DO with CDC MV would help users + Add a dedicated attribute in NSD files instead of having it in the description ?	06/05/2023 01:58 AM
5953	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		PCS-996 DISTURBANCE FAULT RECORDER ED2.0 Server	08/25/2022 07:04 AM
5949	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		e2TANGO-800	09/07/2022 10:04 AM
5926	SCL Tooling	Issues			Resolved	Normal		Review ICT TP	11/29/2022 07:23 AM
5921	General Testing Issues	Improvement			Resolved	Normal		Start using Vendor and Lab Submission Information	09/06/2022 09:33 AM
5920	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		Kalki SYNC 3000 Edition 2 Client	08/05/2022 10:52 AM
5919	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		DS Agile aView Edition 2 Client	08/05/2022 10:39 AM
5918	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		MiCOMP40AgileP44T Edition 2 Server	08/04/2022 06:56 AM
5916	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		XJ Electric Co., Ltd. WYD-811 Microcomputer Tele-control Unit - Edition 2 Client	07/31/2022 12:59 PM
5909	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		VITZRO EM CO., LTD. VIPAM-PB	07/24/2022 03:11 PM
5908	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		AEGIS SERIES Numerical Protection Relay Protection Relay	07/24/2022 03:11 PM
5906	Server	Issues			Rejected	Normal		sCnf51 at least one LPHD	09/06/2022 08:20 AM
5884	CIM Issues	CIM Issues			New	Normal		Modify control model - create DiscreteCommand for enumerations such as raise/lower	07/13/2022 10:45 AM
5881	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		DS Agile aView System HMI [GE Renewable Energy]	07/12/2022 03:27 PM
5879	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		ZLFC [ZIV Aplicaciones y Tecnología SL]	07/05/2022 07:37 PM
5874	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		xGrids Transfer KPG-v1 [KEPCO Knowledge Data & Network Co., Ltd.]	06/28/2022 12:22 PM
5873	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		xGrids Transfer KPG-v1 [KEPCO Knowledge Data & Network Co., Ltd.]	06/28/2022 12:23 PM
5872	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		UR N60 [GE Renewable Energy]	06/28/2022 10:41 AM

#	Project	Tracker	ID	Source	Status	Priority	Standard(s)	Subject	Updated
5868	WG13 Issues	CIM Issues			In Progress	Normal		New BusSegment for busbar modeling	09/19/2024 03:01 PM
5857	WG16 Issues	CIM Issues			Open	Normal		MarketProductType enum values update	08/08/2022 06:03 PM
5847	WG16 Issues	CIM Issues			Open	Normal		IEC62325 Dependency Diagram Update	08/08/2022 05:59 PM
5839	WG16 Issues	CIM Issues			Open	Normal		ResourceCapacity; Propose to use DecimalQuantity for the attributes defaultCapacity, maximumCapacity, minimumCapacity	08/08/2022 05:56 PM
5830	WG16 Issues	CIM Issues			Open	Normal		MarketProductType new enum values	08/08/2022 05:53 PM
5829	WG16 Issues	CIM Issues			Open	Normal		Environmental Profile diagrams moved to Environmental package	08/08/2022 05:52 PM
5818	WG16 Issues	CIM Issues			Open	Normal		Consider enhancing the FuelSource enumeration to include more fuel types	08/17/2022 04:33 AM
5803	WG16 Issues	CIM Issues			In Progress	Normal		Add meterReadingPeriodicity attribute (String) in the MarketEvaluationPoint class	09/15/2022 04:01 PM
5802	WG16 Issues	CIM Issues			Open	Normal		Add scheduledMeterReadingDate attribute (String) in the MarketEvaluationPoint class	08/08/2022 05:44 PM
5794	WG16 Issues	CIM Issues			Open	Normal		MarketParticipant association to MarketRole	08/08/2022 05:40 PM
5764	WG16 Issues	CIM Issues			Open	Normal		Clean up of RegisteredInterTie attributes	08/08/2022 05:21 PM
5762	WG16 Issues	CIM Issues			Open	Normal		RegisteredLoad clean-up of attributes	08/08/2022 05:20 PM
5760	WG16 Issues	CIM Issues			Open	Normal		Addition of new Anode types	08/08/2022 05:20 PM
5751	WG16 Issues	CIM Issues			Open	Normal		Mkt classes review	04/18/2024 11:03 AM
5750	WG16 Issues	CIM Issues			Open	Normal		The characteristics of a MSG Generating Plant uses similar definition as a RegisteredGenerator.	07/19/2022 05:59 PM
5380	WG14 Part 7 Issues	CIM Issues			New	Normal		Customer Installation Management	10/16/2023 01:17 PM
5377	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		MM300 [GE Renewable Energy]	06/10/2022 08:32 AM
5376	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		EVRC2A-NT-610 [ENTEC Electric & Electronic Co., Ltd.]	06/08/2022 10:50 AM
5373	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		MULTILIN B90 [M/s. GE T&D INDIA LIMITED]	06/01/2022 01:44 PM
5370	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		Multilin D60 [GE T&D India Limited]	05/29/2022 08:44 PM
5369	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		Multilin L90 [GE T&D India Limited]	05/27/2022 12:37 PM
5368	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		VIPAM-ARC [VITZRO EM CO., LTD.]	05/27/2022 09:40 AM
5367	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		GRW200 [TOSHIBA Energy Systems & Solutions Corporation]	05/25/2022 09:28 AM
5366	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		MUST DM624 [WOODAM TECH CO., LTD.]	05/18/2022 09:33 AM

#	Project	Tracker	ID	Source	Status	Priority	Standard(s)	Subject	Updated
5364	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		AQ-250: AQ-F255 [Arcteq Relays Ltd.]	05/17/2022 04:45 PM
5363	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		NP950: NPF955 [ICE SAS]	05/17/2022 04:40 PM
5361	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		Mirage Servidor IEC 61850 [Controles S.A.]	05/12/2022 10:10 AM
5360	IEC 61850 Certificate	IEC 61850 Certificate			Approved	Normal		NC61850FEP [NexChal Co., Ltd.]	05/12/2022 09:52 AM

...