

## Issues

#	Project	Tracker	ID	Source	Status	Priority	Standard(s)	Subject	Updated
632	IEC 61850 User Feedback Task Force	Support	8	H30	Resolved	High	IEC 61850-9-2, IEC 61869-9	APPID 0x4000 - Sampled Values	12/05/2023 09:16 AM
6220	IEC TC57 WG10 Future Work	WG10 Future Work			New	Normal	IEC 61850-7-4	Parameters not available in standardized GACP LN - opDITmms, DITmms	10/26/2023 05:00 AM
633	IEC 61850 User Feedback Task Force	Improvement	1	ZIV	Resolved	Normal	IEC 61850-4	Initial values of paramRev and valRev	11/21/2023 09:09 AM
5091	IEC 61850 User Feedback Task Force	Feature	10	H30	Resolved	Normal	IEC 61850-2	Devices types/acronyms	06/05/2023 01:58 AM
5086	IEC 61850 User Feedback Task Force	Feature	10	MH	Resolved	Normal	IEC 61850-7-4 Ed2.1 ,7-5	Clarifications on the local/remote concept 6/8	06/05/2023 01:58 AM
5087	IEC 61850 User Feedback Task Force	Feature	11	MH	Resolved	Normal	IEC 61850-7-4 Ed2.1 ,7-5	Clarifications on the local/remote concept 7/8	06/05/2023 01:58 AM
612	IEC 61850 User Feedback Task Force	Feature	11	RTE	Resolved	Normal	IEC 61850-7-4	Need to create a new LN of group P (Protection), as "PCDP" to represent the Pole Discrepancy Protection.	05/09/2023 09:32 AM
5088	IEC 61850 User Feedback Task Force	Feature	12	MH	Resolved	Normal	IEC 61850-7-4 Ed2.1 ,7-5	Clarifications on the local/remote concept 8/8	06/05/2023 01:58 AM
5089	IEC 61850 User Feedback Task Force	Improvement	13	MH	Resolved	Normal	IEC 61850 7-3 Ed2.1	Extension of CDC ASG	06/05/2023 01:58 AM
618	IEC 61850 User Feedback Task Force	Improvement	14	RTE	Resolved	Normal	IEC 61850-90-3	Evolution of DO SumSqA of LN SPTRExt	05/09/2023 09:32 AM
619	IEC 61850 User Feedback Task Force	Feature	15	RTE	Resolved	Normal		New LN of group L (as "LTED") to represent the dynamic topology of the substation.	05/09/2023 09:32 AM
621	IEC 61850 User Feedback Task Force	Feature	17	RTE	In Progress	Normal	IEC 61850-7-4/7-500	New controllable DO in RREC to define the mode of the recloser of the circuit breaker	05/11/2021 10:08 AM
623	IEC 61850 User Feedback Task Force	Feature	19	RTE	In Progress	Normal		New LN of group L (as "LPLE") representing a group of LED	03/02/2021 09:42 AM
5078	IEC 61850 User Feedback Task Force	Feature	2	MH	Resolved	Normal	IEC 61850-7-1 / 7-2 Ed2.1 / 7-5/7-500	Clarification on the ctlModel 1/3	06/05/2023 01:58 AM
610	IEC 61850 User Feedback Task Force	Improvement	2	RTE	Resolved	Normal	IEC 61850-6	Mapping of another phases system description to the generic phases phsA, phsB, phsC	05/09/2023 09:32 AM
624	IEC 61850 User Feedback Task Force	Support	21	RTE	Resolved	Normal	IEC 61850-6	Clarification of using of ValKind, Vallmport.	05/09/2023 09:32 AM
625	IEC 61850 User Feedback Task Force	Improvement	22	RTE	Resolved	Normal	IEC 61850-7-4	LN RADR evolution	12/05/2023 08:31 AM
626	IEC 61850 User Feedback Task Force	Improvement	23	RTE	Resolved	Normal	TR IEC 61850-90-4, IEC 61850-6	Extension of P-type to describe connexion type (PhysCon)	12/05/2023 08:52 AM
627	IEC 61850 User Feedback Task Force	Feature	29	RTE	Resolved	Normal	IEC 61850-7-4	Activation and deactivation of a function by configuration.	05/09/2023 09:32 AM

#	Project	Tracker	ID	Source	Status	Priority	Standard(s)	Subject	Updated
5079	IEC 61850 User Feedback Task Force	Feature	3	MH	Resolved	Normal	IEC 61850-7-1 Ed2.1, 7-500	Clarification on the ctlModel 2/3	06/05/2023 01:58 AM
629	IEC 61850 User Feedback Task Force	Improvement	35	RTE	Resolved	Normal	IEC TR 61850-90-29	TCTR and TVTR new DO to identify physical terminal allocation in the IED	01/16/2024 08:11 AM
5080	IEC 61850 User Feedback Task Force	Feature	4	MH	Resolved	Normal	IEC 61850-7-1 Ed2.1 ,7-500	Clarification on the ctlModel 3/3	06/05/2023 01:58 AM
667	IEC 61850 User Feedback Task Force	Improvement	4	WG10	Resolved	Normal	IEC 61850-7-4	Report of current active setting group	06/05/2023 01:58 AM
605	IEC 61850 User Feedback Task Force	Improvement	4	H30	In Progress	Normal	IEC 61850-10-3	Test and Simulation mode questions	06/21/2022 02:09 AM
630	IEC 61850 User Feedback Task Force	Improvement	43	RTE	Resolved	Normal	IEC 61850-7-500	XCBR LN new DO to describe withdrawable circuit breaker	05/09/2023 09:32 AM
631	IEC 61850 User Feedback Task Force	Feature	44	RTE	Triage	Normal		Evolution of LN PSCH to build switching on information	08/17/2021 08:03 AM
5081	IEC 61850 User Feedback Task Force	Feature	5	MH	Resolved	Normal	IEC 61850-7-1 Ed2.1/7-4 Ed2.1 Annex B/7-500	Clarifications on the local/remote concept 1/8	06/05/2023 01:58 AM
611	IEC 61850 User Feedback Task Force	Bug	5	RTE	In Progress	Normal	IEC 61850-7-4 / IEC 61850-80-6	Need a new DO (ENUM) to identify the protocol used for the SCADA exchange, in LN ITCI	11/07/2023 08:29 AM
6216	IEC 61850 User Feedback Task Force	Feature	51	RTE	In Progress	Normal	IEC 61850-7-4	Parameters not available in standardized LN - SetPhNum	02/28/2023 09:42 AM
6217	IEC 61850 User Feedback Task Force	Feature	52	RTE	In Progress	Normal	IEC 61850-7-4	Parameters not available in standardized LN - NamAccRtg	02/28/2023 09:42 AM
6218	IEC 61850 User Feedback Task Force	Feature	53	RTE	In Progress	Normal	IEC 61850-7-4	Parameters not available in standardized LN - PhyConnITF	02/28/2023 09:42 AM
6219	IEC 61850 User Feedback Task Force	Feature	54	RTE	In Progress	Normal	IEC 61850-7-4	Parameters not available in standardized LN - VRtg, ARtg and HzRtg	02/28/2023 09:42 AM
6221	IEC 61850 User Feedback Task Force	Feature	56	RTE	In Progress	Normal	IEC 61850-7-4	Parameters not available in standardized GAPC LN - OnOff	02/28/2023 09:42 AM
6222	IEC 61850 User Feedback Task Force	Feature	57	RTE	In Progress	Normal	IEC 61850-7-4	Parameters not available in standardized GAPC LN - SetNb	02/28/2023 09:42 AM
647	IEC 61850 User Feedback Task Force	Support	57	ENTSO-E	Resolved	Normal	IEC 61850-7-500	Single phase and multi phase trip indication for the autorecloser	05/09/2023 09:32 AM
6223	IEC 61850 User Feedback Task Force	Feature	58	RTE	In Progress	Normal	IEC 61850-7-4	Parameters not available in standardized GAPC LN - StrVal	02/28/2023 09:42 AM
6224	IEC 61850 User Feedback Task Force	Feature	59	RTE	In Progress	Normal	IEC 61850-7-4	Parameters not available in standardized GAPC LN - SetRef	02/28/2023 09:42 AM
5082	IEC 61850 User Feedback Task Force	Feature	6	MH	Resolved	Normal	IEC 61850-7-4,7-5	Clarifications on the local/remote concept 2/8	06/05/2023 01:58 AM

#	Project	Tracker	ID	Source	Status	Priority	Standard(s)	Subject	Updated
607	IEC 61850 User Feedback Task Force	Support	6	H30	In Progress	Normal	IEC 61850-80-6 (90-2)	LPHD.Sim management	06/21/2022 02:09 AM
6225	IEC 61850 User Feedback Task Force	Feature	60	RTE	In Progress	Normal	IEC 61850-7-4	Parameters not available in standardized LN - SetPhsOrig	02/28/2023 09:42 AM
5083	IEC 61850 User Feedback Task Force	Feature	7	MH	Resolved	Normal	IEC 61850-7-1 Ed2.1,7-5	Clarifications on the local/remote concept 3/8	06/05/2023 01:58 AM
608	IEC 61850 User Feedback Task Force	Feature	7	H30	In Progress	Normal	IEC 61850-90-xx	Comprehensive set of requirements covering validation and supervision of all IEC 61850 communications	06/21/2022 02:09 AM
5084	IEC 61850 User Feedback Task Force	Feature	8	MH	Resolved	Normal	IEC 61850-7-1 Ed2.1,7-5	Clarifications on the local/remote concept 4/8	06/05/2023 01:58 AM
5085	IEC 61850 User Feedback Task Force	Feature	9	MH	Resolved	Normal	IEC 61850 7-1 / 7-4 Ed2.1,7-5	Clarifications on the local/remote concept 5/8	06/05/2023 01:58 AM