IEC 61850 Certificate - IEC 61850 Certificate #1871

SCD5200 [Invensys Operations Management]

07/08/2021 04:13 PM - Herbert Falk

Status:	Approved		
Priority:	Normal		
61850 Edition:	Edition 1	**Certificate Name:**	30107062-Consulting 11-0099rev2
61850 Tested Aspects:	Client	**Certificate Hash:**	A5049B386005E88D67D21BF0C8BD5F6CCF4524ABED98EE0CD923D3A54253FD1C
Company:	Invensys Operations Management	**Vendor Artifact File Name:**	
Address:	5601 Granite Parkway III, Suite 1000 Plano, Texas 75024 U.S.A.	**Vendor Artifact Hash:**	
Product:	SCD5200	**Umbrella Organization:**	
HW Version:	Invensys Station Computing Dev	**Optional Reservation Test:**	No
SW Version:	SY-1101205	**Serial Number:**	
Key Words:		**Publisher Legacy Variants:**	
Test Procedure Version:	1.1	**Publisher Preferred Rates:**	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), SBO Control (12b), Unbuffered Reporting (B5)	**Publisher Preferred Variants:**	
Certificate/Result Reviewer:	rebecca.davenport,kathy.ellis	**Subscriber Legacy Variants:**	
Approval Date:	05/23/2015	**Subscriber Preferred Variants:**	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	**Subscriber Preferred Rates:**	
Current Test Lab Name:	DNV Netherlands (A)	**Product Variants:**	
Test Document:			

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:13 PM - Herbert Falk

- File 11-0099rev2_Invensys_SCD5200_Certificate.pdf added

Files

11-0099rev2_Invensys_SCD5200_Certificate.pdf	323 KB	07/08/2021	Herbert Falk