

IEC 61850 Certificate - IEC 61850 Certificate #1872

COPA-DATA IEC850 [Ing. Punzenberger COPA-DATA GmbH]

07/08/2021 04:13 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	30107068-Consulting 11-0196
61850 Edition:	Edition 1	Certificate Hash:	28DEF05E0C7E6E60BB71096DFBFA19 650FB089980F7E5E244E865B85CA3C 8D6F
61850 Tested Aspects:	Client	Vendor Artifact File Name:	
Company:	Ing. Punzenberger COPA-DATA GmbH	Vendor Artifact Hash:	
Address:	Karolingerstr.7B 5020 Salzburg Austria	Umbrella Organization:	
Product:	COPA-DATA IEC850	Optional Reservation Test:	No
HW Version:	Windows 7 Pro x64	Serial Number:	
SW Version:	6.51.0.4101	Publisher Legacy Variants:	
Key Words:		Publisher Preferred Rates:	
Test Procedure Version:	1.1	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), SBO Control (12b), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	rebecca.davenport,kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	05/23/2015	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:13 PM - Herbert Falk

- File 11-0196_Punzenberger_COPA-DATA_IEC850_-_Driver_for_IEC61850_added

Files

11-0196_Punzenberger_COPA-DATA_IEC850_-_Driver_for_IEC61850.pdf	0.88 MB	07/08/2021	Herbert Falk
---	---------	------------	--------------