

IEC 61850 Certificate - IEC 61850 Certificate #1878

CCU 1000 Central Control Unit [GE Digital Energy]

07/08/2021 04:13 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	74100681-MOC/INC 12-01140
61850 Edition:	Edition 1	Certificate Hash:	CCC121645747FB8B06E34064C9A19F89694C69AFD54AE8653CD942D54734879E
61850 Tested Aspects:	Client	Vendor Artifact File Name:	
Company:	GE Digital Energy	Vendor Artifact Hash:	
Address:	Av. Pinoa, 10 48170 Zamudio Spain	Umbrella Organization:	
Product:	CCU 1000 Central Control Unit	Optional Reservation Test:	No
HW Version:	1.6	Serial Number:	
SW Version:	1.0	Publisher Legacy Variants:	
Key Words:		Publisher Preferred Rates:	
Test Procedure Version:	1.1	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), SBO Control (12b), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	rebecca.davenport,kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	05/30/2015	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:13 PM - Herbert Falk

- File 12-01140_GE_CCU1000_Certificate.pdf added

Files

12-01140_GE_CCU1000_Certificate.pdf	3.42 MB	07/08/2021	Herbert Falk
-------------------------------------	---------	------------	--------------