

IEC 61850 Certificate - IEC 61850 Certificate #1880

YOUHO [YOUHO ELECTRIC IND. CO., LTD.]

07/08/2021 04:13 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	74101900-MOC/INC 12-01538
61850 Edition:	Edition 1	Certificate Hash:	052EE9CFCBE6C4E71FD108B5284D3 F6BF8CD88C9027C44943DFFF121F1C AA035
61850 Tested Aspects:	Client	Vendor Artifact File Name:	
Company:	YOUHO ELECTRIC IND. CO., LTD.	Vendor Artifact Hash:	
Address:	217, Hwahap-ro, Gwangjeok-Myeon, Yangju-si, Gyeonggi-do, Korea	Umbrella Organization:	
Product:	YOUHO	Optional Reservation Test:	No
HW Version:	LG XNOTE A530/Win 7 Pro	Serial Number:	
SW Version:	1.0	Publisher Legacy Variants:	
Key Words:		Publisher Preferred Rates:	
Test Procedure Version:	1.1	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), SBO Control (12b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	rebecca.davenport,kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	05/30/2015	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:13 PM - Herbert Falk

- File 12-01538_Youho_Electric_IEC61850_Client_Certificate.pdf added

Files

12-01538_Youho_Electric_IEC61850_Client_Certificate.pdf	286 KB	07/08/2021	Herbert Falk
---	--------	------------	--------------