

IEC 61850 Certificate - IEC 61850 Certificate #1881

Broderson RTU32 [Brodersen A/S]

07/08/2021 04:13 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	74102166-MOC/INC 13-0419
61850 Edition:	Edition 1	Certificate Hash:	44E9A38B01ED85EAD74C0575351CA7 7EE32E528F43FCAE924B284E7F7476 51D7
61850 Tested Aspects:	Client	Vendor Artifact File Name:	
Company:	Brodersen A/S	Vendor Artifact Hash:	
Address:	Islevdalvej 187 DK-2610 Roedovre Denmark	Umbrella Organization:	
Product:	Broderson RTU32	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	1.52	Publisher Legacy Variants:	
Key Words:		Publisher Preferred Rates:	
Test Procedure Version:	1.1	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), SBO Control (12b), Setting Group (B4), Setting Group Definition (B4+), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	rebecca.davenport,kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	05/30/2015		
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:13 PM - Herbert Falk

- File 13-0419_Brodersen_RTU32_Client_Certificate.pdf added

Files

13-0419_Brodersen_RTU32_Client_Certificate.pdf	308 KB	07/08/2021	Herbert Falk
--	--------	------------	--------------