IEC 61850 Certificate - IEC 61850 Certificate #1882

YSSA-Gateway [YOUSUNG Instrument & Electric Co., Ltd.]

07/08/2021 04:13 PM - Herbert Falk

Status:	Approved		
Priority:	Normal		
61850 Edition:	Edition 1	**Test Document:**	
61850 Tested Aspects:	Client	**Certificate Name:**	13-043685-01
Company:	YOUSUNG Instrument & Electric Co., Ltd.	**Certificate Hash:**	E80A5AE7D5D9236A7344B9EDF697CF7302067E87D3287828B572899EB9B686E9
Address:	7-13, Songdo-dong, Yeonsu-gu, Incheon Metropolitan City	**Vendor Artifact File Name:**	
Product:	YSSA-Gateway	**Vendor Artifact Hash:**	
HW Version:	Advantech UNO-4683C/Win 7	**Umbrella Organization:**	
SW Version:	1.0	**Optional Reservation Test:**	No
Key Words:		**Serial Number:**	
Test Procedure Version:	1.1	**Publisher Legacy Variants:**	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), SBO Control (12b), Setting Group (B4), Setting Group Definition (B4+), Time Synchronization (B13), Unbuffered Reporting (B5)	**Publisher Preferred Rates:**	
Certificate/Result Reviewer:	rebecca.davenport,kathy.ellis	**Publisher Preferred Variants:**	
Approval Date:	05/30/2015	**Subscriber Legacy Variants:**	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-4, 61850-8-1	**Subscriber Preferred Variants:**	
Current Test Lab Name:	Korea Testing Laboratory (A)	**Subscriber Preferred Rates:**	

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:13 PM - Herbert Falk

- File 13-043685-01-Yousung_rev1.pdf added

Files

13-043685-01-Yousung_rev1.pdf	79.4 KB	07/08/2021	Herbert Falk