

IEC 61850 Certificate - IEC 61850 Certificate #1884

SCD5200 [Invensys Operations Management]

07/08/2021 04:13 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	74104097-MOC/INC 13-1175
61850 Edition:	Edition 1	Certificate Hash:	F648D0FCC564F7F016DCD185056CF6 3425F16B8B63D1C1860500C0445FA99 65D
61850 Tested Aspects:	Client	Vendor Artifact File Name:	
Company:	Invensys Operations Management	Vendor Artifact Hash:	
Address:	5601 Granite Parkway III, Suite 1000 Plano, Texas 75024 USA	Umbrella Organization:	
Product:	SCD5200	Optional Reservation Test:	No
HW Version:	Invensys Station Computing Dev	Serial Number:	
SW Version:	SY-1101205_F	Publisher Legacy Variants:	
Key Words:		Publisher Preferred Rates:	
Test Procedure Version:	1.1	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), SBO Control (12b), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	rebecca.davenport,kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	05/30/2015	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		

Description
This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:13 PM - Herbert Falk

- File 13-1175_Invensys_SCD5200_Client_Certificate.pdf added

Files

13-1175_Invensys_SCD5200_Client_Certificate.pdf	294 KB	07/08/2021	Herbert Falk
---	--------	------------	--------------