IEC 61850 Certificate - IEC 61850 Certificate #1885

SMP 16 / CP-PM [Cooper Power Systems]

07/08/2021 04:13 PM - Herbert Falk

Status:	Approved		
Priority:	Normal		
61850 Edition:	Edition 1	**Certificate Name:**	74104095-MOC/INC 13-1214
61850 Tested Aspects:	Client	**Certificate Hash:**	B70CAB879EFBA4CC30A1229F1AC49C27D4614BDA556529A3A2DC74871484833C
Company:	Cooper Power Systems	**Vendor Artifact File Name:**	
Address:	730 Commerciale Street, Suite 200 Saint-Jean-Chrysostome Quebec, Canada	**Vendor Artifact Hash:**	
Product:	SMP 16 / CP-PM	**Umbrella Organization:**	
HW Version:	V 6.2C374104095	**Optional Reservation Test:**	No
SW Version:		**Serial Number:**	
Key Words:		**Publisher Legacy Variants:**	
Test Procedure Version:	1.1	**Publisher Preferred Rates:**	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), SBO Control (12b), Time Synchronization (B13), Unbuffered Reporting (B5)	**Publisher Preferred Variants:**	
Certificate/Result Reviewer:	rebecca.davenport,kathy.ellis	**Subscriber Legacy Variants:**	
Approval Date:	05/30/2015	**Subscriber Preferred Variants:**	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	**Subscriber Preferred Rates:**	
Current Test Lab Name:	DNV Netherlands (A)	**Product Variants:**	
Test Document:			

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:13 PM - Herbert Falk

- File 13-1214_Cooper_SMP16CPPM_Client_Certificate.pdf added

Files

13-1214_Cooper_SMP16CPPM_Client_Certificate.pdf	288 KB	07/08/2021	Herbert Falk