

IEC 61850 Certificate - IEC 61850 Certificate #1887

SEL-3530 RTAC [Schweitzer Engineering Laboratories, Inc.]

07/08/2021 04:13 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	74101693-MOC/INC 13-1226
61850 Edition:	Edition 1	Certificate Hash:	DA9B933C1CF99949A770478BF2EE23 5B19E400FB762D855361CDEBA95D91 1FD8
61850 Tested Aspects:	Client	Vendor Artifact File Name:	
Company:	Schweitzer Engineering Laboratories, Inc.	Vendor Artifact Hash:	
Address:	2350 NE Hopkins Court Pullman, WA 99163 USA	Umbrella Organization:	
Product:	SEL-3530 RTAC	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	R122	Publisher Legacy Variants:	
Key Words:		Publisher Preferred Rates:	
Test Procedure Version:	1.1	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), SBO Control (12b), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	rebecca.davenport,bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	05/30/2015	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	ABB Switzerland Ltd. (B)		
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:13 PM - Herbert Falk

- File 13-1226_SEL_3530_Client_Certificate.pdf added

Files

13-1226_SEL_3530_Client_Certificate.pdf	301 KB	07/08/2021	Herbert Falk
---	--------	------------	--------------