

IEC 61850 Certificate - IEC 61850 Certificate #1892

PowerScene [AnyGate Corp.]

07/08/2021 04:14 PM - Herbert Falk

| | | | |
|--|--|---------------------------------------|--|
| Status: | Approved | Test Document: | |
| Priority: | Normal | Certificate Name: | 74104126-MOC/INC 13-2294 |
| 61850 Edition: | Edition 1 | Certificate Hash: | 03172B156BB980C5B2E4DF3C3CA0D5 82E6EB7EDD0E4DF6BC750B05DA85F F0DBA |
| 61850 Tested Aspects: | Client | Vendor Artifact File Name: | |
| Company: | AnyGate Corp. | Vendor Artifact Hash: | |
| Address: | 8F, Byucksan Digital Valey 7-cha B/D Guru Digital Complex Guru Gu. Seoul Korea | Umbrella Organization: | |
| Product: | PowerScene | Optional Reservation Test: | No |
| HW Version: | Samsung SENS SF3111/Win 7 Home P | Serial Number: | |
| SW Version: | 1.0.0 | Publisher Legacy Variants: | |
| Key Words: | | Publisher Preferred Rates: | |
| Test Procedure Version: | 1.1 | Publisher Preferred Variants: | |
| IEC 61850 Blocks Certified: | Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), SBO Control (12b), Setting Group (B4), Setting Group Definition (B4+), Time Synchronization (B13), Unbuffered Reporting (B5) | Subscriber Legacy Variants: | |
| Certificate/Result Reviewer: | rebecca.davenport,kathy.ellis | Subscriber Preferred Variants: | |
| Approval Date: | 05/30/2015 | Subscriber Preferred Rates: | |
| Standards Tested: | 61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1 | | |
| Current Test Lab Name: | DNV Netherlands (A) | | |
| Description | | | |
| This certificate and its information was migrated from a previous database | | | |

History

#1 - 07/08/2021 04:14 PM - Herbert Falk

- File 13-2294_Anygate_PowerScene_Client_Certificate.pdf added

Files

| | | | |
|---|--------|------------|--------------|
| 13-2294_Anygate_PowerScene_Client_Certificate.pdf | 327 KB | 07/08/2021 | Herbert Falk |
|---|--------|------------|--------------|