

# IEC 61850 Certificate - IEC 61850 Certificate #1896

## CimWay for PcVue [ARC Informatique ]

07/08/2021 04:14 PM - Herbert Falk

|                                     |   |                                       |  |
|-------------------------------------|---|---------------------------------------|--|
| <b>Status:</b>                      | Approved  | <b>Test Document:</b>                 |  |
| <b>Priority:</b>                    | Normal  | <b>Certificate Name:</b>              | 74104241-MOC/INC 13-2966   |
| <b>61850 Edition:</b>               | Edition 1   | <b>Certificate Hash:</b>              | CA4C8D4630C5901093325B0AF4DFEE<br>7B6630A66FF07179F0B877F51BC6751<br>1CB |
| <b>61850 Tested Aspects:</b>        | Client  | <b>Vendor Artifact File Name:</b>     |  |
| <b>Company:</b>                     | ARC Informatique  | <b>Vendor Artifact Hash:</b>          |  |
| <b>Address:</b>                     | 2 Avenue de la Cristallerie<br>92310 SEVRES<br>France   | <b>Umbrella Organization:</b>         |  |
| <b>Product:</b>                     | CimWay for PcVue  | <b>Optional Reservation Test:</b>     | No   |
| <b>HW Version:</b>                  | Dell Precision T1650/Win Server   | <b>Serial Number:</b>                 |  |
| <b>SW Version:</b>                  | 11.0.2021.2290  | <b>Publisher Legacy Variants:</b>     |  |
| <b>Key Words:</b>                   |   | <b>Publisher Preferred Rates:</b>     |  |
| <b>Test Procedure Version:</b>      | 1.1   | <b>Publisher Preferred Variants:</b>  |  |
| <b>IEC 61850 Blocks Certified:</b>  | Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), SBO Control (12b), Unbuffered Reporting (B5) | <b>Subscriber Legacy Variants:</b>    |  |
| <b>Certificate/Result Reviewer:</b> | rebecca.davenport,kathy.ellis   | <b>Subscriber Preferred Variants:</b> |  |
| <b>Approval Date:</b>               | 06/01/2015  | <b>Subscriber Preferred Rates:</b>    |  |
| <b>Standards Tested:</b>            | 61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1  |                                       |  |
| <b>Current Test Lab Name:</b>       | DNV Netherlands (A)   |                                       |  |

### Description

This certificate and its information was migrated from a previous database

### History

#1 - 07/08/2021 04:14 PM - Herbert Falk

- File 13-2966\_ARCInformatique\_CimWay\_PcVue\_Client\_Certificate.pdf added

### Files

|   |        |            |              |
|---|--------|------------|--------------|
| 13-2966_ARCInformatique_CimWay_PcVue_Client_Certificate.pdf | 165 KB | 07/08/2021 | Herbert Falk |
|---|--------|------------|--------------|