

IEC 61850 Certificate - IEC 61850 Certificate #1898

sgs commshub [Smarter Grid Solutions]

07/08/2021 04:14 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	74104881-MOC/INC 13-3100
61850 Edition:	Edition 1	Certificate Hash:	A60C484E9523C5E537001DBF3AFE1E A668816BC1E30430675079342B038FE 91B
61850 Tested Aspects:	Client	Vendor Artifact File Name:	
Company:	Smarter Grid Solutions	Vendor Artifact Hash:	
Address:	Corunna House 39 Cadogan Street Glasgow, G2 7AB United Kingdom	Umbrella Organization:	
Product:	sgs commshub	Optional Reservation Test:	No
HW Version:	HP Proliant DL385p Gen 8/Win Ser	Serial Number:	
SW Version:	2.2.0	Publisher Legacy Variants:	
Key Words:		Publisher Preferred Rates:	
Test Procedure Version:	1.1	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), SBO Control (12b), Substitution (B3), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	rebecca.davenport,kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	06/01/2015	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:14 PM - Herbert Falk

- File 13-3100_SGS_comms_hub_-_Smarter_Grid_Solutions_61850_client added

Files

13-3100_SGS_comms_hub_-_Smarter_Grid_Solutions_61850_client.pdf 60 KB

07/08/2021

Herbert Falk