IEC 61850 Certificate - IEC 61850 Certificate #1900

SICAM CMIC [Siemens AG]

07/08/2021 04:14 PM - Herbert Falk

Status:	Approved		
Priority:	Normal		
61850 Edition:	Edition 1	**Test Document:**	
61850 Tested Aspects:	Client	**Certificate Name:**	12141001-OPE/INC 14-1085
Company:	Siemens AG	**Certificate Hash:**	0706D7AD87AED916D14ED20CCE51C78F547226E7D5F7773959A3AE536CC8A6B0
Address:	IC SG EA PRO Humboldstr. 59 90459 Nuremberg Germany	**Vendor Artifact File Name:**	
Product:	SICAM CMIC	**Vendor Artifact Hash:**	
HW Version:	6MF21010AB100AA0CC	**Umbrella Organization:**	
SW Version:	ET83 Rev. 01	**Optional Reservation Test:**	No
Key Words:		**Serial Number:**	
Test Procedure Version:	1.1	**Publisher Legacy Variants:**	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), Unbuffered Reporting (B5)	**Publisher Preferred Rates:**	
Certificate/Result Reviewer:	rebecca.davenport,kathy.ellis	**Publisher Preferred Variants:**	
Approval Date:	06/01/2015	**Subscriber Legacy Variants:**	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	**Subscriber Preferred Variants:**	
Current Test Lab Name:	DNV Netherlands (A)	**Subscriber Preferred Rates:**	

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:14 PM - Herbert Falk

- File 14-1085_Siemens_SICAM_CMIC_Client_Certificate.PDF added

Files

14-1085_Siemens_SICAM_CMIC_Client_Certificate.PDF	2.48 MB	07/08/2021	Herbert Falk