

IEC 61850 Certificate - IEC 61850 Certificate #1902

PCS-9700 SCADA/HMI Workstation [NR Electric Co., Ltd.]

07/08/2021 04:14 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	74105929-OPE/INC 14-1822
61850 Edition:	Edition 1	Certificate Hash:	B5824824948A079E42BEB92081C9081 83CA9A54C1588F8C87984B8C3F8443 625
61850 Tested Aspects:	Client	Vendor Artifact File Name:	
Company:	NR Electric Co., Ltd.	Vendor Artifact Hash:	
Address:	69, Suyuan Avenue Nanjing 211102 China	Umbrella Organization:	
Product:	PCS-9700 SCADA/HMI Workstation	Optional Reservation Test:	No
HW Version:	HP 7600/Win 7 Pro	Serial Number:	
SW Version:	R1 (2014-04-27)	Publisher Legacy Variants:	
Key Words:		Publisher Preferred Rates:	
Test Procedure Version:	1.1	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), SBO Control (12b), Setting Group (B4), Setting Group Definition (B4+), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	rebecca.davenport,kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	06/01/2015		
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:14 PM - Herbert Falk

- File 14-1822_NARI_PCS-9700_Client_Certificate.pdf added

Files

14-1822_NARI_PCS-9700_Client_Certificate.pdf	2.29 MB	07/08/2021	Herbert Falk
--	---------	------------	--------------