

IEC 61850 Certificate - IEC 61850 Certificate #1907

ME-RTU [INEA d.o.o.]

07/08/2021 04:18 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	74106906-OPE/INC 15-0760
61850 Edition:	Edition 1	Certificate Hash:	F8EB1E103986C10670695ED3138F981 160D4CAB2F2BC0D9CBEC66CFCC8F 5DECC
61850 Tested Aspects:	Client	Vendor Artifact File Name:	
Company:	INEA d.o.o.	Vendor Artifact Hash:	
Address:	Stegne 11 SI-1000 Ljubljana Slovenia	Umbrella Organization:	
Product:	ME-RTU	Optional Reservation Test:	No
HW Version:	1.23	Serial Number:	
SW Version:	90.34	Publisher Legacy Variants:	
Key Words:		Publisher Preferred Rates:	
Test Procedure Version:	1.1	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), SBO Control (12b), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	rebecca.davenport,kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	06/01/2015	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		

Description
This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:18 PM - Herbert Falk

- File 15-0760_INEA_ME-RTU_ClientEd1_Certificate.pdf added

Files

15-0760_INEA_ME-RTU_ClientEd1_Certificate.pdf	1.68 MB	07/08/2021	Herbert Falk
---	---------	------------	--------------