

IEC 61850 Certificate - IEC 61850 Certificate #1908

Foxboro Evo SCD6000 [Invensys Systems, Inc.]

07/08/2021 04:18 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	74106941-OPE/INC 15-0952_rev1
61850 Edition:	Edition 1	Certificate Hash:	5B94D20ECFE3DED51FD5DDBCD8DB 8DA60DBE48B52A56F600EDCA3F0C7 0C7FAA2
61850 Tested Aspects:	Client	Vendor Artifact File Name:	
Company:	Invensys Systems, Inc.	Vendor Artifact Hash:	
Address:	38 Neponset Avenue Foxborough, MA 02035 U.S.A.	Umbrella Organization:	
Product:	Foxboro Evo SCD6000	Optional Reservation Test:	No
HW Version:	SY-60399002R	Serial Number:	
SW Version:	SY1101207B	Publisher Legacy Variants:	
Key Words:		Publisher Preferred Rates:	
Test Procedure Version:	1.1	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), SBO Control (12b), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	rebecca.davenport,kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	06/01/2015	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		

Description
This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:18 PM - Herbert Falk

- File 15-0952_InvensysSystems_Foxboro_EvoSCD6000_ClientEd1_Certifi added

Files

15-0952_InvensysSystems_Foxboro_EvoSCD6000_ClientEd1_Certifi	79.0 KB	07/08/2021	Herbert Falk
--	---------	------------	--------------