

IEC 61850 Certificate - IEC 61850 Certificate #1912

Transformer Protection Relay-T [M/s. Easun Reyrolle Ltd. (ERLPhase)]

07/08/2021 04:18 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	UARC/PL/C0165/2010
61850 Edition:	Edition 1	Certificate Hash:	4F52E58F49E91427F81047B60AB40F1 99DA5F0EAA6707744B308C744336642 A1
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	M/s. Easun Reyrolle Ltd. (ERLPhase)	Vendor Artifact Hash:	
Address:	98, Sipcot Industrial Complex Hosur - 635126 India	Umbrella Organization:	
Product:	Transformer Protection Relay-T	Optional Reservation Test:	No
HW Version:	1.0	Serial Number:	
SW Version:	1.0	Publisher Legacy Variants:	
Key Words:	Protection, Relay	Publisher Preferred Rates:	
Test Procedure Version:	2.2	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Setting Group (B4), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	rebecca.davenport,bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	06/06/2015		
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Central Power Research Institute India (A)		

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:18 PM - Herbert Falk

- File 0165-2011_Easun_Reyrolle-TPRO.pdf added

Files

0165-2011_Easun_Reyrolle-TPRO.pdf	1.26 MB	07/08/2021	Herbert Falk
-----------------------------------	---------	------------	--------------