IEC 61850 Certificate - IEC 61850 Certificate #1913

Areva MiCOM P145 Feeder Mgmt [Areva T&D]

07/08/2021 04:18 PM - Herbert Falk

Status:	Approved		
Priority:	Normal		
61850 Edition:	Edition 1	**Certificate Name:**	30710079-Consulting 07-0408
61850 Tested Aspects:	Server	**Certificate Hash:**	2F14EF5C0AF2F1E1C5C07A6F94E3398DE49CEE4B4709FAF66528B67202A24862
Company:	Areva T&D	**Vendor Artifact File Name:**	
Address:	St. Leonards Avenue ST17 4LX Stafford United Kingdom	**Vendor Artifact Hash:**	
Product:	Areva MiCOM P145 Feeder Mgmt	**Umbrella Organization:**	
HW Version:		**Optional Reservation Test:**	No
SW Version:	35D	**Serial Number:**	
Key Words:	Relay	**Publisher Legacy Variants:**	
Test Procedure Version:	1.1	**Publisher Preferred Rates:**	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Data Sets (B2), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Time Synchronization (B13), Unbuffered Reporting (B5)	**Publisher Preferred Variants:**	
Certificate/Result Reviewer:	rebecca.davenport,kathy.ellis	**Subscriber Legacy Variants:**	
Approval Date:	06/06/2015	**Subscriber Preferred Variants:**	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	**Subscriber Preferred Rates:**	
Current Test Lab Name:	DNV Netherlands (A)	**Product Variants:**	
Test Document:			

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:18 PM - Herbert Falk

- File 07-0408-Certificate_Areva_P145.pdf added

Files

07-0408-Certificate_Areva_P145.pdf	297 KB	07/08/2021	Herbert Falk