

IEC 61850 Certificate - IEC 61850 Certificate #1913

Areva MiCOM P145 Feeder Mgmt [Areva T&D]

07/08/2021 04:18 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	30710079-Consulting 07-0408
61850 Edition:	Edition 1	Certificate Hash:	2F14EF5C0AF2F1E1C5C07A6F94E339 8DE49CEE4B4709FAF66528B67202A2 4862
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Areva T&D	Vendor Artifact Hash:	
Address:	St. Leonards Avenue ST17 4LX Stafford United Kingdom	Umbrella Organization:	
Product:	Areva MiCOM P145 Feeder Mgmt	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	35D	Publisher Legacy Variants:	
Key Words:	Relay	Publisher Preferred Rates:	
Test Procedure Version:	1.1	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Data Sets (B2), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	rebecca.davenport,kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	06/06/2015	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:18 PM - Herbert Falk

- File 07-0408-Certificate_Areva_P145.pdf added

Files

07-0408-Certificate_Areva_P145.pdf

297 KB

07/08/2021

Herbert Falk