

# IEC 61850 Certificate - IEC 61850 Certificate #1914

## Areva MiCOM P442/P444 Distance [Areva T&D]

07/08/2021 04:18 PM - Herbert Falk

<b>Status:</b>	Approved	<b>Test Document:</b>	
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	30710079-Consulting 07-0410
<b>61850 Edition:</b>	Edition 1	<b>Certificate Hash:</b>	18993EAB10BAE694B5EB5211AA9EC2 ADE909E5C7138344544DEFBE33B411 CADB
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	Areva T&D	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	St. Leonards Avenue ST17 4LX Stafford United Kingdom	<b>Umbrella Organization:</b>	
<b>Product:</b>	Areva MiCOM P442/P444 Distance	<b>Optional Reservation Test:</b>	No
<b>HW Version:</b>		<b>Serial Number:</b>	
<b>SW Version:</b>	C3.9	<b>Publisher Legacy Variants:</b>	
<b>Key Words:</b>	Distance, Relay	<b>Publisher Preferred Rates:</b>	
<b>Test Procedure Version:</b>	1.1	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Data Sets (B2), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Time Synchronization (B13), Unbuffered Reporting (B5)	<b>Subscriber Legacy Variants:</b>	
<b>Certificate/Result Reviewer:</b>	rebecca.davenport,kathy.ellis	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	06/06/2015	<b>Subscriber Preferred Rates:</b>	
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	DNV Netherlands (A)		
<b>Description</b>			
This certificate and its information was migrated from a previous database			

### History

#1 - 07/08/2021 04:18 PM - Herbert Falk

- File 07-0410-Certificate\_Areva\_P442.pdf added

### Files

07-0410-Certificate\_Areva\_P442.pdf

297 KB

07/08/2021

Herbert Falk