IEC 61850 Certificate - IEC 61850 Certificate #1916

MiCOM P634 Transformator-Diffe [Areva T&D]

07/08/2021 04:18 PM - Herbert Falk

Status:	Approved		
Priority:	Normal		
61850 Edition:	Edition 1	**Test Document:**	
61850 Tested Aspects:	Server	**Certificate Name:**	30710079-Consulting 07-0416
Company:	Areva T&D	**Certificate Hash:**	1ACC0417D41E191CA15C3BBE991B6194C4498494CFCA60A9D2E17F6FFB5471D4
Address:	Lyoner Strasse 44-48 D-60528 Frankfurt am Main Germany	**Vendor Artifact File Name:**	
Product:	MiCOM P634 Transformator-Diffe	**Vendor Artifact Hash:**	
HW Version:		**Umbrella Organization:**	Schneider Electric
SW Version:	611-203	**Optional Reservation Test:**	No
Key Words:	Differential, Protection	**Serial Number:**	
Test Procedure Version:	1.1	**Publisher Legacy Variants:**	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Data Sets (B2), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Time Synchronization (B13), Unbuffered Reporting (B5)	**Publisher Preferred Rates:**	
Certificate/Result Reviewer:	rebecca.davenport,kathy.ellis	**Publisher Preferred Variants:**	
Approval Date:	06/06/2015	**Subscriber Legacy Variants:**	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	**Subscriber Preferred Variants:**	
Current Test Lab Name:	DNV Netherlands (A)	**Subscriber Preferred Rates:**	

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:18 PM - Herbert Falk

- File 07-0416-Areva-P634-Certificate.pdf added

#2 - 07/09/2021 09:15 AM - Herbert Falk

- Umbrella Organization set to Schneider Electric

Files

07-0416-Areva-P634-Certificate.pdf	271 KB	07/08/2021	Herbert Falk