

IEC 61850 Certificate - IEC 61850 Certificate #1920

ECI 850 Sepam Server [Schneider Electric]

07/08/2021 04:18 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	30620311-Consulting 07-1309
61850 Edition:	Edition 1	Certificate Hash:	A03B5598477A35CBE70197182908470 F6EE2BD2327EA46786F9303D3FA009 7E0
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Schneider Electric	Vendor Artifact Hash:	
Address:	Power Monitoring & Control (PMC) Electropole - 38EQI 38050 GRENOBLE CEDEX 9 France	Umbrella Organization:	Schneider Electric
Product:	ECI 850 Sepam Server	Optional Reservation Test:	No
HW Version:	Sepam Series 40	Serial Number:	
SW Version:	1.2	Publisher Legacy Variants:	
Key Words:		Publisher Preferred Rates:	
Test Procedure Version:	1.1	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), Setting Group (B4), Time Synchronization (B13)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	rebecca.davenport,kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	06/06/2015	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:18 PM - Herbert Falk

- File 07-1309-Schneider-SepamServer-Certificate.pdf added

#2 - 07/09/2021 09:31 AM - Herbert Falk

- Umbrella Organization set to Schneider Electric

Files

07-1309-Schneider-SepamServer-Certificate.pdf	340 KB	07/08/2021	Herbert Falk
---	--------	------------	--------------