

# IEC 61850 Certificate - IEC 61850 Certificate #1927

## Areva MiCOM P741 Numerical Bus [Areva T&D]

07/08/2021 04:18 PM - Herbert Falk

<b>Status:</b>	Approved	<b>Test Document:</b>	
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	30710079-Consulting 07-1458
<b>61850 Edition:</b>	Edition 1	<b>Certificate Hash:</b>	676D5C6E112C0FA568302C3306D8EC 1D820EAF0EEDA810AC0AF909749C9 C09B5
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	Areva T&D	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	St. Leonards Avenue ST 17 4LX Stafford United Kingdom	<b>Umbrella Organization:</b>	
<b>Product:</b>	Areva MiCOM P741 Numerical Bus	<b>Optional Reservation Test:</b>	No
<b>HW Version:</b>		<b>Serial Number:</b>	
<b>SW Version:</b>	40A	<b>Publisher Legacy Variants:</b>	
<b>Key Words:</b>	Protection	<b>Publisher Preferred Rates:</b>	
<b>Test Procedure Version:</b>	1.1	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Data Sets (B2), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Time Synchronization (B13), Unbuffered Reporting (B5)	<b>Subscriber Legacy Variants:</b>	
<b>Certificate/Result Reviewer:</b>	rebecca.davenport,kathy.ellis	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	06/27/2015	<b>Subscriber Preferred Rates:</b>	
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	DNV Netherlands (A)		

### Description

This certificate and its information was migrated from a previous database

### History

#1 - 07/08/2021 04:18 PM - Herbert Falk

- File 07-1458-Areva-P741-Certificate.pdf added

### Files

07-1458-Areva-P741-Certificate.pdf

699 KB

07/08/2021

Herbert Falk